

**PURCHASING  
AND MATERIALS  
MANAGEMENT**



**City of Myrtle Beach  
SOUTH CAROLINA**

**(843) 918-2170  
FAX: (843) 918-2182  
www.cityofmyrtlebeach.com**

**Addendum #02**

**March 14, 2023**

**IFB 23-B0043**

**Water Heater Replacement Myrtle Beach Convention Center**

The purpose of this Addendum #02 to IFB 23-B0043 for Water Heater Replacement for the Myrtle Beach Convention Center , dated February 20, 2023, is to answer the following questions:

1. Since the BTU rating for the Rinnai Demand Duo Specified is above 199k BTU, It is classified as a boiler. It will have to be registered with the SCLLR and have a boiler inspection. It will also require an Emergency stop button and CO detector, and the installer to have a BL license. Are we also quoting installing these to ensure it is up to code, as i saw the City will be responsible for all inspections?

**Yes the city will inspect also. Just a note, a state inspection is not a substitute for the city inspection.**

2. My vendor is recommending an acid neutralizer for the condensate that comes from the new heater. Is this something we should include in our bid?

**Yes all contractors should include this in their bid package.**

3. Are we also replacing the expansion tank in the water heater room?

**Yes the expansion tank is also being replaced.**

Thank you,  
City of Myrtle Beach  
David Bernstein  
Purchasing Office/Buyer  
Email: dbernstein@cityofmyrtlebeach.com