



## Georgetown County, South Carolina

129 Screven Street, Suite 239  
Post Office Drawer 421270  
Georgetown, SC 29442-4200  
(843) 545-3083 • Fax (843) 545-3500  
E-Mail • [purch@gtcounty.org](mailto:purch@gtcounty.org)  
Website • <http://www.gtcounty.org>

### ADDENDUM #2 TO Bid #23-017 REBID

BID NUMBER: 23-017 REBID

ISSUE DATE: Friday, June 30, 2023

OPENING DATE: Thurs., July 6, 2023

OPENING TIME: 3:00 PM ET

Pre-Bid Conference/Site Inspection: [None]

#### **PROCUREMENT FOR: Walk-In Freezer for Williamsburg County**

---

---

This addendum will amend **Bid #23-017 REBID, Walk-In Freezer for Williamsburg County** originally issued on Wednesday, June 21, 2023. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: [www.gtcounty.org](http://www.gtcounty.org), select "Bid Opportunities" from the Quick Links section.

---

**Question #1:** The spec calls for 2,500 psf uniformly distributed load for the floor. Our pallet jack floor covers 2,000 psf, would that be sufficient or do you want us to build an extreme load floor? With a standard door, you shouldn't even need a pallet jack rated floor, let alone an extreme load floor.

**Response:** Yes, 2,000 psf will be acceptable.

---

[The Remainder of This Page is Intentionally Left Blank]



## ADDENDUM ACKNOWLEDGEMENT

### Bid #23-017 REBID Walk-In Freezer for Williamsburg County Mandatory Submittal Form

**To be returned with the final proposal submission to Georgetown County.**

COMPANY NAME: \_\_\_\_\_

Addendum #1 Received Date: \_\_\_\_\_ Initialed By: \_\_\_\_\_

Addendum #2 Received Date: \_\_\_\_\_ Initialed By: \_\_\_\_\_

Addendum #3 Received Date: \_\_\_\_\_ Initialed By: \_\_\_\_\_

Addendum #4 Received Date: \_\_\_\_\_ Initialed By: \_\_\_\_\_

Addendum #5 Received Date: \_\_\_\_\_ Initialed By: \_\_\_\_\_

Addendum #6 Received Date: \_\_\_\_\_ Initialed By: \_\_\_\_\_