

**PURCHASING
AND MATERIALS
MANAGEMENT**



**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

**Addendum 002
October 4, 2022
IFB 23-B0017
Fencing at Ocean Woods Cemetery**

The purpose of this Addendum 002 to IFB 23-B0017 for Fencing at Ocean Woods Cemetery, dated September 20, 2022, and previously amended on September 27, 2022, is to provide answers to questions received.

- What treatment is to be used on all the lumber (including post)?
 - All lumber will be pressure treated including posts.
- How far are pickets to be spaced?
 - Pickets are to be spaced four (4) inches apart.
- Will 2x4 posts be on the inside or outside of fence?
 - The 2x4 posts will be on the inside with a distance of 8 feet between posts.
- Will 1x6 be full 1x6 dressed out to be ¾ inch board?
 - The 1x6 pickets will be ¾ inch thick.
- Will all nails be hot dipped galvanized?
 - Yes, all nails will be hot dipped galvanized.
- Additional questions are due no later than 12:00 noon on Tuesday, October 4, 2022. Questions may be submitted via e-mail to lgreenough@cityofmyrtlebeach.com All questions received by the deadline will be answered via addendum. Questions received after the deadline may or may not be answered.
- Sealed bids are due in the Purchasing Office no later than 2:00PM (local time) on Wednesday, October 12, 2022. No electronic submissions will be accepted. The City of Myrtle Beach is not responsible for late or misdirected mail.

Please send in your sealed bid to the address listed below:

City of Myrtle Beach
Purchasing Division
3231 Mr. Joe White Avenue
Myrtle Beach, SC 29577
Attn: Lynda Greenough