

ADDENDUM NO. 1

to the

BID DOCUMENTS

for

**ANCHORS STREET NORTHWEST
STORMWATER IMPROVEMENTS**

CITY OF FORT WALTON BEACH
107 Miracle Strip Parkway, S.W.
Fort Walton Beach, FL 32548

Prepared by:



AVCON, INC.

Engineers & Planners
320 Bayshore Drive, Suite A
Niceville, FL 32578
Phone: (850) 678-0050

Addendum Date: February 7, 2019
AVCON Project: 2017.238.01

Note: The bidder shall acknowledge receipt of this addendum on the Bid Proposal.

ADDED Pay Item 02660-1: 2" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY to Technical Specifications.

ADDED Pay Item 02660-2: 2-1/4" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY to Technical Specifications.

ADDED Pay Item 02660-3: 6" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY to Technical Specifications.

ADDED Pay Item 02660-4: 8" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY to Technical Specifications.

B. Changes to the Drawings:

6. Sheet G3 **REVISED** Summary of Quantities to include Pay Item 02660-1: 2" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY, Pay Item 02660-2: 2-1/4" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY, Pay Item 02660-3: 6" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY, and Pay Item 02660-4: 8" PVC POTABLE WATERLINE & GATE VALVE & BOX ASSEMBLY.

7. Sheets C2-C10 **REMOVED** Key Map.

8. Sheet C6 **REVISED** inverts of STM-P-21, STM-P-22, STM-P-23, STM-P-24, STM-P-25, and STM-P-26.

ADDED approximate locations and sizes of existing water lines and corresponding callouts to detail conflicts.

9. Sheet C7 **REVISED** inverts of STM-P-14, STM-P-14A, STM-P-18, and STM-P-19.

ADDED approximate locations and sizes of existing water lines and corresponding callouts to detail conflicts.

10. C8 **REVISED** locations of STM-28 and STM-29 (shifted approximately 2' north) to avoid conflict with existing sanitary manhole. See note Sheet C8.

11. C9 **ADDED** approximate locations and sizes of existing water lines and corresponding callouts to detail conflicts.

12. C10 **ADDED** approximate locations and sizes of existing water lines and corresponding callouts added detailing conflicts.

13. C11 **REVISED** inverts of STM-P-14, STM-P-14A, STM-P-18, STM-P-19, STM-P-21, STM-P-22, STM-P-23, STM-P-24, STM-P-25, and STM-P-26.

REVISED Northings and Eastings for STM-28 and STM-29.

14. C12

ADDED "WATER LINE CONFLICT DETAIL" and "GATE VALVE AND BOX
DETAIL – 12" & SMALLER."

END OF ADDENDUM NO. 1