

We had a few questions asked about the pad mount transformers so I wanted to share the information.

The secondary voltage should be 240/120. The primary voltage is as stated in the bid packet 7620/13200y.

These should be ANSI Standard type 2.

Please email with any other questions.

Thank you,

**Sandy Vallejo**  
Engineering Specialist  
931-217-3138 cell

---

*Phone* 615.384.6770 ext.113 *Fax* 615.382.1642  
1000 Central Avenue, Springfield, TN 37172  
*E-mail* [svallejo@springfield-tn.org](mailto:svallejo@springfield-tn.org)

---

**SPRINGFIELD ELECTRIC ~ LIGHTING The Path!**

