



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: November 20, 2020
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #1 to Invitation for Bids # 63270 Refurbish L76 and SR512 Airboat Ramps

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your quote documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: How far deep into the water does the wood to be replaced?
A1: The length of the ramp in the water to be replaced is specified in the SOW. The lengths shown are current conditions. Water elevations will recede as we move into the winter months, so the actual length in the water should be less than currently indicated.

Q2: Is it some specific type of stainless-steel anchors to use?
A2: The specific type of stainless steel is 316 SS.

Q3: Who is responsible for pulling the permits?
A3: No permits are required for this project.

Attachments:
Pre-bid Meeting Sign in Sheet
Pre-bid Recording – available upon request

NOTE: The Bid Opening **remains** 2:00 p.m., **Thursday, December 10, 2020**

Please acknowledge receipt of this Addendum on the **BID FORM** provided in the bid package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.