

Magnum Fence and Security Inc.

Lic # 719567

1070 N. Ventura Ave Ventura, CA 93001 (805) 641 3656 Fax (805) 641 3606

REQUEST FOR INFORMATION

Date: May 21, 2021

Adam Dutter
Ojai Unified School District
P 805 640 4300 x1006, adutter@ojaiusd.org

RE: Topa Topa New Electrical Service Fencing

Adam:

The chainlink in the plans is a 9-gauge wire with a 2oz coating, fused bonded green PVC coating and 3/8-inch mesh and is green vinyl coated.

Please note that for this product the zinc coating will have to be applied before weaving. Will that be acceptable?

Since the wire is thick and the weave is tight, there will be scarring at the bends which is unavoidable. Please confirm that this is acceptable.

Please let me know if you have any questions

Regards,
Ralph J. Coolman
Ralph J. Coolman

Cc: Chris Selvey, Taft Electric

Reduce zinc coating to 0.3oz so zinc coating is standard. Provide fence fabric that complies with ASTM F668 Class 2b. Change mesh size to 5/8". Provide green PVC color.

Martin Hartmann
Hartmann Architecture Studio
05/25/21