

**ADDENDUM #2  
TO  
SPECIFICATION AND CONTRACT DOCUMENTS**

**October 2, 2017**

TO: ALL PLAN HOLDERS  
FOR: ITB-018-2017  
Public Restrooms Retrofit

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.**

**The purpose of addenda # 2 is to answer questions received prior to the deadline of Tuesday, September 26, 2017. Answers are in RED.**

1. Will we be required to obtain a permit? **YES**
2. The SOW calls for a tankless toilet rated at .8GPF. There is not a tankless toilet made at .8GPF supplied by a 1/2" water line. Therefore, can a different toilet be proposed? We have found a Zurn 25561 Tanked toilet at 1.0GPF. **YES - 1.0 GPF tanked toilets are acceptable.**
3. Concerning the urinals, the SOW doesn't address these specifically. Does the city want these changed out also with motion detection flush valves? **YES**
4. The SOW doesn't address existing toilets with flush valves. Does the city want these replaced with motion detection flush valves rated at 1.28GPF? **YES** Contractor does not know of a flush valve rated lower than 1.28GPF.

Addendum No. 1      Dated \_\_\_\_\_

Signature: \_\_\_\_\_

Addendum No. 2      Dated \_\_\_\_\_

Signature: \_\_\_\_\_

FAILURE TO SUBMIT ACKNOWLEDGEMENT OF ANY ADDENDUM THAT AFFECTS THE BID PRICES IS CONSIDERED A MAJOR IRREGULARITY AND WILL BE CAUSE FOR REJECTION OF THE BID.

**THIS FORM MUST BE INCLUDED WITH BID PROPOSAL**