



ADDENDUM NO. 1

Issue Date: 06/30/2020

Project Name: Date Flow System Antenna & Tower

Bid Number: 2020049

Bid Opening Date: **July 14, 2020**

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Questions and Answers

1. Considering the COVID 19 pandemic, may we submit our bids via e-mail?
We will not accept bids via email. They can be submitted by mail or other delivery service, or hand delivered. If hand delivering, please note any person entering a County facility is required to wear a mask. Because of COVID-19 the bid opening will be conducted via ZOOM at 2:00 p.m. on July 14.
The link to the opening is: <https://ircgov.zoom.us/j/7837260776>
Or Telephone:
Dial:
USA 602 333 2017
USA 8882045987 (US Toll Free)
Conference code: 153949

Public members will be in listen only mode, but will be able to type questions in the chat after the responses have been opened.
2. Does the County have FAA Determination of No Hazard for the new tower? If not, the old one? Are we expected to obtain a new FAA DNH before stating construction, if necessary?
IRC will apply for an FAA Determination of No Hazard. Contractor will not be expected to obtain.
3. Does the County desire grounding of the new tower? If so, please provide specifications.
The tower is to be grounded per applicable NEC codes.
4. We are to install the communications cables from the antennas to the ground. Do we just coil them up at the bottom of the tower, or are we running them somewhere?

Addendum 1 - 2020049

The contractor will coil cable at the bottom of the tower. DFS will be responsible for installation and testing while contractor is on site.

5. Are we expected to sweep test the communication lines?

No. DFS will be responsible for installation and testing while contractor is on site.