

PUBLIC NOTICE
INVITATION TO BID # 1258

The Springfield Electric Department will be accepting sealed bids for:

Galvanized Steel Poles

Qty – 20	45' galvanized steel pole, ground line 206 ft-kips
Qty - 20	50' galvanized steel pole, ground line 231 ft-kips
Qty - 20	55' galvanized steel pole, ground line 252 ft-kips
Qty - 4	75' galvanized steel pole, ground line 632 ft-kips
Qty - 2	80' galvanized steel pole, ground line 813 ft-kips
Qty - 1	85' galvanized steel pole, ground line 866 ft-kips

Specifications and bid requirements may be download at www.springfieldtn.gov. Please contact Sandy Vallejo at (931) 217-3138 with questions. Please reference **BID NUMBER 1258** on the outside of the sealed envelope. Sealed bids must be received in the Office of the City Recorder, 405 North Main Street, Springfield, TN 37172 by 2:30 pm local time, Tuesday, September 12, 2023.

The City of Springfield reserves the right to reject any or all bids.

Lisa H. Crockett
City Recorder

Galvanized Steel Poles

Qty.	Description	Price	Manufacturer	Delivery
20	45' galvanized steel poles, minimum ultimate capacity at GL, 206 ft-kips			
20	50' galvanized steel poles, minimum ultimate capacity at GL, 231 ft-kips			
20	55' galvanized steel poles, minimum ultimate capacity at GL, 252 ft-kips			

All poles must meet the following specifications:

Material to be: ASTM A572 galvanized. Fy-65 ksi with a Charpy V-Notch Impact Value of 15 foot-pounds @ -20 F/-29 C. Heat Load Tested.

Have welded butt and top, no detachable top or bottom plates

Must be single piece

Includes 7/8" holes per attached drill specification sheets

Polyurethane coating applied at 16 mils minimum thickness from butt of pole to 2' above ground line.

4' Ground sleeve, 2' above to 2' below ground line

NEMA 2 hole ground lug, 3' above ground line

ADDITIONAL NEMA 2 hole ground lugs, as indicated on drill specification sheet

Drilling specifications are attached.

Name Plate Data:

THE CITY RESERVES THE RIGHT TO REJECT ANY AND ALL BIDS

SED

DATE:

HEIGHT:

GL:

Galvanized Steel Poles

Qty.	Description	Price	Manufacturer	Delivery
4	75' galvanized steel poles, minimum ultimate capacity at GL, 632 ft-kips			

All poles must meet the following specifications:

Material to be: ASTM A572 galvanized. Fy-65 ksi with a Charpy V-Notch Impact Value of 15 foot-pounds @ -20 F/-29 C. Heat Load Tested.

Have solid butt and top, no detachable top plate

Includes 7/8" holes per attached drill specification sheets

Polyurethane coating applied at 16 mils minimum thickness from butt of pole to 2 feet above groundline

4' Ground sleeve, 2' above to 2' below the groundline

NEMA 2 hole ground lug, 3' above ground line

ADDITIONAL NEMA 2 hole ground lugs, as indicated on drill specification sheet

Drilling specifications are attached.

Name Plate Data:

THE CITY RESERVES THE RIGHT TO REJECT ANY AND ALL BIDS

SED

DATE:

HEIGHT:

GL:

Galvanized Steel Poles

Qty.	Description	Price	Manufacturer	Delivery
2	80' galvanized steel poles, minimum ultimate capacity at GL, 813 ft-kips			
1	85' galvanized steel pole, minimum ultimate capacity at GL, 866 ft-kips			

All poles must meet the following specifications:
 Material to be: ASTM A572 galvanized. Fy-65 ksi with a Charpy V-Notch Impact Value of 15 foot-pounds @ -20 F/-29 C. Heat Load Tested.
 Have welded butt and top, no detachable top or bottom plates
 Includes 7/8" holes per attached drill specification sheets
 Polyurethane coating applied at 16 mils minimum thickness from butt of pole to 2 feet above ground line
 4' Ground sleeve, 2' above to 2' below the ground line
 NEMA 2 hole ground lug, 3' above ground line
 ADDITIONAL NEMA 2 hole ground lugs, as indicated on drill specification sheet
 Ladder clips beginning at 30' from ground line
Drilling specifications are attached.

Name Plate Data:

THE CITY RESERVES THE RIGHT TO REJECT ANY AND ALL BIDS

SED

DATE:

HEIGHT:

GL:

IRAN DIVESTMENT ACT NOTICE

Tenn. Code Ann. § 12-12-106 requires the chief procurement officer to publish, using credible information freely available to the public, a list of persons it determines engage in investment activities in Iran, as described in § 12-12-105.

For these purposes, the State intends to use the attached list of “Entities determined to be non-responsive bidders/offers pursuant to the New York State Iran Divestment Act of 2012.”

While inclusion on this list would make a person ineligible to contract with the state of Tennessee, if a person ceases its engagement in investment activities in Iran, it may be removed from the list.

If you feel as though you have been erroneously included on this list please contact the Central Procurement Office at CPO.Website@tn.gov.

List Date: May 4, 2022

Source: <https://www.ogs.ny.gov/iran-divestment-act-2012>

1. Ak Makina, Ltd.
2. Amona
3. Bank Markazi Iran
(Central Bank of Iran)
4. Bank Mellat
5. Bank Melli Iran
6. Bank Saderat Iran
7. Bank Sepah
8. Bank Tejarat
9. China Precision Machinery
Import- Export Corporation
(CPMIEC)
10. ChinaOil (China National United
Oil Corporation)
11. China National Offshore Oil
Corporation (CNOOC)
12. China National Petroleum
Corporation (CNPC)
13. Indian Oil Corporation
14. Kingdream PLC
15. Naftiran Intertrade Co. (NICO)
16. National Iranian Tanker Co.
(NITC)
17. Oil and Natural Gas Corporation
(ONGC)
18. Oil India, Ltd.
19. Persia International Bank
20. Petroleos de Venezuela
(PDVSA Petróleo, SA)
21. PetroChina Co., Ltd.
22. Petronet LNG, Ltd.
23. Sameh Afzar Tajak Co. (SATCO)
24. Shandong FIN CNC Machine
Co., Ltd.
25. Sinohydro Co., Ltd.
26. Sinopec Corp. (China
Petroleum & Chemical
Corporation)
27. SKS Ventures
28. SK Energy Co., Ltd.
29. Som Petrol AS
30. Unipet (China International
United Petroleum & Chemicals
Co., Ltd.)
31. Zhuhai Zhenrong Co.

IRAN DIVESTMENT ACT

“By the submission of this bid, each bidder and each person signing on behalf of any bidder certifies, and in the case of a joint bid each thereto certifies as to its own organization, under penalty of perjury, that to the best of its knowledge and belief that each bidder is not a person included within the list created pursuant to § 12-12-106.”

Signature: _____

Date: _____

Title: _____