



- NOTES:**
1. PAD MOUNTED UTILITY TRANSFORMER.
 2. PROVIDE (2)-4" CONDUIT FROM MAIN HEAD END ROOM TO PROPERTY LINE FOR TELEPHONE SERVICE. CONDUIT LOCATION, SIZE AND BENDING RADIUS SHALL BE COORDINATED WITH UTILITY BEFORE INSTALLATION E.C. TO PROVIDE UP TO 150' OF ADDITIONAL (2)-4" CONDUIT AND COMPLETE INSTALLATION BASED ON UTILITY COORDINATION.
 3. MINIMUM SIZE ELECTRIC HANDHOLES, 48"X36"X24".
 4. ALL LOW VOLTAGE CONDUIT RUNS SHALL HAVE HAND HOLES/PULL BOXES SUPPLIED AT 150' INTERVALS UNLESS OTHERWISE INDICATED BY LOCAL UTILITY. MINIMUM SIZE SHALL BE 43"X36"X 24".
 5. UTILITY TRANSFORMER MINIMUM CLEARANCES, 10'.
 6. SEWER STATION, COORDINATE EXACT LOCATION WITH CIVIL PLANS.
 7. SITE LIGHTING BY UTILITY.
 8. SCHOOL SIGNAGE, COORDINATE EXACT LOCATION WITH CIVIL PLANS.
- KEYNOTES:**
1. SECURITY POLE WITH CAMERA SEE DETAIL #12/E-005.
 2. SEE DETAIL #1/E-404 FOR CAMERA LOCATIONS.
 3. SEE DETAILS #1/#2/E-300 FOR CAMERA LOCATIONS.
 4. (1)-2" SLEEVE FOR SITE UTILITY LIGHTING.
 5. SCOREBOARD, SEE DETAIL #1/E-007.
 6. PROVIDE (1)-2" CONDUIT FROM SPORTS LIGHTING POLE TO SECOND FLOOR CONCESSIONS BUILDING FOR OWNER SOUND SYSTEM CABLING.
 7. RECEPTACLE PEDESTAL SEE DETAIL #2/E-007. MOUNT IN CORNER OF DUGOUT, COORDINATE WITH BENCH LOCATION.
 8. FIRE SERVICE BACKFLOW, PROVIDE 1" CONDUIT TO FACP FOR TAMPER SWITCHES AND TEMPERATURE LOW LIMIT SENSOR. COORDINATE EXACT QUANTITY AND LOCATION WITH CIVIL PLANS.
 9. DOMESTIC SERVICE BACKFLOW, COORDINATE EXACT LOCATION WITH CIVIL PLANS.
 10. POST INDICATOR VALVE. PROVIDE 1" CONDUIT TO FACP. COORDINATE EXACT LOCATION WITH CIVIL PLANS.
 11. VANDAL RESISTANT OUTDOOR LED STRIP LIGHT. SEE LIGHTING SCHEDULE FOR MORE FIXTURE INFORMATION, CIRCUIT TO BE FED VIA CHP-8.

REVISIONS:

No.	Description	Date

PROJECT: 9201-170630
DATE: JANUARY 15, 2018
DRAWN BY: MFL
CHECKED BY: MM

ELECTRICAL SITE PLAN

E-010

1 E010 - ELECTRICAL SITE
1" = 50'-0"