

Addendum No.2

February 1, 2024

A New Road for:

Roane Regional Road & Utility extensions.

To: Prime contractors and all others to whom drawings and specifications have been issued. This Addendum forms part of the Contract Documents. It supplements and modifies them as follows:

From Chadd Blackburn (Duracap Asphalt)

1) There is a line item for pavement markings, but none are shown on plans, or on the existing roadway (Except the entrance). Will this item be removed?

No, the line item is to stay.

2) The Curb and Gutter detail does not match the existing Mountable Curb & Gutter on Sam Rayburn Dr. Will matching the existing be allowed?


Matching the existing will be allowed.

A. Drawings: None.

B. Specifications: None.

End of Addendum

Submitted by:


Aws Al hadeethi, P.E.
MBI Companies Inc.
299 N. Weisgarber Rd
Knoxville, TN 37919

Date: 02-01-2024

Job Number: 231075