



- KEY NOTES:**
1. MANWAY IN TOP OF FERROUS CHLORIDE TANK
 2. DISCHARGE PULSATION ACCUMULATOR
 3. TANK GOOSENECK VENT. FABRICATE END CONNECTION FROM 2\"/>
 - 4. CALIBRATION RESERVOIR
 - 5. 2\"/>
 - 6. PIPE RACK FROM FRAMING CHANNEL. USE TYPE 6 PIPE ATTACHMENTS.
 - 7. TEFLON BELLOWS TYPE EXPANSION JOINT.
 - 8. TYPE E PENETRATION. SEE DRAWING M4.
 - 9. TANK HOLDDOWN METHOD AND DETAILS BY MANUFACTURER.
 - 10. 4\"/>

BC BROWN AND CALDWELL
 CONSULTING ENGINEERS
 PHOENIX, ARIZONA

PROJECT MANAGER: *[Signature]* DATE: 9-13-90
 APPROVED: *[Signature]* DATE: 9-13-90
 APPROVED: *[Signature]* DATE: 9-25-90

LINE IS 2 INCHES AT FULL SCALE (1/16\"/>

FILE	3453
DRAWN	BEW
DESIGNED	WMH & BEW
CHECKED	APS
CHECKED	RNW

REVISIONS					
ZONE	REV.	DESCRIPTION	BY	DATE	APP.

CITY OF AVONDALE

WASTEWATER TREATMENT FACILITY

INTERCEPTOR PUMPING STATION

SECTIONS

DRAWING NUMBER	M1003
SHEET NUMBER	203

RECORD DRAWINGS 12/15/92

0237 6-25-98