



SECTION 3
S1001
SCALE: 3/8"=1'-0"

SECTION 4
S1001
SCALE: 3/8"=1'-0"

DETAIL A
S1002
SCALE: 3/8"=1'-0"

S1002
A liner or coating as specified in Section 03300 shall be provided for all interior concrete surfaces of the interceptor pumping station wet well above elevation 930.00.

RECORD DRAWINGS 12/15/92

BROWN AND CALDWELL
CONSULTING ENGINEERS
PHOENIX, ARIZONA

SUBMITTED: *[Signature]* DATE: 9-13-90
APPROVED: *[Signature]* DATE: 9-13-90
APPROVED: *[Signature]* DATE: 9-25-90

LINE IS 2 INCHES AT FULL SIZE (IF NOT 2'-SCALE ACCORDINGLY)

FILE 3453
DRAWN DL
DESIGNED PAS
CHECKED APS
CHECKED PAS

[Professional Engineer Seal]
[Professional Engineer Seal]

REVISIONS				
ZONE REV.	DESCRIPTION	BY	DATE	APP.

CITY OF AVONDALE

WASTEWATER TREATMENT FACILITY

INTERCEPTOR PUMPING STATION

SECTIONS AND DETAILS

DRAWING NUMBER **S1002**
SHEET NUMBER 142