 <p>CLAYTON COUNTY <b>Water</b> AUTHORITY</p> <p>1600 Battle Creek Road Morrow, GA 30260</p>	<b>JONESBORO RPS IMPROVEMENTS</b>	
	<b>ADDENDUM 1</b>	
	<b>Date</b>	Friday, April 19, 2024
	<b>Bid Number</b>	2024-WP-12
	<b>Pre-Bid Meeting</b>	Tuesday, April 23, 2024 at 2:00 p.m. local time
<b>Bid Opening</b>	Tuesday, May 7, 2024 at 2:00 p.m. local time	
<b>ADDENDUM MUST BE SIGNED AND INCLUDED IN YOUR BID SUBMITTAL</b>		

**SECTION 00 91 13.01**  
**ADDENDUM 1**

**PART 1 – REVISIONS TO THE PROJECT MANUAL**

The following REVISIONS shall be incorporated into the PROJECT MANUAL for the above-referenced project:

A. Section 01 14 00, Coordination with Owner’s Operations

1. Part 1.06-B(5) shall be revised as follows: “Draining and Cleaning of Tanks and Water Mains: Unless otherwise specified, Owner will drain the existing ground storage tanks ~~at beginning of~~ **prior to** shutdowns that require tank draining...”
2. Shutdown 7 described in Table 01 14 00-B shall be removed from the contract.
3. For Shutdown 8, Temporary Systems Required to Perform Shutdown column, remove “One 30-inch line stop” from the contract.
4. Add the following row to Table 01 14 00-B:

9	Noah’s Ark RPS	To install the proposed surge anticipator valves and gate valves	<ul style="list-style-type: none"> <li>• GST #1</li> <li>• All pumps in Building #1</li> </ul>	<ul style="list-style-type: none"> <li>• GST #2</li> <li>• All pumps in Building #2</li> </ul>	-	8 hours
---	----------------	--	--	--	---	---------

B. Section 01 75 00, Checkout and Startup Procedures

1. Part 1.02-C(2)c(2) shall be revised as follows: “Equipment and material shall be operated for a minimum ~~30-day~~ **14-day** operational period to verify performance. In addition to specific requirements specified in the individual specification sections, process data that is recorded in the PLC shall be submitted to the Engineer in tabular format showing hourly process performance data. A log of all alarms shall also be submitted, along with notes describing corrective measures applied in response to alarm condition.”

C. Section 32 31 13, Steel Fencing

1. Part 2.09-B shall be revised as follows: "The main entrance gate shall be a **double single** slide cantilever type gate with electric gate operators and vehicle detector loops for automatic operation."
2. Add Part 2.09-F: "Gate operator system shall be as manufactured by Customline, Inc.; Crusader Division of McKinney Electronics, or equal."

D. Section 00 73 00, Supplementary Conditions

1. Part 5.03-SC-5.03, the following drawings shall be added to the list:
  - a. Tank Drawings: Jonesboro Tanks, CROM, 1991
  - b. Tank Drawings: Noah's Ark Tank, CROM, September 1971

E. Section 40 66 54, Cellular Communication System, shall be added to the contract.

**All other terms and conditions of the PROJECT MANUAL remain unchanged.**

**PART 2 – REVISIONS TO THE DRAWINGS**

A. Drawing C053

1. Add the following note: "4. Where BFV-400E connects to existing flanges or piping, Contractor shall completely remove the existing coating from the existing flanges or existing piping for a distance of 6-inches and apply new coating in accordance with Section 09 90 00."

B. Drawing CD001

1. Add Detail C-01-0100

C. Drawing M102 shall be removed from the contract.

D. Drawing M103

1. Add the following note: "2. Where proposed valves, fittings, and/or piping connects to existing flange or piping, Contractor shall completely remove the existing coating from the existing flange or existing piping for a distance of 6-inches and apply new coating in accordance with Section 09 90 00."

E. Drawing M104

1. Revise Note 1 to read: "1. Tap ~~30-inch~~ **24-inch** discharge header and install 3/4 inch Sch 40 PVC remote sensing line from tap to 6-inch surge anticipator valve per manufacturer's guidelines."

F. Drawing M400

1. Revise callout at Pump 3 suction to read: 18"x10" ECC. RED., ~~DEMO.~~

G. Drawing S3 shall be added to the contract.

### **PART 3 – QUESTIONS AND ANSWERS**

**Q1: Regarding drawing C050, please provide details for the existing tower being demolished.**

A1: Drawings for the existing tower are not available. A picture of the tower is included as Attachment A to this addendum.

**Q2: The demolition shown on drawing M102 conflicts with the work to be performed in Section 01 11 00 Part 1.02 B. 2. Please clarify.**

A2: Refer to PART 2 – C of this Addendum.

**Q3: Please provide more information and details on the alternate item shown in Section 01 23 00 Part 3.01 A. 1.**

A3: Jonesboro RPS construction drawings (Finished Water Pumping Station, Robert and Company, May 1991) are included as Attachment D to this addendum. No other drawings or details on the existing natural gas engine are available.

**Q4: Please provide copies of the lead-based paint surveys referenced in Section 02 83 00 Part 1.01 A. 1.**

A4: The asbestos and lead based paint survey reports are included as Attachments B and C to this addendum.

**Q5: Drawing E102 shows power to the new valves at Noah's Ark. Are any control circuits required?**

A5: No. Remote control circuit wiring is not required to be installed for these valve actuators.

**Q6: Does the American Iron and Steel Act apply to the project?**

A6: No.

**Q7: Item 7 in the shutdown schedule in Section 01 14 00 references replacement of MOV-010A through MOV-010D. Please confirm whether these valves and this shutdown is applicable to the project.**

- A7: Shutdown 7 described in Table 01 14 00-B shall be removed from the project. Refer to PART 1 – A.2 in this Addendum.
- Q8: Please provide as-built information for all electrical duct banks shown on E050.**
- A8: Jonesboro RPS construction drawings (Finished Water Pumping Station, Robert and Company, May 1991) are included as Attachment D to this addendum.
- Q9: Regarding Article 7.08 of the Supplementary Conditions, what fees are waived by the Owner and what permits or fees are required from other agencies/entities other than the Owner?**
- A9: **CCWA:** No permits are required from the Owner.  
**Clayton County Community Development:** The project requires building and trade permits from Clayton County Community Development which the Contractor shall pay for. Drawings have been reviewed and are ready for the Contractor to pickup.  
**Clayton County Transportation and Development:** Land disturbance activity and grading permits from Clayton County Transportation and Development have been received and will be provided to the Contractor.  
**Lead-based Abatement:** The Contractor shall be responsible for any permits and fees associated with lead-based paint abatement.  
**Georgia Environmental Protection Division:** The project has been approved by GA EPD; copies of the GA EPD permit approval will be provided to the Contractor.  
Contractor is responsible for all fees associated with the project; none of the fees for the above-mentioned permits shall be waived.
- Q10: Can the existing duct banks shown on E050 be abandoned in place rather than removed? If not, we assume that temporary feeds will need to be provided to/from the existing Tank 2 Aeration Control Panel. Please clarify.**
- A10: Existing duct banks identified for demolition shall be removed, not abandoned. See Section 01 14 00 for requirements for maintaining Owner operations. Specifically for the Tank 2 Aeration Control Panel, additional site investigation is recommended.
- Q11: Drawings C050 and M402 show the location of the existing gas meter in conflict with proposed DB52 shown on E051 and E401. If the gas service is demolished to facilitate the construction of the proposed ductbank, does a temporary generator need to be supplied to provide backup power to existing Pump No. 3 and/or Pumps No. 1 & 4?**
- A11: Existing Pump No. 3 shall maintain backup power until JB-P-1, JB-P-2 and the proposed generator are put into service. Contractor shall route duct bank around existing gas meter/gas service or temporarily relocate gas meter/gas service to maintain the existing gas generator in service until the above criteria is met.

- Q12: The Building Code Analysis on A501 appears to indicate that a Fire Alarm is not required. Note 1 on E500 indicates that a Fire Alarm System is required. Please clarify.**
- A12: The fire alarm system is not a Code requirement, but it is a Project requirement. Provide a fire alarm system for the new Electrical Building per Section 28 46 20.
- Q13: Section 01 91 13 Part 3.02 references a 14-day operating test period. Section 01 75 00 Part 1.02 C. references a 30-day operational period. Please clarify which is required.**
- A13: Section 01 75 00 Part 1.02 C shall be revised to a 14-day operational period. Refer to PART 1 – B.1 of this Addendum.
- Q14: Stage 1 of the Suggested Sequence of Work (00 14 00) shows replacing the yard valves at the Jonesboro RPS. Is the intent for the Owner to temporarily operate these valves manually or does the Contractor need to provide temporary power to each valve?**
- A14: The yard valves at Jonesboro RPS shall be manually operable temporarily until the proposed electrical systems are installed and the electric actuators can be installed.
- Q15: Please provide drawing details of the existing Meter Vault shown on C050.**
- A15: Jonesboro RPS construction drawings (Finished Water Pumping Station, Robert and Company, May 1991) are included as Attachment D to this addendum.
- Q16: Please provide details on the double check valve, box, and sample station assemblies referenced in Note 3 on drawing C053.**
- A16: Drawings for the existing double check valve, box, and sample station are not available.
- Q17: Regarding Section 01 14 00 Part 1.06 B. 6. b., is the intent to provide a 14-day period between each shutdown listed in Table 01 14 00-B?**
- A17: Section 01 14 00 Part 1.06-B(6)b refers to SCADA outages which are separate from pump outages. The 14-day period referenced in this paragraph only applies to shutdowns in Table 01 14 00-B if they require a SCADA shutdown.
- Q18: Drawings M403 (JP-P-2) and M404 (Section E) have leaders to see equipment pad detail 1 on S3. Drawing S3 does not appear to be included in the documents. Please clarify or provide the detail as necessary.**
- A18: Drawing S3 is added to the Drawings, see PART 2 – F in this Addendum and Attachment G of this addendum.
- Q19: To which structures do you expect Note 3 on drawing C052 apply?**
- A19: Water Tank #1, Water Tank #2, and Jonesboro RPS pump building.
- Q20: Regarding Note 3 on M403, please provide details on the components necessary for the seal water system.**
- A20: Refer to API Standard 682, standard seal piping plan 11.

- Q21: Does Note 5 on M403 apply to the existing Meter and Altitude Valve Vaults? If so, please provide existing vault details.**
- A21: Jonesboro RPS construction drawings (Finished Water Pumping Station, Robert and Company, May 1991) are included as Attachment D to this addendum. No other drawings/details of the Jonesboro RPS are available.
- Q22: Regarding M401 Section C and M404 Section F, please confirm that the existing concrete supports should be reused for the new 12" SAV installation.**
- A22: It is the intent for the existing concrete supports to be reused for the new 12-inch SAV installation.
- Q23: Regarding E051, what are the depths of the existing gas line and water line (in particular in front of Tank 2 where DB-51 crosses it twice) that run parallel to Old Morrow Rd.?**
- A23: The depth of the gas main is unknown. Cover over the existing 24-inch water main varies from 3 to 4 feet.
- Q24: Regarding Section 32 31 13 Part 2.09 B & C, please clarify whether proposed cantilevered sliding gate is intended to be a double or single sliding gate.**
- A24: Refer to PART 1 – C.1 of this Addendum.
- Q25: We assume that the proposed sliding and swing gates should be ornamental as shown on CD002 and not chain link as specified in 32 31 13.**
- A25: The proposed sliding and swing gates at Jonesboro RPS shall be ornamental as shown on CD002.
- Q26: Regarding Section 32 31 13 Part 2.09 C, please provide manufacturer(s) and model(s) for the proposed gate operator(s).**
- A26: Refer to PART 1 – C.2 of this Addendum.
- Q27: Is the entire fence intended to be ornamental? If not, please indicate where fence transitions to chain link.**
- A27: All fencing at Jonesboro RPS shall be ornamental.
- Q28: Provide elevations for depths of the six buried 24" BFVs with EMOs (two at Noah's Ark RPS, four at Jonesboro RPS) for figuring length of stem & bonnet tube.**
- A28: Jonesboro RPS construction drawings (Finished Water Pumping Station, Robert and Company, May 1991), Jonesboro RPS tank drawings (Jonesboro Tanks, CROM, 1991), and Noah's Ark RPS tank drawings (Noah's Ark Tank, CROM, September 1971) are included as Attachments D, E, and F to this addendum. No other depth information is available.

**Q29: The seventh BFV (BFV-400E) at the Jonesboro RPS is inside a meter vault. Please provide dimensions of vault and/or orientation and location of the EMO (inside vault or outside vault).**

A29: Electric motor operator for BFV-400E shall be mounted to the top of the meter vault slab above the valve.

**Q30: 'Table 01 14 00-B Schedule of Shutdowns' indicates replacement of yard valves MOV-010A through MOV-010D at Noah's Ark RPS. These valves are not mentioned on the Drawings or elsewhere. Please clarify.**

A30: Refer to PART 1 – A.2 of this Addendum, which removes reference to MOV-010A through MOV-010D at Noah's Ark RPS from the project scope of work.

**Q31: Drawing M102 'Noah's Ark RPS Demolition Photos' details removal of Pumps No. 2 & No. 4. This is not indicated on the other demolition drawings (M100, M101) and no provisions for replacement of pumps or piping is mentioned elsewhere. Please clarify.**

A31: Refer to PART 2 – C of this Addendum, which removes drawing M102 from the project scope of work.

**Q32: Is AMTECH Drives approved for Supply?**

A32: Approved VFD manufacturers are listed in Section 26 29 23.

**Q33: Drawing E051 shows a security camera provided by others. Please confirm whether the Contractor needs to provide a pole for mounting the camera.**

A33: No, the pole for the security camera is by others.

**Q34: Is lightning protection required for the generator?**

A34: No, the standby generator set is excluded from the lightning protection provisions in Section 26 41 00.

**Q35: Drawing I002 shows an antenna for LCP-500, is this integral to the control panel or does this need to be routed to the exterior of the building?**

A35: Cellular antenna shall be integral to the control panel similar to existing RTU panel.

**Q36: Regarding Section 01 14 00 Table 01 14 00-B, please provide explanation and/or detail of the 30" line stop required in Shutdown No. 8.**

A36: Refer to PART 1 – A.3 of this Addendum; the 30-inch linestop is not required to install MOV-100A and MOV-100B and shall be removed as a requirement to perform Shutdown No. 8.

**Q37: Regarding the SAV replacement for the Noah's Ark RPS shown on M100-M104, will an additional shutdown be required or should the Contractor plan to perform the work during Shutdown No. 8?**

A37: Refer to PART 1 – A.4 in this Addendum; an additional shutdown (Shutdown No. 9) shall be added to Table 01 14 00-B as a part of this addendum.

**Q38: C-32-0510 on drawing CD002 shows the slide gate as 4' tall. C-32-0512 shows the swing gate as 8' tall. Please clarify what height the fence should be.**

A38: Detail C-32-0510 identifies a 4-inch post, but does not identify height. The ornamental fence and gates shall be 8-feet tall.

**Q39: Please confirm that no lead-based paint abatement is required for the Noah Ark Repump Station Improvements.**

A39: Lead-based paint abatement may be required for Noah's Ark RSP. Asbestos and Lead Based Paint Survey for Noah's Ark RPS, ECS Southeast, LLP, November 2022 has been included as Attachment B to this addendum. In addition, Refer to Section 02 83 00 Lead-Based Paint Abatement.

**Q40: Please provide the locations and quantities of the lead base abatement at the Jonesboro Repump Station Improvements.**

A40: Asbestos and Lead Based Paint Survey for Jonesboro RSP, ECS Southeast, LLP, November 2022 has been included as Attachment C to this addendum.

**Q41: Please provide the survey and test report for the lead base abatement for Jonesboro Repump Station Improvements.**

A41: See responses to Q40: and Q41:.

**Q42: Please clarify if this project requires AIS (American Iron and Steel act) requirements.**

A42: This project does not require compliance with the American Iron and Steel Act.

**Q43: Please confirm that SECTION 01 45 33 SPECIAL INSPECTIONS is the owner or the engineer of record scope of work.**

A43: Contractor shall comply with Section 01 45 33. Refer to Part 1.01 The Requirement and 3.05 Contractor Responsibilities.

**Q44: Under specification section 02 83 00 (LBP) Lead Base Paint section 1.01 the contractor shall provide all labor, equipment, tools, materials and permit required to test for, remove and dispose of lead-based paint materials required to complete the work. Results of a lead base paint survey for each site are included. But the documents received do not include a survey. Please provide an Asbestos and Lead Based Paint Survey.**

A44: See responses to Q40: and Q41:.

**Q45: Has the Owner obtained the necessary right of way permits for installation of new utilities shown on plan C053 the Electrical Ductbank?**

A45: Clayton County Transportation and Development reviewed and approved the Work as shown.

**Q46: This project we are replacing a minimal number of spools and fittings that are tied into an existing line. The layout is not designed to isolate the new piping from the existing piping. If testing against the existing line could**



**cause a failed test. Consideration should be given to this. Minimal testing should be considered under these conditions. Please clarify.**

A46: No pressure testing of proposed piping against existing piping, fittings, or valves shall be required. Acceptance of the proposed piping, fittings, and valves installation shall be based on their performance and functionality during the 14-Day Operating Test Period described in Section 01 91 13 – General Commissioning Requirements.

**Q47: If a Bidder has been previously approved by the CCWA as a Responsible Bidder per section 00 45 13, do we have to resubmit this information again?**

A47: Bidder must submit all required information listed in Section 00 21 13 – Instructions to Bidders and Section 00 45 13 – Bidders Qualifications.

**Q48: Drawing M404, Section C details the equipment pads has a note to see drawing S3. But there is no drawing S3 supplied in the documents. Please provide sheet S3.**

A48: Drawing S3 is added to the Drawings, see PART 2 – F in this Addendum and attachments.

**Q49: Please clarify why drawing M102 showing demolition of Noah's Ark RPS pumps was included in these documents?**

A49: Refer to PART 2 – C of this Addendum.

**Q50: Specification 40 05 00, 3.01, S. states, "ALL PIPING SHALL HAVE TYPE "A" BEDDING AS SHOWN ON THE DRAWINGS, UNLESS OTHERWISE SPECIFIED HEREIN OR INDICATED ON THE DRAWINGS.", however there is not a Type A bedding detail shown, please provide.**

A50: See Type A bedding detail in PART 4 – H of this Addendum.

**Q51: Specification 40 05 00, 3.04, A. states "All piping shall be properly flushed and tested unless specifically exempted elsewhere in the Specifications or otherwise approved by the Engineer." However, this job requires replacing a limited amount of spools and/or valves which doesn't allow for testing. In the original bid Addendum #4, Q&A #13 addressed this item, which the response stated, "No pressure testing of proposed piping against existing piping, fittings, or valves will be required.". Please reconfirm your response for this bid.**

A51: Refer to Q46: response.

**Q52: Specification 01 14 00-B Schedule of Shutdowns doesn't list replacement of the 6" SAV's at Noah's Ark RPS. There is not an isolation valve on the downstream side, so its likely two partial shutdowns would need to occur (#1 = Pumps #1 & #2 are off and pump #4 is on, #2= Pump #4 is off and pumps #1 & #2 are on). Please confirm if the two shutdowns are acceptable or if another means is available/acceptable.**

- A52: An additional shutdown (Shutdown No. 9) shall be added to Table 01 14 00-B. Refer to PART 1 – A.4 in this Addendum. Surge anticipator valves and associated gate valves, fittings, and piping shall be installed during Shutdown No. 9.
- Q53: Drawing M104, note 1 states, "Tap 30-inch discharge header and install 3/4-inch SCH 40 PVC remote sensing line from tap to 6-inch surge anticipator valve per manufacturer's guidelines". Please respond to the following questions:**
- A. It appears the discharge header is 24" according to drawing M103 and not 30", please confirm.**
- B. Is there an existing tap that can be utilized for the new line (existing SAV sensing line tap)?**
- C. If an existing tap cannot be used a direct wet tap into the header maybe be required since it is unclear if the existing tie rods will interfere with a tapping saddle. Please confirm if any objection or other intentions for the tap.**
- A53: A. Refer to PART 2 – E of this Addendum; the existing discharge header at Noah's Ark Building 1 is 24-inch.
- B. There is not an existing tap on the 24-inch header for the existing surge relief valves.
- C. Direct tapping of the 24-inch discharge header is allowable.
- Q54: Drawing M102 Photos 1, 2, & 3 show and call for demolition of pumps, engines, ductile iron piping, and natural gas piping. However, this appears to be scope from the original bid (when the natural gas engines and pumps were to be replaced), but this scope was removed in the rebid. Please confirm all work shown on this drawing is incorrect and provide updated sheet or remove sheet from documents.**
- A54: Refer to PART 2 – C of this Addendum.
- Q55: Specification 01 14 00, 1.06, B, 5. states "Owner will drain the existing ground storage tanks at beginning of shutdowns that require tank draining." The sentence implies that the duration of time it takes to drain the tanks is part of the maximum duration allowed for the shutdown (8 hours). Although the amount of time to drain the tanks is not stated (likely several hours), further reducing the amount of time the contractor can work during the shutdown will likely not allow enough time for the contractor to complete the required work. Please confirm that the Owner will drain the existing GST's immediately prior to the shutdown allowing the contractor a full 8 hours to perform the work. We assume the Owner will close the GST fill line(s) and pump down the water as low as possible while not creating any potential issues for the pumps, then the remaining water will be drained by the tank drain line (single 12" pipe for both GST's at Jonesboro). Once the remaining water is drained from the tanks the contractor's**

**shutdown duration starts. Please confirm these assumptions and clarify anything inaccurate or missing.**

A55: See PART 1 – A.1 of this Addendum. Contractor shall have the full time listed in Table 01 14 00-B for each individual shutdown. The tank draining process described in the above question is generally correct.

**Q56: Drawing M400 at Pump 3 suction calls out "18"x10" ECC. RED., DEMO." However, the fitting is drawn as existing, and on M403 it is also drawn as existing. Please confirm this fitting does not get replaced.**

A56: See PART 2 – F of this Addendum; the existing 18" x 10" reducer on Pump 3 suction piping at Jonesboro RPS is existing and shall not be demolished or replaced.

**Q57: Drawing M402, photo 2 appears to show cooling water supply and return/discharge for the engine. Does the return/discharge pipe extend below the grating and then stop a few inches above the concrete slab, or does it continue somewhere else?**

A57: Yes, the return pipe extends below the grating and terminates above the discharge header trench slab.

**Q58: Drawing M403, Note 5 states "ALL EXISTING FINISHED WATER PIPING AND VALVES INSIDE THE PUMP ROOM AND OUTSIDE OF THE BUILDING EXTENDING TO 12-INCHES BELOW GRADE SHALL BE COATED PER SPECIFICATION 09 90 00". A few questions/clarifications on this note:**

**A. Does this note apply to both Jonesboro and Noah's Ark?**

**B. If it applies to Noah's Ark, only Building 1 piping?**

**C. We assume the only "buried" piping that will need to be uncovered to be painted to 12" below grade are the pump suction pipes & surge pipes that are partially exposed, please confirm.**

**D. Does any of the piping in vaults get painted? If so, please be specific to which vaults.**

A58: A. Note 5 on Drawing M403 applies only to Jonesboro RPS.

B. N/A

C. Pipe coating shall extend 12-inches below grade where pipe transitions from above grade to below grade without passing through a structural element (like a building or vault wall). The above grade pump suction piping outside of the building extending to 12-inches below grade shall comply with the note.

D. Note on drawing M403 does not apply to vaults; however, refer to PART 2 – A.1 of this Addendum for required coating for BFV-400E installation.

## **PART 4 – ATTACHMENTS**

A. Jonesboro RPS antenna photograph

B. Asbestos and Lead Based Paint Survey for Noah's Ark RPS, ECS Southeast, LLP, November 2022

- C. Asbestos and Lead Based Paint Survey for Jonesboro RPS, ECS Southeast, LLP, November 2022
- D. Finished Water Pumping Station, Robert and Company, May 1991
- E. Jonesboro Tanks, CROM, 1991
- F. Noah's Ark Tank, CROM, September 1971
- G. Drawing S3
- H. Detail C-01-0100
- I. Section 40 66 54, Cellular Communication System

**END OF SECTION**

<b>Acknowledgment of receipt of this addendum must be signed and included in your bid submittal.</b>	
<b>Company Name</b>	
<b>Signature</b>	
<b>Date</b>	



# ASBESTOS AND LEAD BASED PAINT SURVEY



NOAH'S ARK RSP

1865 NOAH'S ARK ROAD  
JONESBORO, GEORGIA 30236

ECS PROJECT NO. 49:18720

FOR: HAZEN AND SAWYER

NOVEMBER 30, 2022





November 30, 2022

Mr. Chas Goblisch  
Hazen and Sawyer  
1300 Altmore Avenue  
Suite D-520  
Atlanta, Georgia 30342  
CGoblisch@hazenandsawyer.com

ECS Project No. 49:18720

Reference: Asbestos and Lead Based Paint Survey, Noah's Ark RSP, 1865 Noah's Ark Road, Jonesboro, Georgia

Dear Mr. Goblisch:

ECS Southeast, LLP (ECS) is pleased to provide Hazen and Sawyer with the results of the above referenced Asbestos and Lead Based Paint Survey performed at Noah's Ark RSP located at 1865 Noah's Ark Road in Jonesboro, Georgia. This report summarizes our observations, analytical results, findings, and recommendations related to the work performed. The work described in this report was performed by ECS in general accordance with the Scope of Services described in ECS Proposal Number 49:33782P and the terms and conditions of the agreement authorizing those services.

ECS appreciates this opportunity to provide Hazen and Sawyer with our services. If we can be of further assistance to you, please do not hesitate to contact us.

Sincerely,

ECS Southeast, LLP

Jenny Clark, REM  
Environmental Department Manager  
jclark@ecslimited.com  
404-640-9257

Justin Roth, CHMM  
Environmental Principal  
jroth@ecslimited.com  
843-654-4448

## **EXECUTIVE SUMMARY**

The subject property is developed with a water treatment facility located at 1865 Noah's Ark Road in Jonesboro, Clayton County, Georgia. The two pump station buildings consist of approximately 5,800 square feet of space in total. The buildings were reportedly constructed in 1974 and 1996 respectively. ECS understands the buildings are scheduled for demolition.

The purpose of the Asbestos and Lead Based Paint Survey was to identify asbestos-containing materials (ACMs) and lead-paint that may be present within the building materials scheduled to be impacted by the planned demolition activities.

### **Asbestos Survey**

On November 18, 2022, Ms. Jenny Clark, REM, an accredited inspector, performed the asbestos assessment. Bulk samples were submitted to EMSL Analytical, Inc. (EMSL) in Smyrna, Georgia for analysis via Polarized Light Microscopy (PLM) in accordance with the current EPA-600 methodology.

A total of 22 bulk samples from nine homogeneous areas were submitted to the laboratory of which 28 layers were analyzed. Based on the laboratory analysis of the bulk samples collected during the survey, one of the materials were reported to contain asbestos above the regulatory limit.

The following material was reported as asbestos-containing:

- Roofing Mastic - Building #1 / Upper Roof

The following materials were reported as non-asbestos containing:

- Window Glass and Glazing;
- Exterior Stucco Window Sill;
- Gasket Material;
- Tank Insulation Material;
- Exterior Wall Panel;
- Built-up Roofing - Upper and Lower Roof; and
- Exterior Window Caulk.

Due to inaccessibility or the destructive means that asbestos sampling requires, unseen ACMs may remain within the building hidden behind inaccessible areas that include, but are not limited to, sub-grade walls, structural members, topping slabs, sub-grade sealants, flooring located below underlayments, areas behind exterior walls, pipe trenches, and subsurface utilities, etc.

If suspect materials are discovered during construction activities, they should be presumed to contain asbestos and be treated as ACMs or be sampled immediately upon discovery and prior to disturbance for asbestos content by a certified asbestos inspector in accordance with 29 Code of Federal Regulations (CFR) 1926.1101.

### **Lead Paint Survey**



On November 18, 2022, Ms. Jenny Clark, REM, an accredited inspector, performed the Lead Paint Survey. Paint chip samples were submitted to EMSL Analytical, Inc. (EMSL) in Kernersville, North Carolina for analysis via Flame Atomic Absorption Spectroscopy (AAS) in accordance with EPA Method SW 3050B/7000B.

A total of nine paint chips were collected. Based on the findings of the lead survey, detectable concentrations of lead were identified on some paints and surface coatings.

The executive summary is an integral portion of this report, however, ECS recommends the report be read in its entirety.

<b>TABLE OF CONTENTS</b>		<b>PAGE</b>
<b>1.0</b>	<b>SITE DESCRIPTION</b> .....	<b>1</b>
<b>2.0</b>	<b>PURPOSE</b> .....	<b>1</b>
<b>3.0</b>	<b>METHODOLOGY</b> .....	<b>1</b>
3.1	Asbestos-Containing Materials .....	1
3.2	Lead in Paint and Surface Coatings .....	2
<b>4.0</b>	<b>RESULTS</b> .....	<b>2</b>
4.1	Asbestos-Containing Materials .....	3
4.2	Suspect or Assumed Asbestos-Containing Materials .....	3
4.3	Lead in Paint and Surface Coatings .....	4
<b>5.0</b>	<b>RECOMMENDATIONS AND REGULATORY REQUIREMENTS</b> .....	<b>5</b>
5.1	Asbestos-Containing Materials .....	5
5.2	Lead in Paint and Surface Coatings .....	5
<b>6.0</b>	<b>LIMITATIONS</b> .....	<b>6</b>

## **TABLE OF APPENDICES**

Appendix I: Site Photographs

Appendix II: Asbestos Bulk Sample Results

Appendix III: Lead Laboratory Analytical Results

Appendix IV: Certifications/Licenses

## 1.0 SITE DESCRIPTION

The subject property is developed with a water treatment facility located at 1865 Noah's Ark Road in Jonesboro, Clayton County, Georgia. The two pump station buildings consist of approximately 5,800 square feet of space in total. The buildings were reportedly constructed in 1974 and 1996 respectively. The interior finishes include concrete floors, walls and ceilings. The exteriors are brick. Building #1 has a built-up roof on two roofing systems, upper and lower and Building #2 has a membrane roof.

## 2.0 PURPOSE

The purpose of the Asbestos and Lead Based Paint Survey was to identify asbestos-containing materials (ACMs) and lead-containing paint (LCP) which require special handling and/or disposal if disturbed during construction activities. The identification of ACMs require trained labor, regulated work practices, and special disposal. The identification of LCP requires disclosure to contractors and monitoring of lead exposure.

## 3.0 METHODOLOGY

ECS performed the authorized Scope of Services in general accordance with our proposal, standard industry practice(s) and methods specified by regulation(s) for the identification of ACMs and LCP.

### 3.1 Asbestos-Containing Materials

On November 18, 2022, Ms. Jenny Clark, REM, an EPA accredited inspector, performed the asbestos survey. The survey consisted of observing the accessible areas of the building for the presence of suspect materials which may contain asbestos. The survey involved detecting both friable materials (materials which can be pulverized or reduced to a powder by hand pressure when dry) and non-friable materials (materials which pose a hazard when sawn, sanded, drilled or pulverized). Homogeneous materials (based on material type, color, texture, etc.) were identified in during the survey.

The EPA National Emissions Standard for Hazardous Air Pollutants (NESHAP) requires a survey for asbestos prior to renovation or demolition. Renovation or demolition is defined under NESHAP as the removal of a load-bearing structure or member. On the basis of requirements under NESHAP for renovation activities, ECS conducted a limited survey for potential ACM. The ACM survey was limited in that we did not conduct demolition such as jack/sledge hammering to expose potentially concealed materials.

Samples were collected in general accordance with EPA Standard 40 CFR 763 Subpart E, Asbestos Hazard Emergency Response Act (AHERA) and OSHA Standard 29 CFR 1926.1101 Inspection Protocol. Multiple samples of each unique material were submitted. Samples were analyzed using "Positive Stop" methodology. If one sample of a homogeneous material is reported to contain asbestos, the remaining samples of that material are not analyzed. If one sample of a material from a homogeneous area was reported to contain greater than 1% asbestos, then by EPA definition, it was characterized as asbestos-containing material.

As per the regulations, samples were collected from random locations of each homogeneous area, with the material's number of samples based upon the following criteria:

- Thermal Insulation Materials (piping, breeching, boiler insulation, etc.) – A minimum of two (2) samples are required. Patch areas (less than 6 square or linear feet) may have one (1) sample collected.
- Surfacing Materials (plaster, fireproofing, etc.) – A minimum of seven (7) samples are to be taken for areas greater than 5,000 square feet; five (5) for areas greater than 1,000 square feet, but less than 5,000 square feet; three (3) for areas less than 1,000 square feet.
- Miscellaneous Materials (flooring, adhesives, roofing, wallboard, etc.) – A minimum of two (2) samples are required.

In order to determine if the suspect materials observed during the visual survey contained asbestos, representative bulk samples were collected and placed in sealed packages. Samples were collected during the survey and submitted to EMSL for analysis using the EPA recommended method of Polarized Light Microscopy (PLM) coupled with dispersion staining (Method No. EPA 600/M4-020-82, Dec. 1982). EMSL participates in the National Voluntary Laboratory Accreditation Program (NVLAP). Their NVLAP accreditation number is 101048-1. Several of the samples were layered and analyzed as multiple samples. EPA regulations require that multiple samples of each homogeneous area be collected for laboratory analysis. The material type, sample location, and analytical results of each bulk sample are also summarized in the attached Asbestos Bulk Analysis report in **Appendices**.

During the survey, ECS attempted to identify suspect ACMs in readily accessible areas. However, due to the destructive means required to identify some materials, certain areas were deemed inaccessible (i.e. behind walls or sub grade materials) and were not surveyed for suspect ACMs. Unidentified suspect ACMs may be located in these and/or other inaccessible areas.

### **3.2 Lead in Paint and Surface Coatings**

The lead paint survey was performed by collection of suspect lead paint chips to identify lead concentrations in painted surfaces.

The lead paint assessment was conducted utilizing the U.S. EPA definition of lead-based paint (LBP). Under this definition, painted surfaces which contain lead in concentrations equal to or greater than 0.5% lead by weight are classified as coated with LBP. Paints with concentrations of detectable levels of paint are considered LCPs. Activities which disturb LCPs and glazing (while not LBPs by the U.S. EPA definition) are regulated by OSHA (29 CFR 1926.62).

Because the current or proposed use of the property is not residential or child-occupied, the scope of the lead paint survey was not conducted in accordance with HUD Chapter 7 requirements. This representative survey included collecting paint chips from walls, windows, doors, and miscellaneous components.

## **4.0 RESULTS**

The following is a summary of laboratory results, findings and observations.

#### 4.1 Asbestos-Containing Materials

In total, 22 bulk samples from nine homogeneous areas were submitted to the laboratory of which 28 layers were analyzed. An Asbestos-Containing Material (ACM) is defined as any material containing more than one percent (>1%) asbestos as determined using the method specified in Appendix E, Subpart E, 40 CFR Part 763, Section 1, PLM. Materials are categorized by the U.S. EPA in the following categories:

- Friable ACMs are defined as any ACM that, when dry, can be crumbled, pulverized or reduced to powder by hand pressure. Non-friable ACMs are defined as any ACM that, when dry, cannot be crumbled, pulverized, or reduced to powder by hand pressure.
- Category I non-friable ACM are listed as following: packings, gaskets, resilient floor coverings, and asphalt roofing products containing more than one percent (>1%) asbestos.
- Category II non-friable ACM are listed as any material, excluding Category I non-friable ACM, containing more than one percent (>1%) asbestos.

Regulated Asbestos Containing Materials (RACM) are friable ACM or non-friable ACM that will be or has been subjected to sanding, grinding, cutting, or abrading or has crumbled, been pulverized, or reduced to powder in the course of renovation and/or demolition operations.

EMSL submitted a signed final laboratory report to ECS on November 22, 2022. One of the bulk samples submitted for analysis were reported to contain asbestos in detectable concentrations. A complete list of the sampled materials submitted for analysis and sample locations are located in the Appendix of this report. Representative photographs of collected samples are also located in the Appendix of this report.

#### Summary of Asbestos-Containing Materials Identified

Sample ID	Location	Material Description	Analytical Results	Category
RM-2	Building #1 - Upper Roof	Roofing Mastic	3% Chrysotile	Category I non-friable

#### 4.2 Suspect or Assumed Asbestos-Containing Materials

Due to the inaccessibility or the destructive means that asbestos sampling requires, additional suspect ACMs may remain within the building hidden behind inaccessible areas that include, but are not limited to, sub-grade walls, structural members, topping slabs, sub-grade sealants, flooring located below underlayments, areas behind exterior walls, pipe trenches, and subsurface utilities, etc. These areas were deemed inaccessible and were not assessed.

If these materials are discovered during construction activities, they should be presumed to contain asbestos and be treated as ACMs or be sampled immediately upon discovery and prior to disturbance for asbestos content by a certified asbestos inspector in accordance with 29 CFR 1926.1101.

Based upon our past experience in the identification of ACMs in similarly constructed buildings, the following additional suspect ACMs may also be located in inaccessible areas of the structure:

- Within the piping systems or equipment not accessed below grade.

### 4.3 Lead in Paint and Surface Coatings

Paint and surface coatings which contain detectable concentrations of lead considered "lead-containing paints". Since OSHA has no specific action level for lead in paint, all paint on the site found to have a measurable concentration of lead should be assumed to be lead containing. Work performed which may disturb lead-containing paint is regulated under OSHA as referenced under 29 CFR 1926.62. A total of 164 readings were collected during the survey, including calibration readings. Paint and other surface coatings which are defined by applicable regulation as lead-based paints are summarized in the table below and photographs of lead-based paint identified are located in the Appendix.

Paint and surface coatings which contain detectable concentrations of lead are considered LCPs. Since OSHA has no specific action level for lead in paint, all paint on the site found to have a measurable concentration of lead should be assumed to be lead-containing. Work performed which may disturb LCP is regulated under OSHA as referenced under 29 CFR 1926.62. A total of nine paint chip samples were collected during the survey. Paint and other surface coatings that were sampled are summarized in the table below and photographs of sampling locations are located in the Appendix.

### Summary of Paint Chip Results

Sample ID	Color	Substrate	Component	Lead Concentration (%) by Weight
PC-1 / Bldg #1	Yellow	Concrete	Wall	<0.0080%
PC-2 / Bldg #1	Light Blue	Metal	Equipment - Base	<0.0080%
PC-3 / Bldg #1	Brown	Concrete	Floor	0.026%
PC-4 / Bldg #1	Yellow	Concrete	Ceiling	<0.0080%
PC-5 / Bldg #1	Light Blue	Metal	Equipment - Piping	0.015%
PC-6 / Bldg #2	Gray	Metal	Equipment - Base	0.017%
PC-7 / Bldg #2	Light Blue	Metal	Equipment - Base	<0.0080%

Sample ID	Color	Substrate	Component	Lead Concentration (%) by Weight
PC-8 / Bldg #2	Yellow	Concrete	Wall	<0.0080%
PC-9 / Bldg #2	Light Blue	Metal	Equipment - Piping	<0.0080%

## 5.0 RECOMMENDATIONS AND REGULATORY REQUIREMENTS

Based on our understanding of the purpose of the Asbestos and Lead Based Paint Survey, the results of laboratory analysis, and our findings and observations, ECS presents the following recommendations.

### 5.1 Asbestos-Containing Materials

ECS recommends where a material type has been identified as asbestos-containing that other materials with similar color, texture, age and size throughout the building's interior and exterior be assumed to contain asbestos. Please refer to Section 4.1 for a complete list of building materials that were reported positive for asbestos and to Section 4.2 for materials that were assumed to contain asbestos.

Suspect ACMs not observed due to inaccessibility or not sampled due to the destructive means that sampling would require may also be encountered during construction activities. At the time of the survey, only limited destructive means were used to locate or sample suspect ACMs; therefore, additional suspect ACMs may remain within inaccessible areas that include, but are not limited to, sub-grade walls, structural members, topping slabs, exterior areas, sub-grade sealants, flooring located below underlayments, vapor barriers, pipe trenches and other subsurface utilities, etc. If additional suspect ACMs are uncovered which were not accessible during this survey, it is recommended that these materials either be assumed to contain asbestos or be sampled prior to disturbance upon discovery for asbestos content by an asbestos inspector in accordance with 29 CFR 1926.1101.

### 5.2 Lead in Paint and Surface Coatings

Based on the findings of the lead survey, detectable concentrations of lead were identified on some paints and surface coatings.

The presence of lead is a concern primarily when conditions exist where it may be inhaled or ingested. Regardless of the analytical results of a material, all painted and/or glazed surfaces may still contain concentrations of lead in the paint, which when disturbed, may generate lead dust greater than the Permissible Exposure Limit (PEL) of 50 micrograms per cubic meter ( $\mu\text{g}/\text{m}^3$ ) as an 8-hour Time Weighted Average (TWA) established by the OSHA "Lead Exposure in Construction Rule (29 CFR 1926.62)."



The OSHA standard gives no guidance on acceptable levels of lead in paint at which no exposure to airborne lead (above the action level) would be expected. Rather, OSHA defines airborne concentrations, and references specific types of work practices and operations from which a lead hazard may be generated (reference 29 CFR 1926.62, section d). Environmental and personnel monitoring should be conducted during any removal/demolition process (as appropriate) to verify that actual personal exposures are below the PEL of 50  $\mu\text{g}/\text{m}^3$  as an 8-hour TWA. Under OSHA requirements, the contractor performing renovation work will be required to conduct this monitoring and follow applicable requirements under 29 CFR 1926.62 if disturbing LCP.

Destructive actions to paint containing detectable levels of lead (e.g. component removal, demolition, sanding, grinding, burning, paint preparation, etc.) will require the contractor comply with the standards of the OSHA regulation 29 CFR 1926.62, including but not limited to training, initial exposure monitoring, the use of personal protective equipment, and medical surveillance. The OSHA standard gives no guidance on acceptable levels of lead in paint at which no exposure to airborne lead (above the action level) would be expected. Rather, OSHA defines airborne concentrations, and references specific types of work practices and operations from which a lead hazard may be generated (reference 29 CFR 1926.62, section d). Environmental and personnel monitoring should be conducted during any removal/demolition process (as appropriate) to verify that actual personal exposures are below the PEL as an 8-hour TWA.

## 6.0 LIMITATIONS

The conclusions and recommendations presented within this report are based upon a reasonable level of assessment within normal bounds and standards of professional practice for a site in this particular geographic setting. ECS is not responsible or liable for the discovery and elimination of hazards that may potentially cause damage, accidents, or injuries.

The observations, conclusions, and recommendations pertaining to environmental conditions at the subject site are necessarily limited to conditions observed, and/or materials reviewed at the time this study was undertaken. No warranty, expressed or implied, is made with regard to the conclusions and recommendations presented within this report. This report is provided for the exclusive use of the client. This report is not intended to be used or relied upon in connection with other projects or by other unidentified third parties without the written consent of ECS and the client.

Our recommendations are in part based on federal, state, and local regulations and guidelines. ECS does not assume the responsibility of the person(s) in charge of the site, or otherwise undertake responsibility for reporting to any local, state, or federal public agencies, any conditions at the site that may present a potential danger to public health, safety, or the environment. Under this scope of services, ECS assumes no responsibility regarding any response actions initiated as a result of these findings. General compliance with regulations and response actions are the sole responsibility of the Client and should be conducted in accordance with local, state, and/or federal requirements.

# **Appendix I: Site Photographs**




1 - View of Noah's Ark Building 1



2 - View of Noah's Ark Building 2



3 - View of the interior of Noah's Ark - Building 1



4 - View of the interior of Noah's Ark - Building 2



5 - View of the wall panels



6 - View of the tank insulation



7 - View of the roof of Building 1



8 - View of the roof of Building 2



9 - View of yellow paint on CMU wall

# **Appendix II: Asbestos Bulk Sample Results**





# EMSL Analytical, Inc.

2205 Corporate Plaza Parkway SE, Suite 200 Smyrna, GA 30080

Tel/Fax: (770) 956-9150 / (770) 956-9181

<http://www.EMSL.com> / [atlantalab@emsl.com](mailto:atlantalab@emsl.com)

EMSL Order: 072208277

Customer ID: ENCS55

Customer PO:

Project ID:

**Attention:** Jenny Clark  
ECS Southeast, LLP  
1200 Woodruff Road  
Suite H-12  
Greenville, SC 29607

**Project:** 18720

**Phone:** (864) 987-1610

**Fax:** (864) 987-1615

**Received Date:** 11/18/2022 12:05 PM

**Analysis Date:** 11/21/2022

**Collected Date:**

## Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
WG-1 072208277-0001	Window Glazing - Bldg. #1 - Window	Clear Non-Fibrous Homogeneous	HA: 1	100% Non-fibrous (Other)	None Detected
WG-2 072208277-0002	Window Glazing - Bldg. #1 - Window	Clear Non-Fibrous Homogeneous	HA: 1	100% Non-fibrous (Other)	None Detected
WS-1 072208277-0003	Window Sill - Bldg. #1 - Exterior Window	Gray Non-Fibrous Homogeneous	HA: 2	100% Non-fibrous (Other)	None Detected
WS-2 072208277-0004	Window Sill - Bldg. #1 - Exterior Window	Gray Non-Fibrous Homogeneous	HA: 2	100% Non-fibrous (Other)	None Detected
G-1 072208277-0005	Gasket - Bldg. #1 - Blue Equip	Brown Fibrous Homogeneous	HA: 3	90% Cellulose 10% Non-fibrous (Other)	None Detected
G-2 072208277-0006	Gasket - Bldg. #1 - Blue Equip	Brown Fibrous Homogeneous	HA: 3	90% Cellulose 10% Non-fibrous (Other)	None Detected
TI-1-Layer 1 072208277-0007	Tank Insulation - Bldg. #1 - Tank 1	Blue Non-Fibrous Homogeneous	HA: 4	5% Min. Wool 95% Non-fibrous (Other)	None Detected
TI-1-Layer 2 072208277-0007A	Tank Insulation - Bldg. #1 - Tank 1	Tan Non-Fibrous Homogeneous	HA: 4	20% Min. Wool 80% Non-fibrous (Other)	None Detected
TI-2-Layer 1 072208277-0008	Tank Insulation - Bldg. #1 - Tank2	Blue Non-Fibrous Homogeneous	HA: 4	5% Min. Wool 95% Non-fibrous (Other)	None Detected
TI-2-Layer 2 072208277-0008A	Tank Insulation - Bldg. #1 - Tank2	Tan Non-Fibrous Homogeneous	HA: 4	20% Min. Wool 80% Non-fibrous (Other)	None Detected
WP-1 072208277-0009	Wall Panel - Bldg. #1 - Ext.- Under Windows	White Non-Fibrous Homogeneous	HA: 5	100% Non-fibrous (Other)	None Detected
WP-2 072208277-0010	Wall Panel - Bldg. #1 - Ext.- Under Windows	White Non-Fibrous Homogeneous	HA: 5	100% Non-fibrous (Other)	None Detected

Initial report from: 11/21/2022 11:52:10



# EMSL Analytical, Inc.

2205 Corporate Plaza Parkway SE, Suite 200 Smyrna, GA 30080

Tel/Fax: (770) 956-9150 / (770) 956-9181

<http://www.EMSL.com> / [atlantalab@emsl.com](mailto:atlantalab@emsl.com)

EMSL Order: 072208277

Customer ID: ENCS55

Customer PO:

Project ID:

## Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
RM-1 072208277-0011	Roof Mastic - Bldg. #1 - Upper Roof	Black Non-Fibrous Homogeneous	5% Cellulose	95% Non-fibrous (Other)	None Detected
			HA: 6		
RM-2 072208277-0012	Roof Mastic - Bldg. #1 - Upper Roof	Black Non-Fibrous Homogeneous		97% Non-fibrous (Other)	3% Chrysotile
			HA: 6		
BUR-1-Mastic 072208277-0013	Built-Up Roofing - Bldg. #1 - Upper Roof	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-1-Felt 072208277-0013A	Built-Up Roofing - Bldg. #1 - Upper Roof	Black Fibrous Homogeneous	80% Cellulose	20% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-2-Mastic 072208277-0014	Built-Up Roofing - Bldg. #1 - Upper Roof	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-2-Felt 072208277-0014A	Built-Up Roofing - Bldg. #1 - Upper Roof	Black Fibrous Homogeneous	80% Cellulose	20% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-3-Mastic 072208277-0015	Built-Up Roofing - Bldg. #1 - Lower Roof	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-3-Felt 072208277-0015A	Built-Up Roofing - Bldg. #1 - Lower Roof	Black Fibrous Homogeneous	80% Cellulose	20% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-4-Mastic 072208277-0016	Built-Up Roofing - Bldg. #1 - Lower Roof	Black Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 7		
BUR-4-Felt 072208277-0016A	Built-Up Roofing - Bldg. #1 - Lower Roof	Black Fibrous Homogeneous	80% Cellulose	20% Non-fibrous (Other)	None Detected
			HA: 7		
GM-1 072208277-0017	Gasket Material - Bldg. #2 - Equip	Red Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 8		
GM-2 072208277-0018	Gasket Material - Bldg. #2 - Equip	Red Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 8		
WS-3 072208277-0019	Window Sill - Bldg. #2 - Exterior Window	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 2		
WS-4 072208277-0020	Window Sill - Bldg. #2 - Exterior Window	Gray Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 2		

Initial report from: 11/21/2022 11:52:10



# EMSL Analytical, Inc.

2205 Corporate Plaza Parkway SE, Suite 200 Smyrna, GA 30080

Tel/Fax: (770) 956-9150 / (770) 956-9181

<http://www.EMSL.com> / [atlantalab@emsl.com](mailto:atlantalab@emsl.com)

**EMSL Order:** 072208277  
**Customer ID:** ENCS55  
**Customer PO:**  
**Project ID:**

## Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
WC-1 <small>072208277-0021</small>	Window Caulk - Bldg. #2 - Exteroir	Brown Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 9		
WC-2 <small>072208277-0022</small>	Window Caulk - Bldg. #2 - Exteroir	Brown Non-Fibrous Homogeneous		100% Non-fibrous (Other)	None Detected
			HA: 9		

Analyst(s) \_\_\_\_\_  
 Violedah Richardson (28)

\_\_\_\_\_  
 Violedah Richardson, Laboratory Manager  
 or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc Smyrna, GA NVLAP Lab Code 101048-1

Initial report from: 11/21/2022 11:52:10

# Asbestos Bulk Building Materials - Chain of Custody



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

EMSL Order Number / Lab Use Only

072208277

EMSL Analytical, Inc.  
2205 Corporate Plaza Southeast  
Suite 200  
Smyrna, GA 30080  
PHONE: (770) 956-9150  
EMAIL: atlantab@emsl.com

Customer Information	Customer ID: ENCS55	Billing Information	Billing ID:
	Company Name: ECS Southeast LLP		Company Name: ECS Southeast LLP
	Contact Name: Jenny Clark		Billing Contact: Jenny Clark
	Street Address: 1200 Woodruff Road, Suite H-12		Street Address: 1200 Woodruff Road, Suite H-12
	City, State, Zip: Greenville SC 29607 Country: US		City, State, Zip: Greenville SC Country:
	Phone: 4046409257		Phone: 4046409257
Email(s) for Report: jclark@ecslimited.com	Email(s) for Invoice: jclark@ecslimited.com		

**Project Information**

Project Name/No: 18720

EMSL LIMS Project ID: (If applicable, EMSL will provide)

US State where samples collected: GA

State of Connecticut (CT) must select project location  
 Commercial (Taxable)  Residential (Non-Taxable)

Sampled By Name: Jenny Clark

Sampled By Signature: *Jenny Clark*

No. of Samples in Shipment: 22

Turn-Around-Time (TAT)  
 3 Hour  6 Hour  24 Hour  32 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. \*32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

**Test Selection**

**PLM - Bulk (reporting limit)**

PLM EPA 600/R-93/116 (<1%)  
 PLM EPA NOB (<1%)  
 POINT COUNT  
 400 (<0.25%)  1,000 (<0.1%)  
 POINT COUNT w/ GRAVIMETRIC  
 400 (<0.25%)  1,000 (<0.1%)  
 NIOSH 9002 (<1%)  
 NYS 198.1 (Friable - NY)  
 NYS 198.6 NOB (Non-Friable - NY)  
 NYS 198.8 (Vermiculite SM-V)

**TEM - Bulk**

TEM - Bulk  
 TEM EPA NOB  
 NYS NOB 198.4 (Non-Friable-NY)  
 TEM EPA 600/R-93/116 w Milling Prep (0.1%)

**Other Tests (please specify)**

Positive Stop - Clearly Identified Homogeneous Areas (HA)

Sample Number	HA Number	Sample Location	Material Description
WG-1	1	Bldg #1 - window	Window Glazing
WG-2	1	↓	↓
WS-1	2	Bldg #1 exterior window	Window sill
WS-2	2	↓	↓
G-1	3	Bldg #1 - blue equip.	Basket
G-2	3	↓	↓
T1-1	4	Bldg #1 - Tank 1	Tank Insulation
T1-2	4	↓ Tank 2	↓
WP-1	5	Bldg #1 - ext - under	Wall panel
WP-2	5	↓ windows	↓

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

After Thanks given is fine

Method of Shipment: drop-off

Sample Condition Upon Receipt:

Relinquished by: *Jenny Clark* Date/Time: 11/18/2012 12:00pm

Received by: *SS* Date/Time: 11/18/2012 12:05 PM

Relinquished by: Date/Time:

Received by: Date/Time:

Controlled Document - Asbestos Bulk R5 03/18/2021

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



# **Appendix III: Lead Laboratory Analytical Results**



**EMSL Analytical, Inc.**

706 Gralin Street, Kernersville, NC 27284  
Phone/Fax: (336) 992-1025 / (336) 992-4175  
<http://www.EMSL.com> [greensborolab@emsl.com](mailto:greensborolab@emsl.com)

EMSL Order: 022208685  
CustomerID: ENCS55  
CustomerPO:  
ProjectID:

Attn: **Jenny Clark**  
**ECS Southeast, LLP**  
**1200 Woodruff Road**  
**Suite H-12**  
**Greenville, SC 29607**

Phone: (864) 987-1610  
Fax: (864) 987-1615  
Received: 11/21/2022 09:00 AM  
Collected: 11/18/2022

Project: 18720

**Test Report: Lead in Paint Chips by Flame AAS (SW 846 3050B/7000B)\***

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Weight</i>	<i>Lead Concentration</i>
PC-1	022208685-0001	11/18/2022	11/22/2022	.377 g	<0.0080 % wt
PC-2	022208685-0002	11/18/2022	11/22/2022	.251 g	<0.0080 % wt
PC-3	022208685-0003	11/18/2022	11/22/2022	.2722 g	0.026 % wt
PC-4	022208685-0004	11/18/2022	11/22/2022	.2952 g	<0.0080 % wt
PC-5	022208685-0005	11/18/2022	11/22/2022	.2628 g	0.015 % wt
PC-6	022208685-0006	11/18/2022	11/22/2022	.1146 g	<0.017 % wt
PC-7	022208685-0007	11/18/2022	11/22/2022	.2578 g	<0.0080 % wt
PC-8	022208685-0008	11/18/2022	11/22/2022	.3082 g	<0.0080 % wt
PC-9	022208685-0009	11/18/2022	11/22/2022	.3113 g	<0.0080 % wt

James Cole, Laboratory Manager  
or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.  
\* Analysis following Lead in Paint by EMSL SOP/Determination of Environmental Lead by FLAA. Reporting limit is 0.008% wt based on the minimum sample weight per our SOP. "<" (less than) result signifies the analyte was not detected at or above the reporting limit. Measurement of uncertainty is available upon request. Definitions of modifications are available upon request.  
Samples analyzed by EMSL Analytical, Inc. Kernersville, NC AIHA LAP, LLC-ELLAP Accredited #102564

Initial report from 11/23/2022 08:42:38

EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

82285

Customer Information	Customer ID:	Billing ID:
	Company Name: ECS Southeast LLP	Company Name: ECS Southeast LLP
	Contact Name: Jenny Clark	Billing Contact: Jenny Clark
	Street Address: 1200 Woodruff Road Suite H-12	Street Address: 1200 Woodruff Road, Suite H-12
	City, State, Zip: Greenville SC 29607 Country: US	City, State, Zip: Greenville SC 29607 Country: US
	Phone: 4046409257	Phone: 4046409257
Email(s) for Report: jclark@ecslimited.com		Email(s) for Invoice:

Project Information

Project Name/No: 18720

EMSL LIMS Project ID: (If applicable, EMSL will provide)

US State where samples collected: GA

State of Connecticut (CT) must select project location:  Commercial (Taxable)  Residential (Non-Taxable)

Sampled By Name: Jenny Clark

Sampled By Signature: *Jenny Clark*

No. of Samples in Shipment: 4

Turn-Around-Time (TAT)

3 Hour  6 Hour  24 Hour  32 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. \*32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION	
CHIPS <input checked="" type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm <sup>2</sup>	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input checked="" type="checkbox"/>	
*Reporting Limit based on a minimum 0.25g sample weight	SW 846-8010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>	
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>	
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	<input type="checkbox"/>	
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>	
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>	
*If no box is checked, non-ASTM Wipe is assumed	SW 846-8010D*	ICP-OES	10µg/wipe	<input type="checkbox"/>	
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	SW 846-1311 / SW 846-8010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>	
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	SW 846-1312 / SW 846-8010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>	
TTLIC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>	
	22 CCR App. II, SW 846-8010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>	
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	22 CCR App. II, SW 846-8010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>	
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>	
	SW 846-8010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>	
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>	
	Unpreserved <input type="checkbox"/> Preserved with HNO <sub>3</sub> <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water	Unpreserved <input type="checkbox"/> Preserved with HNO <sub>3</sub> <input type="checkbox"/> PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input type="checkbox"/>	
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>	
Other:				<input type="checkbox"/>	

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
PC-1	Bldg #1 Wall	Yellow	11/18/2022
PC-2	Equip. Base	Light blue	
PC-3	Floor	Brown	
PC-4	Ceiling	Yellow	
PC-5	Pipe	Light blue	

Method of Shipment: *drop off @ EMSL FX*

Sample Condition Upon Receipt:

Relinquished by: *Jenny Clark* Date/Time: *11/18/2022 12:00PM*

Received by: *SS NS* Date/Time: *11/18/22 12:05 hrs*

Relinquished by:

Received by: *NS* Date/Time: *11/21/22 9:00*





# **Appendix IV: Certifications/ Licenses**

---

---

# ***The Environmental Institute***

---

---

## ***Jennifer Clark***

---

Social Security Number - XXX-XX-4341  
ECS Souteast LLP - 1281 Kennestone Circle, Suite 200, Marietta, GA 30066

*Has completed 8 hours of coursework and satisfactorily  
passed an examination that meets all criteria required for  
EPA/AHERA/ASHARA (TSCA Title II) Approved Reaccreditation*

### ***Asbestos in Buildings: Inspector & Management Planner Refresher***

January 18, 2022

Course Date

18780

Certificate Number

January 18, 2022

Examination Date

January 17, 2023

Expiration Date



Darryl L. Watson

Darryl L. Watson - Principal Instructor

(Approved by the ABIH Certification Maintenance Committee for 1 CM point - Approval #11-583)  
(FL Provider Registration #FL49-0001342 - Inspector Ref. Course #0002805 - Mgmt. Plan Ref. Course #0002806)  
TEI - 1395 S. Marietta Parkway SE - Building 100, Suite 124- Marietta, GA 30067  
Phone: 770-427-3600 - Website: [www.tei-atl.com](http://www.tei-atl.com)

---

---

# **The Environmental Institute**

---

---

## *Jennifer Clark*

---

Social Security Number - XXX-XX-4341  
ECS Southeast LLP - 1281 Kenneston Circle, Suite 200 - Marietta, Georgia 30066

*Has completed 8 hours of coursework and satisfactorily passed the hands-on skills assessment and an examination that meets training criteria in accordance with requirements for Lead-Based Paint Activities in Target Housing and Child-Occupied Facilities as regulated by Georgia DNR/EPD Chapter 391-3-24 and U. S. EPA TSCA 40 CFR Part 745 for the refresher course titled*

## **Lead Inspector Refresher**

August 18, 2021

Course Date

1986

Certificate Number

August 18, 2021

Examination Date


August 17, 2023


Georgia Expiration Date

August 17, 2024

EPA Expiration Date



  
Bonnie B. Maurras - Principal Instructor

  
David W. Hogue - Training Manager

(Approved by the ABIH Certification Maintenance Committee for 1 CM point - Approval #11-584)

TEI - 1395 S. Marietta Parkway SE - Building 100, Suite 124 - Marietta, GA 30067

Phone: 770-427-3600 - Website: [www.tei-atl.com](http://www.tei-atl.com)

(State of Georgia Accredited - Certification No. 20-0799-006SR - September 21, 1999)

# ASBESTOS AND LEAD PAINT SURVEY



JONESBORO RSP

7700 OLD MORROW ROAD  
JONESBORO, GEORGIA 30236

ECS PROJECT NO. 49:18721

FOR: HAZEN AND SAWYER

NOVEMBER 30, 2022





November 30, 2022

Mr. Chas Goblisch  
Hazen and Sawyer  
1300 Althmore Avenue  
Suite D-520  
Atlanta, Georgia 30342  
CGoblisch@hazenandsawyer.com

ECS Project No. 49:18721

Reference: Asbestos and Lead Paint Survey, Jonesboro RSP, 7700 Old Morrow Road, Jonesboro, Georgia

Dear Mr. Goblisch:

ECS Southeast, LLP (ECS) is pleased to provide Hazen and Sawyer with the results of the above referenced Asbestos and Lead Paint Survey performed at Jonesboro RSP located at 7700 Old Morrow Road in Jonesboro, Clayton County, Georgia. This report summarizes our observations, analytical results, findings, and recommendations related to the work performed. The work described in this report was performed by ECS in general accordance with the Scope of Services described in ECS Proposal Number 49:33783P and the terms and conditions of the agreement authorizing those services.

ECS appreciates this opportunity to provide Hazen and Sawyer with our services. If we can be of further assistance to you, please do not hesitate to contact us.

Sincerely,

ECS Southeast, LLP

Jenny Clark, REM  
Environmental Department Manager  
jclark@ecslimited.com  
404-640-9257

Justin Roth, CHMM  
Environmental Principal  
jroth@ecslimited.com  
843-654-4448

## **EXECUTIVE SUMMARY**

The subject property is developed with a water treatment facility located at 7700 Old Morrow Road in Jonesboro, Clayton County, Georgia. The pump station building consists of approximately 2,800 square feet of space and was reportedly constructed in 1991. ECS understands the building is scheduled for demolition.

The purpose of the Asbestos and Lead Paint Survey was to identify asbestos-containing materials (ACMs) and lead-paint that may be present within the building materials scheduled to be impacted by the planned demolition activities.

### **Asbestos Survey**

On November 18, 2022, Ms. Jenny Clark, REM, an accredited inspector, performed the asbestos assessment. Bulk samples were submitted to EMSL Analytical, Inc. (EMSL) in Smyrna, Georgia for analysis via Polarized Light Microscopy (PLM) in accordance with the current EPA-600 methodology.

A total of eight bulk samples from four homogeneous areas were submitted to the laboratory of which eight layers were analyzed. Based on the laboratory analysis of the bulk samples collected during the survey, none of the materials were reported to contain asbestos above the regulatory limit.

The following materials were reported as non asbestos containing:

- Exterior window caulk;
- Exterior sealant;
- Roofing mastic; and
- Built-up roofing material.

Due to inaccessibility or the destructive means that asbestos sampling requires, unseen ACMs may remain within the building hidden behind inaccessible areas that include, but are not limited to, sub-grade walls, structural members, topping slabs, sub-grade sealants, flooring located below underlayments, areas behind exterior walls, pipe trenches, and subsurface utilities, etc.

If suspect materials are discovered during construction activities, they should be presumed to contain asbestos and be treated as ACMs or be sampled immediately upon discovery and prior to disturbance for asbestos content by a certified asbestos inspector in accordance with 29 Code of Federal Regulations (CFR) 1926.1101.

### **Lead Paint Survey**

On November 18, 2022, Ms. Jenny Clark, REM, an accredited inspector, performed the Lead Paint Survey. Paint chip samples were submitted to EMSL Analytical, Inc. (EMSL) in Kernersville, North Carolina for analysis via Flame Atomic Absorption Spectroscopy (AAS) in accordance with EPA Method SW 3050B/7000B.

A total of six paint chips were collected. Based on the findings of the lead survey, detectable concentrations of lead were identified on some paints and surface coatings.

The executive summary is an integral portion of this report, however, ECS recommends the report be read in its entirety.



<b>TABLE OF CONTENTS</b>		<b>PAGE</b>
<b>1.0</b>	<b>SITE DESCRIPTION</b> .....	<b>1</b>
<b>2.0</b>	<b>PURPOSE</b> .....	<b>1</b>
<b>3.0</b>	<b>METHODOLOGY</b> .....	<b>1</b>
3.1	Asbestos-Containing Materials .....	1
3.2	Lead in Paint and Surface Coatings .....	2
<b>4.0</b>	<b>RESULTS</b> .....	<b>2</b>
4.1	Asbestos-Containing Materials .....	3
4.2	Suspect or Assumed Asbestos-Containing Materials .....	3
4.3	Lead in Paint and Surface Coatings .....	3
<b>5.0</b>	<b>RECOMMENDATIONS AND REGULATORY REQUIREMENTS</b> .....	<b>4</b>
5.1	Asbestos-Containing Materials .....	4
5.2	Lead in Paint and Surface Coatings .....	5
<b>6.0</b>	<b>LIMITATIONS</b> .....	<b>5</b>

## **TABLE OF APPENDICES**

Appendix I: Site Photographs

Appendix II: Asbestos Bulk Sample Results

Appendix III: Lead Laboratory Analytical Results

Appendix IV: Certifications/Licenses

## 1.0 SITE DESCRIPTION

The property is developed with a water treatment facility located at 7700 Old Morrow Road in Jonesboro, Clayton County, Georgia. The pump station building consists of approximately 2,800 square feet of space and was reportedly constructed in 1991. The interior finishes include concrete floors, walls and ceilings. The exterior is brick with a built-up roof.

## 2.0 PURPOSE

The purpose of the Asbestos and Lead Paint Survey was to identify asbestos-containing materials (ACMs) and lead-containing paint (LCP) which require special handling and/or disposal if disturbed during construction activities. The identification of ACMs require trained labor, regulated work practices, and special disposal. The identification of LCP requires disclosure to contractors and monitoring of lead exposure.

## 3.0 METHODOLOGY

ECS performed the authorized Scope of Services in general accordance with our proposal, standard industry practice(s) and methods specified by regulation(s) for the identification of ACMs and LCP.

### 3.1 Asbestos-Containing Materials

On November 18, 2022, Ms. Jenny Clark, REM, an EPA accredited inspector, performed the asbestos survey. The survey consisted of observing the accessible areas of the building for the presence of suspect materials which may contain asbestos. The survey involved detecting both friable materials (materials which can be pulverized or reduced to a powder by hand pressure when dry) and non-friable materials (materials which pose a hazard when sawn, sanded, drilled or pulverized). Homogeneous materials (based on material type, color, texture, etc.) were identified in during the survey.

The EPA National Emissions Standard for Hazardous Air Pollutants (NESHAP) requires a survey for asbestos prior to renovation or demolition. Renovation or demolition is defined under NESHAP as the removal of a load-bearing structure or member. On the basis of requirements under NESHAP for renovation activities, ECS conducted a limited survey for potential ACM. The ACM survey was limited in that we did not conduct demolition such as jack/sledge hammering to expose potentially concealed materials.

Samples were collected in general accordance with EPA Standard 40 CFR 763 Subpart E, Asbestos Hazard Emergency Response Act (AHERA) and OSHA Standard 29 CFR 1926.1101 Inspection Protocol. Multiple samples of each unique material were submitted. Samples were analyzed using "Positive Stop" methodology. If one sample of a homogeneous material is reported to contain asbestos, the remaining samples of that material are not analyzed. If one sample of a material from a homogeneous area was reported to contain greater than 1% asbestos, then by EPA definition, it was characterized as asbestos-containing material.

As per the regulations, samples were collected from random locations of each homogeneous area, with the material's number of samples based upon the following criteria:

- Thermal Insulation Materials (piping, breeching, boiler insulation, etc.) – A minimum of two (2) samples are required. Patch areas (less than 6 square or linear feet) may have one (1) sample collected.
- Surfacing Materials (plaster, fireproofing, etc.) – A minimum of seven (7) samples are to be taken for areas greater than 5,000 square feet; five (5) for areas greater than 1,000 square feet, but less than 5,000 square feet; three (3) for areas less than 1,000 square feet.
- Miscellaneous Materials (flooring, adhesives, roofing, wallboard, etc.) – A minimum of two (2) samples are required.

In order to determine if the suspect materials observed during the visual survey contained asbestos, representative bulk samples were collected and placed in sealed packages. Samples were collected during the survey and submitted to EMSL for analysis using the EPA recommended method of Polarized Light Microscopy (PLM) coupled with dispersion staining (Method No. EPA 600/M4-020-82, Dec. 1982). EMSL participates in the National Voluntary Laboratory Accreditation Program (NVLAP). Their NVLAP accreditation number is 101048-1. Several of the samples were layered and analyzed as multiple samples. EPA regulations require that multiple samples of each homogeneous area be collected for laboratory analysis. The material type, sample location, and analytical results of each bulk sample are also summarized in the attached Asbestos Bulk Analysis report in **Appendices**.

During the survey, ECS attempted to identify suspect ACMs in readily accessible areas. However, due to the destructive means required to identify some materials, certain areas were deemed inaccessible (i.e. behind walls or sub grade materials) and were not surveyed for suspect ACMs. Unidentified suspect ACMs may be located in these and/or other inaccessible areas.

### **3.2 Lead in Paint and Surface Coatings**

The lead paint survey was performed by collection of suspect lead paint chips to identify lead concentrations in painted surfaces.

The lead paint assessment was conducted utilizing the U.S. EPA definition of lead-based paint (LBP). Under this definition, painted surfaces which contain lead in concentrations equal to or greater than 0.5% lead by weight are classified as coated with LBP. Paints with concentrations of detectable levels of paint are considered LCPs. Activities which disturb LCPs and glazing (while not LBPs by the U.S. EPA definition) are regulated by OSHA (29 CFR 1926.62).

Because the current or proposed use of the property is not residential or child-occupied, the scope of the lead paint survey was not conducted in accordance with HUD Chapter 7 requirements. This representative survey included collecting paint chips from walls, windows, doors, and miscellaneous components.

## **4.0 RESULTS**

The following is a summary of laboratory results, findings and observations.

#### 4.1 Asbestos-Containing Materials

In total, eight bulk samples from four homogeneous areas were submitted to the laboratory of which eight layers were analyzed. An Asbestos-Containing Material (ACM) is defined as any material containing more than one percent (>1%) asbestos as determined using the method specified in Appendix E, Subpart E, 40 CFR Part 763, Section 1, PLM. Materials are categorized by the U.S. EPA in the following categories:

- Friable ACMs are defined as any ACM that, when dry, can be crumbled, pulverized or reduced to powder by hand pressure. Non-friable ACMs are defined as any ACM that, when dry, cannot be crumbled, pulverized, or reduced to powder by hand pressure.
- Category I non-friable ACM are listed as following: packings, gaskets, resilient floor coverings, and asphalt roofing products containing more than one percent (>1%) asbestos.
- Category II non-friable ACM are listed as any material, excluding Category I non-friable ACM, containing more than one percent (>1%) asbestos.

Regulated Asbestos Containing Materials (RACM) are friable ACM or non-friable ACM that will be or has been subjected to sanding, grinding, cutting, or abrading or has crumbled, been pulverized, or reduced to powder in the course of renovation and/or demolition operations.

EMSL submitted a signed final laboratory report to ECS on November 22, 2022. None of the bulk samples submitted for analysis were reported to contain asbestos in detectable concentrations. A complete list of the sampled materials submitted for analysis and sample locations are located in the Appendix of this report. Representative photographs of collected samples are also located in the Appendix of this report.

#### 4.2 Suspect or Assumed Asbestos-Containing Materials

Due to the inaccessibility or the destructive means that asbestos sampling requires, additional suspect ACMs may remain within the building hidden behind inaccessible areas that include, but are not limited to, sub-grade walls, structural members, topping slabs, sub-grade sealants, flooring located below underlayments, areas behind exterior walls, pipe trenches, and subsurface utilities, etc. These areas were deemed inaccessible and were not assessed.

If these materials are discovered during construction activities, they should be presumed to contain asbestos and be treated as ACMs or be sampled immediately upon discovery and prior to disturbance for asbestos content by a certified asbestos inspector in accordance with 29 CFR 1926.1101.

Based upon our past experience in the identification of ACMs in similarly constructed buildings, the following additional suspect ACMs may also be located in inaccessible areas of the structure:

- Within the piping systems or equipment not accessed below grade.

#### 4.3 Lead in Paint and Surface Coatings

Paint and surface coatings which contain detectable concentrations of lead considered "lead-containing paints". Since OSHA has no specific action level for lead in paint, all paint on the site found to have a measurable concentration of lead should be assumed to be lead containing. Work

performed which may disturb lead-containing paint is regulated under OSHA as referenced under 29 CFR 1926.62. A total of [164] readings were collected during the survey, including calibration readings. Paint and other surface coatings which are defined by applicable regulation as lead-based paints are summarized in the table below and photographs of lead-based paint identified are located in the Appendix.

Paint and surface coatings which contain detectable concentrations of lead are considered LCPs. Since OSHA has no specific action level for lead in paint, all paint on the site found to have a measurable concentration of lead should be assumed to be lead-containing. Work performed which may disturb LCP is regulated under OSHA as referenced under 29 CFR 1926.62. A total of six paint chip samples were collected during the survey. Paint and other surface coatings that were sampled are summarized in the table below and photographs of sampling locations are located in the Appendix.

### Summary of Paint Chip Results

Sample ID	Color	Substrate	Component	Lead Concentration (%) by Weight
PC-1	Light Blue	Metal	Equipment - Piping	0.035%
PC-2	Yellow	Concrete/ CMU	Wall	<0.010%
PC-3	Red	Metal	Pipe	<0.020%
PC-4	Light Blue	Metal	Equipment - Base	<0.0080%
PC-5	Brown	Metal	Door Components	<0.039%
PC-6	Dark Yellow	Metal	CAT Equipment	<0.021%

## 5.0 RECOMMENDATIONS AND REGULATORY REQUIREMENTS

Based on our understanding of the purpose of the Asbestos and Lead Paint Survey, the results of laboratory analysis, and our findings and observations, ECS presents the following recommendations.

### 5.1 Asbestos-Containing Materials

None of the bulk samples submitted to EMSL were reported to contain detectable concentrations of asbestos. If additional suspect asbestos-containing materials are uncovered which were not accessible during this sampling event, it is recommended that these materials be sampled or tested immediately upon discovery for asbestos content by an asbestos inspector in accordance with 29 CFR 1926.1101.

## 5.2 Lead in Paint and Surface Coatings

Based on the findings of the lead survey, detectable concentrations of lead were identified on some paints and surface coatings.

The presence of lead is a concern primarily when conditions exist where it may be inhaled or ingested. Regardless of the analytical results of a material, all painted and/or glazed surfaces may still contain concentrations of lead in the paint, which when disturbed, may generate lead dust greater than the Permissible Exposure Limit (PEL) of 50 micrograms per cubic meter ( $\mu\text{g}/\text{m}^3$ ) as an 8-hour Time Weighted Average (TWA) established by the OSHA "Lead Exposure in Construction Rule (29 CFR 1926.62)."

The OSHA standard gives no guidance on acceptable levels of lead in paint at which no exposure to airborne lead (above the action level) would be expected. Rather, OSHA defines airborne concentrations, and references specific types of work practices and operations from which a lead hazard may be generated (reference 29 CFR 1926.62, section d). Environmental and personnel monitoring should be conducted during any removal/demolition process (as appropriate) to verify that actual personal exposures are below the PEL of  $50 \mu\text{g}/\text{m}^3$  as an 8-hour TWA. Under OSHA requirements, the contractor performing renovation work will be required to conduct this monitoring and follow applicable requirements under 29 CFR 1926.62 if disturbing LCP.

Destructive actions to paint containing detectable levels of lead (e.g. component removal, demolition, sanding, grinding, burning, paint preparation, etc.) will require the contractor comply with the standards of the OSHA regulation 29 CFR 1926.62, including but not limited to training, initial exposure monitoring, the use of personal protective equipment, and medical surveillance. The OSHA standard gives no guidance on acceptable levels of lead in paint at which no exposure to airborne lead (above the action level) would be expected. Rather, OSHA defines airborne concentrations, and references specific types of work practices and operations from which a lead hazard may be generated (reference 29 CFR 1926.62, section d). Environmental and personnel monitoring should be conducted during any removal/demolition process (as appropriate) to verify that actual personal exposures are below the PEL as an 8-hour TWA.

## 6.0 LIMITATIONS

The conclusions and recommendations presented within this report are based upon a reasonable level of assessment within normal bounds and standards of professional practice for a site in this particular geographic setting. ECS is not responsible or liable for the discovery and elimination of hazards that may potentially cause damage, accidents, or injuries.

The observations, conclusions, and recommendations pertaining to environmental conditions at the subject site are necessarily limited to conditions observed, and/or materials reviewed at the time this study was undertaken. No warranty, expressed or implied, is made with regard to the conclusions and recommendations presented within this report. This report is provided for the exclusive use of the client. This report is not intended to be used or relied upon in connection with other projects or by other unidentified third parties without the written consent of ECS and the client.

Our recommendations are in part based on federal, state, and local regulations and guidelines. ECS does not assume the responsibility of the person(s) in charge of the site, or otherwise undertake responsibility for reporting to any local, state, or federal public agencies, any conditions at the site that may present a potential danger to public health, safety, or the environment. Under this scope of services, ECS assumes no responsibility regarding any response actions initiated as a result of these findings. General compliance with regulations and response actions are the sole responsibility of the Client and should be conducted in accordance with local, state, and/or federal requirements.



# **Appendix I: Site Photographs**



1 - View of Jonesboro RSP



2 - View of dark yellow paint on CAT equipment




3 - View of blue paint on pipes



4 - View of red paint on pipes and blue paint on base of equipment



5 - View of the interior of the building



6 - View of yellow paint on CMU wall



7 - View of the roof

# **Appendix II: Asbestos Bulk Sample Results**



# EMSL Analytical, Inc.

2205 Corporate Plaza Parkway SE, Suite 200 Smyrna, GA 30080

Tel/Fax: (770) 956-9150 / (770) 956-9181

<http://www.EMSL.com> / [atlantalab@emsl.com](mailto:atlantalab@emsl.com)

EMSL Order: 072208305

Customer ID: ENCS55

Customer PO:

Project ID:

**Attention:** Jenny Clark  
ECS Southeast, LLP  
1200 Woodruff Road  
Suite H-12  
Greenville, SC 29607

**Project:** 18721

**Phone:** (864) 987-1610

**Fax:** (864) 987-1615

**Received Date:** 11/21/2022 8:00 AM

**Analysis Date:** 11/22/2022

**Collected Date:**

## Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 Method using Polarized Light Microscopy

Sample	Description	Appearance	Non-Asbestos		Asbestos
			% Fibrous	% Non-Fibrous	% Type
WC-1 072208305-0001	Caulk - Exterior Windows	White Non-Fibrous Homogeneous	HA: 1	100% Non-fibrous (Other)	None Detected
WC-2 072208305-0002	Caulk - Exterior Windows	White Non-Fibrous Homogeneous	HA: 1	100% Non-fibrous (Other)	None Detected
S-1 072208305-0003	Sealant - Exterior	White Non-Fibrous Homogeneous	HA: 2	100% Non-fibrous (Other)	None Detected
S-2 072208305-0004	Sealant - Exterior	White Non-Fibrous Homogeneous	HA: 2	100% Non-fibrous (Other)	None Detected
RM-1 072208305-0005	Black Mastic - Roof	Black Non-Fibrous Homogeneous	HA: 3	20% Cellulose 80% Non-fibrous (Other)	None Detected
RM-2 072208305-0006	Black Mastic - Roof	Black Non-Fibrous Homogeneous	HA: 3	20% Cellulose 80% Non-fibrous (Other)	None Detected
BUR-1 072208305-0007	Built-Up Roofing - Roof	Black Non-Fibrous Homogeneous	HA: 4	3% Synthetic 97% Non-fibrous (Other)	None Detected
BUR-2 072208305-0008	Built-Up Roofing - Roof	Black Non-Fibrous Homogeneous	HA: 4	5% Synthetic 95% Non-fibrous (Other)	None Detected

Analyst(s)

Anthony Sanaie (4)

Kyle Rich (4)

Violedah Richardson, Laboratory Manager  
or Other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. The above analyses were performed in general compliance with Appendix E to Subpart E of 40 CFR (previously EPA 600/M4-82-020 "Interim Method") but augmented with procedures outlined in the 1993 ("final") version of the method. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Estimation of uncertainty is available on request.

Samples analyzed by EMSL Analytical, Inc Smyrna, GA NVLAP Lab Code 101048-1

Initial report from: 11/22/2022 09:34:30



EMSL ANALYTICAL, INC.  
 LABORATORY • PRODUCTS • TRAINING

EMSL Analytical, Inc. / Lab Use Only

072208305

Customer Information	Customer ID: ENCS55	Billing Information	Billing ID:
	Company Name: ECS Southeast LLP		Company Name: ECS Southeast LLP
	Contact Name: Jenny Clark		Billing Contact: Jenny Clark
	Street Address: 1200 Woodruff Road, Suite H-12		Street Address: 1200 Woodruff Road, Suite H-12
	City, State, Zip: Greenville SC 29607 Country: US		City, State, Zip: Greenville SC Country:
	Phone: 4046409257		Phone: 4046409257
Email(s) for Report: jclark@ecslimited.com	Email(s) for Invoice: jclark@ecslimited.com		

**Project Information**

Project Name/No: 10721

EMSL LIMS Project ID: (If applicable, EMSL will provide)

US State where samples collected: GA

State of Connecticut (CT) must select project location:  
 Commercial (Taxable)  Residential (Non-Taxable)

Sampled By Name: Jenny Clark

Sampled By Signature: *Jenny Clark*

No. of Samples in Shipment: 8

Turn-Around-Time (TAT)

3 Hour  6 Hour  24 Hour  32 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week

Please call ahead for large projects and/or turnaround times 6 Hours or Less. \*32 Hour TAT available for select tests only; samples must be submitted by 11:30am.

**Test Selection**

**PLM - Bulk (reporting limit)**

PLM EPA 600/R-93/116 (<1%)  
 PLM EPA NOB (<1%)  
 POINT COUNT

400 (<0.25%)  1,000 (<0.1%)

POINT COUNT w/ GRAVIMETRIC

400 (<0.25%)  1,000 (<0.1%)

NIOSH 9002 (<1%)  
 NYS 198.1 (Friable - NY)  
 NYS 198.6 NOB (Non-Friable - NY)  
 NYS 198.8 (Vermiculite SM-V)

**TEM - Bulk**

TEM - Bulk  
 TEM EPA NOB  
 NYS NOB 198.4 (Non-Friable-NY)  
 TEM EPA 600/R-93/116 w Milling Prep (0.1%)

**Other Tests (please specify)**

Positive Stop - Clearly Identified Homogeneous Areas (HA)

Sample Number	HA Number	Sample Location	Material Description
WC-1	1	Exterior Windows	caulk
WC-2	1	↓	↓
S-1	2	Exterior	sealant
S-2	2	↓	↓
RM-1	3	Roof	Black Mastic
RM-2	3	↓	↓
BUR-1	4	Roof	Built-up roofing
BUR-2	4	↓	↓

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Method of Shipment: Drop-box

Sample Condition Upon Receipt:

Relinquished by: Jenny Clark

Date/Time: 11/20/22 11:18am

Received by: *[Signature]*

Date/Time: 11/21/22 8:00 AM

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)



# **Appendix III: Lead Laboratory Analytical Results**

**EMSL Analytical, Inc.**

706 Gralin Street, Kernersville, NC 27284  
 Phone/Fax: (336) 992-1025 / (336) 992-4175  
<http://www.EMSL.com> [greensborolab@emsl.com](mailto:greensborolab@emsl.com)

EMSL Order: 022208684  
 CustomerID: ENCS55  
 CustomerPO:  
 ProjectID:

Attn: **Jenny Clark**  
**ECS Southeast, LLP**  
**1200 Woodruff Road**  
**Suite H-12**  
**Greenville, SC 29607**

Phone: (864) 987-1610  
 Fax: (864) 987-1615  
 Received: 11/21/2022 09:00 AM  
 Collected: 11/18/2022

Project: 18721

**Test Report: Lead in Paint Chips by Flame AAS (SW 846 3050B/7000B)\***

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Weight</i>	<i>Lead Concentration</i>
PC-1	022208684-0001	11/18/2022	11/22/2022	.2823 g	0.035 % wt
PC-2	022208684-0002	11/18/2022	11/22/2022	.1941 g	<0.010 % wt
PC-3	022208684-0003	11/18/2022	11/22/2022	.102 g	<0.020 % wt
PC-4	022208684-0004	11/18/2022	11/22/2022	.2605 g	<0.0080 % wt
PC-5	022208684-0005	11/18/2022	11/22/2022	.0509 g	<0.039 % wt
PC-6	022208684-0006	11/18/2022	11/22/2022	.0959 g	<0.021 % wt

James Cole, Laboratory Manager  
 or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

\* Analysis following Lead in Paint by EMSL SOP/Determination of Environmental Lead by FLAA. Reporting limit is 0.008% wt based on the minimum sample weight per our SOP. "<" (less than) result signifies the analyte was not detected at or above the reporting limit. Measurement of uncertainty is available upon request. Definitions of modifications are available upon request.

Samples analyzed by EMSL Analytical, Inc. Kernersville, NC AIHA LAP, LLC-ELLAP Accredited #102564

Initial report from 11/23/2022 08:44:19



8284

EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

Customer Information	Customer ID:	Billing ID:
	Company Name: ECS Southeast LLP	Company Name: ECS Southeast LLP
	Contact Name: Jenny Clark	Billing Contact: Jenny Clark
	Street Address: 1200 Woodruff Road Suite H-12	Street Address: 1200 Woodruff Road, Suite H-12
	City, State, Zip: Greenville SC 29607 Country: US	City, State, Zip: Greenville SC 29607 Country: US
	Phone: 4046409257	Phone: 4046409257
Email(s) for Report: jclark@ecslimited.com	Email(s) for Invoice:	

Project Information

Project Name/No: 18721

EMSL LIMS Project ID: (If applicable, EMSL will provide)

US State where samples collected: GA

State of Connecticut (CT) must select project location:  Commercial (Taxable)  Residential (Non-Taxable)

Purchase Order:

Sampled By Name: Jenny Clark

Sampled By Signature: *Jenny Clark*

Turn-Around-Time (TAT):  3 Hour  6 Hour  24 Hour  32 Hour  48 Hour  72 Hour  96 Hour  1 Week  2 Week

No of Samples In Shipment: 1

Please call ahead for large projects and/or turnaround times 6 Hours or Less. \*32 Hour TAT available for select tests only; samples must be submitted by 11:30am

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input checked="" type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm <sup>2</sup>	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input checked="" type="checkbox"/>
*Reporting Limit based on a minimum 0.25g sample weight	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
*If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCPLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
Unpreserved <input type="checkbox"/>	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Preserved with HNO <sub>3</sub> <input type="checkbox"/> PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
Drinking Water	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input type="checkbox"/>
Unpreserved <input type="checkbox"/>	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
Preserved with HNO <sub>3</sub> <input type="checkbox"/> PH<2				<input type="checkbox"/>
TSP/SPM Filter				<input type="checkbox"/>
Other:				<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
PC-1	PIPE	LIGHT BLUE	11/10/2022
PC-2	WALL	YELLOW	↓
PC-3	PIPE	RED	
PC-4	EQUIPMENT BASE	LIGHT BLUE	
PC-5	DOOR FRAME	BROWN	

Method of Shipment: drop-off

Sample Condition Upon Receipt: @EMSL #190515787194

Relinquished by: Jenny Clark

Date/Time: 11/10/2022 12:00pm

Received by: *NS*

Date/Time: 11/18/22 12:05 PM

Received by: *NS*

Date/Time: 11/21/22 9:00



### Lead Chain of Custody

EMSL Order Number / Lab Use Only

*8284*

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
PC-6	CAT EQUIPMENT	DARK YELLOW	11/18/2022

Method of Shipment: <i>drop-off</i>		Sample Condition Upon Receipt:	
Relinquished by: <i>Jimmy Clark</i>	Date/Time: <i>11/18/2022 12:02PM</i>	Received by:	Date/Time:
Relinquished by:	Date/Time:	Received by:	Date/Time:

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

# **Appendix IV: Certifications/ Licenses**

---

---

# ***The Environmental Institute***

---

---

## ***Jennifer Clark***

---

Social Security Number - XXX-XX-4341

ECS Souteast LLP - 1281 Kennestone Circle, Suite 200, Marietta, GA 30066

*Has completed 8 hours of coursework and satisfactorily  
passed an examination that meets all criteria required for  
EPA/AHERA/ASHARA (TSCA Title II) Approved Reaccreditation*

### ***Asbestos in Buildings: Inspector & Management Planner Refresher***

January 18, 2022

Course Date

18780

Certificate Number

January 18, 2022

Examination Date

January 17, 2023

Expiration Date



Darryl L. Watson

Darryl L. Watson - Principal Instructor

(Approved by the ABIH Certification Maintenance Committee for 1 CM point - Approval #11-583)  
(FL Provider Registration #FL49-0001342 - Inspector Ref. Course #0002805 - Mgmt. Plan Ref. Course #0002806)  
TEI - 1395 S. Marietta Parkway SE - Building 100, Suite 124- Marietta, GA 30067  
Phone: 770-427-3600 - Website: [www.tei-atl.com](http://www.tei-atl.com)

---

---

# **The Environmental Institute**

---

---

## *Jennifer Clark*

Social Security Number - XXX-XX-4341  
ECS Southeast LLP - 1281 Kenneston Circle, Suite 200 - Marietta, Georgia 30066

*Has completed 8 hours of coursework and satisfactorily passed the hands-on skills assessment and an examination that meets training criteria in accordance with requirements for Lead-Based Paint Activities in Target Housing and Child-Occupied Facilities as regulated by Georgia DNR/EPD Chapter 391-3-24 and U. S. EPA TSCA 40 CFR Part 745 for the refresher course titled*

## **Lead Inspector Refresher**

August 18, 2021

Course Date

1986

Certificate Number

August 18, 2021

Examination Date


August 17, 2023


Georgia Expiration Date

August 17, 2024

EPA Expiration Date



  
Bonnie B. Maurras - Principal Instructor


  
David W. Hogue - Training Manager

(Approved by the ABIH Certification Maintenance Committee for 1 CM point - Approval #11-584)

TEI - 1395 S. Marietta Parkway SE - Building 100, Suite 124 - Marietta, GA 30067

Phone: 770-427-3600 - Website: [www.tei-atl.com](http://www.tei-atl.com)

(State of Georgia Accredited - Certification No. 20-0799-006SR - September 21, 1999)



# FINISHED WATER PUMPING STATION

## FOR CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA

JOB NO. 91016-00  
 CONTRACT 2  
 MAY 3, 1991

### INDEX OF DRAWINGS

SHEET NO.	DRAWING NO.	DESCRIPTION	SHEET NO.	DRAWING NO.	DESCRIPTION
<b>ENVIRONMENTAL</b>					
1	91016-C2-01	COVER SHEET, LOCATION MAP AND INDEX OF DRAWINGS	14	91016-C2-S01	FOUNDATION PLAN
2	91016-C2-02	PROCESS FLOW AND INSTRUMENTATION	15	91016-C2-S02	ROOF FRAMING PLAN
3	91016-C2-03	SITE PLAN, OUTSIDE PIPING AND NOTES	16	91016-C2-S03	SECTIONS AND DETAILS
4	91016-C2-04	PUMP STATION, VALVE VAULT AND METER PIT-PLAN	17	91016-C2-S04	SECTIONS AND DETAILS
5	91016-C2-05	PUMP STATION - PARTIAL PLAN	18	91016-C2-S05	PITS-PLANS, SECTIONS AND DETAILS
6	91016-C2-06	SECTIONS	<b>MECHANICAL</b>		
7	91016-C2-07	SECTIONS	19	91016-C2-M01	MECHANICAL PLAN, SECTION, SCHEDULES AND NOTES
8	91016-C2-08	PUMP STATION - SECTIONS; VALVE VAULT AND METER PIT-PLANS	<b>ELECTRICAL</b>		
9	91016-C2-09	TYPICAL DETAILS	20	91016-C2-E01	LEGEND, ABBREVIATIONS, GENERAL NOTES AND GROUNDING LAYOUT
10	91016-C2-10	TYPICAL DETAILS	21	91016-C2-E02	LIGHTING AND RECEPTACLE LAYOUT AND DETAILS
11	91016-C2-A01	ARCHITECTURAL PLANS AND SECTIONS	22	91016-C2-E03	HEATING AND VENTILATION LAYOUT AND DIAGRAMS
12	91016-C2-A02	ELEVATIONS	23	91016-C2-E04	POWER LAYOUT AND DETAILS
13	91016-C2-A03	DOOR SCHEDULE; DOOR, WINDOW AND LOUVER DETAILS	24	91016-C2-E05	SINGLE LINE DIAGRAM
			25	91016-C2-E06	MOTOR CONTROL CENTER, WIRING DIAGRAMS AND DETAILS
			26	91016-C2-E07	LIGHTING FIXTURE SCHEDULE, LIGHTING PANELBOARD AND EXISTING FILTER BUILDING
			27	91016-C2-E08	TELEMETERING AND INSTRUMENTATION
			28	91016-C2-E09	ELECTRICAL DETAILS

**APPROVED**  
 STATE OF GEORGIA  
 WATER SUPPLY SECTION  
 AUG 29 1991  
 ENVIRONMENTAL PROTECTION DIVISION  
 By *Charles B. Addison*

**APPROVED FOR WATER SECTION ONLY**


**RECEIVED**  
 MAY 06 1991  
 DRINKING WATER PROGRAM

**RECEIVED**  
 MAY 07 1991  
 DRINKING WATER PROGRAM

*Handwritten signature*

**Robert and Company**  
 Architects - Engineers - Planners  
 96 Poplar Street, N.W. Atlanta, Georgia







# FINISHED WATER PUMPING STATION



FOR  
CLAYTON COUNTY  
WATER AUTHORITY  
MORROW, GEORGIA

JOB NO. 91016-00  
CONTRACT 2






1 SITE PLAN  
02 02  
1" = 20'-0"



PROVIDE TEMPORARY TRAFFIC BARRIERS AND SHORING AS REQUIRED

SYMBOL	DATE	BY	REVISION	DEPARTMENT
				ENVIRONMENTAL
FINISHED WATER PUMPING STATION FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				SITE PLAN CONSTRUCTION GRADING
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				SCALE: 1" = 20'-0" DWG. NO. 91016-C1-01A DATE 17 APR 1991
DESIGN: SDB	DRAWN: RB	CHECKED: KWS	SHEET 1 OF 1 SHEETS	

91016/03  
NOT Released For Construction



**LEGEND AND ABBREVIATIONS**


- |  |                                  |  |  |
|--|----------------------------------|--|--|
|  | FORWARD FLOW                     |  | MOTOR OPERATOR                           |
|  | SECONDARY FLOW                   |  | VENTURI FLOW METER                       |
|  | ELECTRICAL WIRING                |  | PANEL MOUNTED PUSHBUTTON                 |
|  | COUNTY LEASED PHONE LINES        |  | PANEL MOUNTED RUN LIGHT                  |
|  | FIELD MOUNTED AT PUMP STA.       |  | LEVEL TRANSMITTER                        |
|  | PANEL MOUNTED AT W.J. HOOPER WTP |  | SYSTEM PRESSURE TRANSMITTER              |
|  | MOTOR CONTROL CENTER             |  | FLOW TRANSMITTER                         |
|  | TONE EQUIPMENT                   |  | 3-PEN RECORDER-FLOW, PRESSURE TANK LEVEL |
|  | BUTTERFLY VALVE                  |  | FLOW TOTALIZER                           |
|  | CHECK VALVE                      |  | BACKFLOW PREVENTER                       |
|  | ALTITUDE VALVE (SINGLE ACTING)   |  | PRESSURE REDUCING VALVE                  |
|  | SURGE RELIEF VALVE               |  | GATE VALVE                               |
|  | PRESSURE GAUGE                   |  |  |

**INSTRUMENTATION GENERAL NOTES**


1. ALL ELECTRICAL WIRING SHOWN DASHED ON FLOW SCHEMATIC DRAWINGS SHALL BE FURNISHED AND INSTALLED BY THE CONTRACTOR. CONTRACTOR SHALL BE RESPONSIBLE FOR PROPER SIZE, TYPE, AND NUMBER OF CONDUCTORS BETWEEN ALL ITEMS OF INSTRUMENTATION INSTALLED.
2. SEE ELECTRICAL DRAWINGS FOR CONTROL WIRING LOCATION AND DETAILS.
3. RUN ALL WIRING IN PROPERLY SIZED STEEL CONDUITS.
4. ALL SHIELDED CABLES SHALL BE INSTALLED SEPARATELY IN STEEL CONDUIT. DO NOT INSTALL ANY OTHER CIRCUITS IN SAME CONDUIT WITH SHIELDED INSTRUMENTATION CIRCUITS.
5. SEE DETAIL DRAWINGS FOR EXACT LOCATION AND SIZE OF ALL PIPING, VALVES, AND EQUIPMENT.
6. SEE INSTRUMENTATION AND CONTROL SPECIFICATIONS FOR INSTRUMENT SCHEDULE AND DETAILS.
7. RECORDER, TOTALIZER, PUMP START-STOP PUSH BUTTONS AND RUN LIGHTS SHALL BE INSTALLED ON EXISTING PANEL AT W. J. HOOPER WTP, STOCKBRIDGE, GEORGIA. SEE ELECTRICAL DRAWING E7, DETAIL 1/E7 FOR LAYOUT.
8. TRANSMITTERS SHALL BE MOUNTED ON WALL OF NEW PUMPING STATION.

SYMBOL		DATE	BY	REVISION
<b>FINISHED WATER PUMPING STATION</b> DEPARTMENT: ENVIRONMENTAL PROCESS FLOW AND INSTRUMENTATION				SCALE: NONE
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				DWG. NO.: 91016-C2-02
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				DATE: MAY 3, 1991
DESIGN: K.M.B.	DRAWN: F.G.H.	CHECKED:	SHEET 2 OF SHEETS	

NOT Released For Construction 91016/02




1 SITE PLAN  
02 | 02  
1" = 20'-0"



SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ENVIRONMENTAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			SITE PLAN CONSTRUCTION GRADING
Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			SCALE: 1" = 20'-0"
DESIGN:	DRAWN:	CHECKED:	DWG. NO. 91016-C2-03
			DATE MAY 3, 1991
			SHEET 3 OF 28 SHEETS

NOT Released For Construction 91016/03



**GENERAL NOTES**

1. TWO - 2.7 MG PRESTRESSED CONCRETE STORAGE TANKS UNDER CONSTRUCTION UNDER SEPARATE CONTRACT. CONTRACTOR SHALL COORDINATE ALL PUMP STATION WORK WITH TANK CONTRACTOR (THE CROM CORPORATION). CONTRACTOR SHALL WORK WITH TANK CONTRACTOR CONCERNING SITE STORAGE AND ACCESS, CONSTRUCTION SCHEDULING AND CLEARANCE FOR EQUIPMENT DURING CONSTRUCTION.
2. 24" D.I. PIPE TO ALTITUDE VALVE VAULT WILL BE FURNISHED AND INSTALLED BY OWNER. CONTRACTOR SHALL COORDINATE WITH OWNER TO CONNECT 24" D.I. TO P.E. WALL PIPE AT VALVE VAULT. ANY NECESSARY ADJUSTMENT OR REALIGNMENT SHALL BE MADE BY CONTRACTOR.
3. CONTRACT WILL END AT 24" X 30" INCREASER. CONTRACTOR SHALL BLOCK OFF OR PLUG OPENING OF REDUCER UNTIL 30" D.I. LINE IS INSTALLED BY OWNER AND CONNECTION TO METER PIT IS MADE.
4. PUMP STATION CONTRACTOR SHALL FINISH GRADE AND GRASS ENTIRE SITE. BACKFILL AROUND TANKS TO GRADE SHOWN AFTER TANK CONTRACTOR HAS COMPLETED ALL WORK. DISPOSE OF EXCESS MATERIAL AT NORTH END OF SITE. GRADE TO DRAIN AND GRASS ENTIRE SITE. PUMP STATION CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DAMAGE TO TANKS DURING EARTH WORK OPERATIONS.
5. PUMP STATION CONTRACTOR SHALL MAKE CONNECTIONS TO TANK (24" TANK FILL LINE; 24" PUMP SUCTION HEADER; 12" TANK DRAIN LINE) COORDINATE WORK WITH TANK CONTRACTOR. NO CONNECTION SHALL BE MADE TO TANK UNTIL TANK IS FILLED, INSPECTED AND APPROVED BY ENGINEER, OWNER AND GEOTECHNICAL ENGINEER.
6. INSTALL HAY BALES AND SILT FENCE PRIOR TO START OF CONSTRUCTION AS REQUIRED BY REGULATING AGENCIES FOR SILTATION CONTROL. MAINTAIN FENCE THROUGHOUT CONSTRUCTION.


1 SITE PLAN  
03/03 1" = 20'-0"



**APPROVED**  
STATE OF GEORGIA  
WATER SUPPLY SECTION  
AUG 29 1991  
ENVIRONMENTAL PROTECTION DIVISION  
By *Charles B. Adkinson*  
**APPROVED FOR WATER SECTION ONLY**

SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119		DEPARTMENT ENVIRONMENTAL SITE PLAN OUTSIDE PIPING AND NOTES SCALE: 1" = 20'-0" DWG. NO. 91016-C2-03 DATE MAY 3, 1991	
DESIGN: RLW/SDB	DRAWN: RLW/SDB	CHECKED: <i>RLW</i>	SHEET 3 OF 28 SHEETS

NOT Released For Construction 91016/03



CO-ORDINATE PIPING CONNECTIONS W/  
TANK CONTRACTOR. CONNECTIONS SHALL  
NOT BE MADE UNTIL AFTER TANK IS  
FILLED AND APPROVED BY ENGINEER  
AND TESTING LABORATORY.

CO-ORDINATE PIPING CONNECTIONS W/  
TANK CONTRACTOR. CONNECTIONS SHALL  
NOT BE MADE UNTIL AFTER TANK IS  
FILLED AND APPROVED BY ENGINEER  
AND TESTING LABORATORY.

6'-0" x 5'-0"  
BOTTOM EL 925.00  
FILL W/ GRAVEL  
LINE BOTTOM, SIDES,  
& TOP W/ FILTER  
FABRIC

ALTITUDE  
VALVE  
VAULT  
(SEE SHEET 08)

STORAGE


ELECTRICAL

SOUTH  
STORAGE  
TANK

NORTH  
STORAGE  
TANK


ASPHALT DRIVE

METERING  
PIT  
(SEE SHEET 08)




SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ENVIRONMENTAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			GENERAL FLOOR PLAN
Robert and Company Architects-Engineers-Planners 98 Poplar Street, N.W. Atlanta, Georgia 30335 404-577-4000 FAX: 404-577-7119			SCALE: AS SHOWN
DATE: MAY 3, 1991			DWG. NO. 91016-C2-04
DESIGN:	DRAWN:	CHECKED:	SHEET 4 OF SHEETS

NOT Released For Construction 91016/04




1 PLAN  
04 05 3/8" = 1'-0"



SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			
DESIGN:	DRAWN:	CHECKED:	
			DEPARTMENT ENVIRONMENTAL
			PARTIAL PLAN
			SCALE: AS SHOWN
			DWG. NO. 91016-C2-05
			DATE MAY 3, 1991
			SHEET 5 OF SHEETS

91016/05 NOT Released For Construction



**A SECTION**  
08 | 06  
3/8" = 1'-0"

**B SECTION**  
04 | 06  
05  
3/8" = 1'-0"


**C SECTION**  
08 | 06  
3/8" = 1'-0"

SYMBOL		DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION					ENVIRONMENTAL
FOR:		CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			SECTIONS
		SCALE: AS SHOWN			DWG. NO. 91016-C2-06
DESIGN:		DRAWN:			DATE MAY 3, 1991
		CHECKED:			SHEET 6 OF SHEETS

**Robert and Company**  
Architects-Engineers-Planners  
96 Poplar Street, N.W. Atlanta, Georgia 30335  
404 577-4000 FAX: 404 577-7119

NOT Released For Construction 91016/06






**A** SECTION  
 05 07 3/8" = 1'-0"

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				ENVIRONMENTAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				SECTIONS
<b>Robert and Company</b> Architects-Engineers-Planners 96 Foglar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				SCALE: AS SHOWN
DWG. NO. 91016-C2-07				DATE MAY 3, 1991
DESIGN:	DRAWN:	CHECKED:	SHEET 7 OF SHEETS	

NOT Released For Construction 91016/07


CORE DRILL MASONRY WALL TO ACCOMMODATE 10" STEEL WALL PIPE W/ SPIDER GUIDE FOR 6" SCH 40 BLACK STEEL EXHAUST PIPE




**A** SECTION  
05 08 3/8" = 1'-0"

**GENERAL NOTES :**

1. INSULATE ENGINE EXHAUST SYSTEM FROM FLEXIBLE CONNECTOR TO BUILDING WALL (INCLUDING MUFFLER ) WITH 3" OF CALCIUM SILICATE. BAND IN PLACE WITH STAINLESS STEEL BANDS ON 9" CENTERS. COVER INSULATION WITH 0.016" ALUMINUM JACKET BANDED WITH 3/8" X 0.2" ALUMINUM BANDS.
2. PROVIDE SUCTION AND DISCHARGE GAUGES WITH GAUGE COCK ON EACH PUMP. EACH GAUGE SHALL BE ASHCROFT MODEL NO 4 1/2 - 1009-A OR EQUAL. GAUGES SHALL HAVE POLISHED STAINLESS STEEL CASES. SUCTION GAUGE SHALL BE 0-50 PSI; DISCHARGE GAUGE SHALL BE 0-150 PSI.
3. WATER PIPING AND VALVES FROM PUMP TO ENGINE SHALL BE FACTORY PRE-PIPED. SEE MECHANICAL DWG SHEET 19 FOR NATURAL GAS SUPPLY PIPING TO ENGINE.



**1** ALTITUDE VALVE VAULT  
04 08 3/8" = 1'-0"



**2** METER PIT  
04 08 3/8" = 1'-0"


**APPROVED**  
STATE OF GEORGIA  
WATER SUPPLY SECTION  
AUG 29 1991  
ENVIRONMENTAL PROTECTION DIVISION  
By *Charles B. Adkins*

**APPROVED FOR WATER SECTION ONLY**


SYMBOL	DATE	BY	REVISION	DEPARTMENT
				ENVIRONMENTAL
				PUMP STATION - SECTION; VALVE VAULT, METER PIT PLANS
FOR:				CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA
				SCALE: AS SHOWN
				DWG. NO. 91016-C2-08
				DATE: MAY 3, 1991
DESIGN: <i>[Signature]</i>	DRAWN: <i>[Signature]</i>	CHECKED: <i>[Signature]</i>		SHEET 8 OF 28 SHEETS

NOT Released For Construction 91016C08


CORE DRILL MASONRY WALL TO ACCOMMODATE 10" STEEL WALL PIPE W/ SPIDER GUIDE FOR 6" SCH 40 BLACK STEEL EXHAUST PIPE



**A SECTION**  
05 | 08 3/8" = 1'-0"




**1 ALTITUDE VALVE VAULT**  
04 | 08 3/8" = 1'-0"




**2 METER PIT**  
04 | 08 3/8" = 1'-0"

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				ENVIRONMENTAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				PLANS AND SECTION
Robert and Company Architects-Engineers-Planners 36 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			SCALE: AS SHOWN	DWG. NO. 91016-C2-08
DESIGN:	DRAWN:	CHECKED:	DATE: MAY 3, 1991	SHEET 8 OF SHEETS


NOT Released For Construction 91016/08




PLAN



PLAN




PLAN




SECTION A

THRUST BLOCKING—BENDS



SECTION B

THRUST BLOCKING—TEES




SECTION C


THRUST BLOCKING—PLUGS

PIPE SIZE	90° BEND				45° BEND				22½° BEND				11¼° BEND				TEE OR PLUG				
	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	
36"	3'-0"	10'-6"	10'-4"	6'-6"	2'-0"	7'-8"	7'-8"	5'-0"	3'-7"	5'-0"	6'-0"	2'-9"	3'-7"	4'-0"	3'-9"	2'-6"	3'-0"	8'-9"	8'-9"	5'-0"	
30"	2'-9"	9'-0"	9'-3"	5'-9"	1'-6"	6'-9"	6'-9"	3'-9"	1'-10"	4'-9"	5'-0"	2'-6"	1'-11"	3'-6"	3'-6"	2'-6"	2'-9"	7'-6"	7'-9"	4'-9"	
24"	2'-7"	7'-3"	7'-3"	4'-6"	1'-3"	5'-3"	5'-6"	3'-3"	1'-8"	3'-9"	4'-0"	2'-0"	1'-9"	2'-9"	2'-9"	2'-3"	2'-6"	6'-0"	6'-3"	3'-9"	
20"	2'-1"	6'-0"	6'-3"	3'-9"	1'-0"	4'-6"	4'-6"	2'-6"	1'-5"	3'-3"	3'-3"	1'-6"	1'-6"	2'-3"	2'-6"	2'-0"	2'-4"	5'-0"	5'-3"	3'-3"	
18"	1'-11"	5'-6"	5'-6"	3'-6"	1'-0"	4'-0"	4'-3"	2'-6"	1'-3"	2'-9"	3'-0"	1'-6"	1'-4"	2'-0"	2'-3"	1'-9"	1'-2"	4'-6"	4'-9"	3'-0"	
16"	1'-9"	5'-0"	5'-0"	3'-3"	0'-11"	3'-6"	3'-9"	2'-3"	1'-2"	2'-6"	2'-9"	1'-3"	1'-3"	1'-9"	2'-0"	1'-6"	1'-6"	4'-0"	4'-6"	3'-0"	
14"	1'-7"	4'-3"	4'-3"	2'-8"	0'-10"	3'-0"	2'-6"	2'-0"	1'-1"	2'-3"	2'-6"	1'-3"	1'-2"	1'-6"	1'-9"	1'-3"	1'-6"	3'-6"	3'-9"	2'-6"	
12"	1'-4"	3'-6"	3'-9"	2'-6"	0'-10"	2'-6"	3'-0"	2'-0"	1'-1"	2'-0"	2'-0"	1'-0"	1'-2"	1'-6"	1'-6"	1'-3"	1'-3"	3'-0"	3'-3"	2'-3"	


- NOTES:
- THRUST BLOCKING TO BE 4000 PSI CONCRETE.
  - DIMENSIONS CALCULATED USING A SOIL LOAD BEARING CAPACITY OF 2000 PSF. IF SOIL BEARING CAPACITY IS FOUND TO BE LESS THAN 2000 PSF, THE ENGINEER CAN INCREASE THESE DIMENSIONS.
  - THRUST BLOCKING SHALL BEAR AGAINST UNDISTURBED SOIL.
  - CONTRACTOR SHALL BE RESPONSIBLE FOR POSITIVE BLOCKING OF ALL PRESSURE LINES AS REQUIRED BY ACTUAL CONDITIONS. ABOVE REQUIREMENTS ARE MINIMUM.
  - ALL BLOCKING SHALL BE FURNISHED AS REQUIRED AT NO ADDITIONAL COST TO THE OWNER.



YARD CLEAN-OUT DETAIL  
N.T.S.




TYPICAL GUARD POST DETAIL  
SCALE: 1/2"=1'-0"




VALVE BOX DETAIL  
N.T.S.

NOTE  
NUMBER, SIZE, PROJECTION, AND SPACING OF BOLTS SHALL BE AS INDICATED ON EQUIPMENT SHOP DRAWINGS APPROVED BY ENGINEERS.




TYPICAL ANCHOR BOLT DETAIL  
N.T.S.

NOTE  
ALL WALKWAYS SHALL HAVE EXPANSION JOINTS SPACED 30'-0" O.C. (MAX.) AND CONTRACTION JOINTS SPACED 6'-0" O.C. (MAX.).




CONCRETE WALKWAY DETAIL  
SCALE: 1"=1'-0"




TYPICAL PAVING DETAIL  
N.T.S.

SYMBOL	DATE	BY	REVISION
			DEPARTMENT ENVIRONMENTAL
			DETAILS AND SECTIONS
FOR: FINISHED WATER PUMPING STATION			SCALE: AS SHOWN
CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			DWG. NO. 91016-C2-09
Robert and Company Architects - Engineers - Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335			DATE:
DESIGN:	DRAWN:	CHECKED:	SHEET 9 OF 28 SHEETS


NOT Released for Construction




PLAN




SECTION A



PLAN




TYP. CONCRETE  
PIPING SUPPORT  
N.T.S.




TYPICAL GRATING DETAILS  
N.T.S.

NOTE  
OPENINGS IN GRATING SHALL BE SHOP CUT AND BANDED. NO FIELD CUTTING WILL BE ALLOWED.


4'-0" x 4'-0" SINGLE LEAF, WATERTIGHT ALUM. HATCH WITH SPRING LIFT HATCH SHALL BE BILCO TYPE "J" OR APPROVED EQUAL.



PIT ACCESS HATCH SECTION B  
N.T.S.



RUNG FASTENING DETAIL  
SCALE: 3" = 1'-0"




ALUMINUM ACCESS LADDER  
N.T.S.

SYMBOL DATE BY REVISION



FINISHED WATER PUMPING STATION		DEPARTMENT ENVIRONMENTAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA		DETAILS AND SECTIONS
SCALE: AS SHOWN		DWG. NO. 91016-C2-10
DATE:		DATE:
DESIGN:	DRAWN:	CHECKED:
SHEET 10 OF 28 SHEETS		

Robert and Company  
Architects - Engineers - Planners  
96 Poplar Street, N.W. Atlanta, Georgia 30335



NOT Released For Construction



**1 ROOF PLAN**  
 A01/A01 3/16" = 1'-0"



**2 FLOOR PLAN**  
 A01/A01 3/16" = 1'-0"




**A TYPICAL WALL SECTION**  
 A01/A01 3/4" = 1'-0"


**B TYP WINDOW SECTION**  
 A01/A01 3/4" = 1'-0"

SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ENVIRONMENTAL
CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			PLANS AND SECTIONS
Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			DWG. NO. 91016-C2-A01
DESIGN:	DRAWN:	CHECKED:	DATE MAY 3, 1991
SHEET // OF SHEETS			SCALE: AS SHOWN


NOT Released For Construction



1 WEST ELEVATION  
 A02 | A02 3/16" = 1'-0"



2 NORTH ELEVATION  
 A02 | A02 3/16" = 1'-0"





3 EAST ELEVATION  
 A02 | A02 3/16" = 1'-0"

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				ENVIRONMENTAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				ELEVATIONS AND DETAILS
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				SCALE: AS SHOWN
DWC. NO. 91016-C2-A02				DATE MAY 3, 1991
DESIGN:	DRAWN:	CHECKED:	SHEET 12 OF SHEETS	

NOT Released For Construction

# DOOR SCHEDULE


DOOR NO.	DOOR DATA				FRAME DATA						REMARKS	
	SIZE	MATL.	TYPE	GLASS	MATL.	TYPE	HEAD	JAMB	SILL	LABEL		HDWE. SET
101	PR 2'-6"x9'-0"x1 3/4"	H.M.	A	WIRE	H.M.	A	3/A03	4/A03	5/A03	NONE	0	COILING ROLL-UP
102	12'-0"x11'-4"	STL	OH	NONE	MC	-	1/A03	2/A03	N/A	NONE	0	
103	3'-0"x7'-0"x1 3/4"	H.M.	A	WIRE	H.M.	A	3/A03	4/A03	5/A03	NONE	0	
104	3'-0"x7'-0"x1 3/4"	H.M.	A	WIRE	H.M.	A	3/A03	4/A03	5/A03	NONE	0	
105	3'-0"x7'-0"x1 3/4"	H.M.	A	WIRE	H.M.	A	3/A03	4/A03	5/A03	NONE	0	




**9 CONTROL JOINT DTL**  
A02/A03 N.T.S.

## DOOR AND FRAME ELEVATIONS


NO SCALE




**1 ROLL-UP HEAD DETAIL**  
A03/A03 1 1/2" = 1'-0"




**3 DOOR HEAD DETAIL**  
A03/A03 SCALE : 1 1/2" = 1'-0"




**4 DOOR JAMB DETAIL**  
A03/A03 SCALE : 1 1/2" = 1'-0"




**2 ROLL-UP JAMB DETAIL**  
A03/A03 1 1/2" = 1'-0"




**5 DOOR SILL DETAIL**  
A03/A03 SCALE : 1 1/2" = 1'-0"




**6 WINDOW HEAD DETAIL**  
A01/A03 N.T.S.



**7 WINDOW JAMB DETAIL**  
A01/A03 N.T.S.




**8 WINDOW SILL DETAIL**  
A01/A03 N.T.S.




**10 LOUVER DETAILS**  
A01/A03 N.T.S.

FINISHED WATER PUMPING STATION CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA	DEPARTMENT ENVIRONMENTAL DOOR SCHEDULE DOOR, WINDOW & LOUVER DETAILS SCALE: FULL DWG. NO. 91016-C2-A03 DATE 16 APR 91
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119	NOT RELEASED FOR CONSTRUCTION







- NOTES:**
1. THE STRUCTURE IS STABLE ONLY IN ITS COMPLETED STATE. TEMPORARY SUPPORTS, SUCH AS TEMPORARY GUYS, BRACES, FALSEWORK, CRIBBING OR OTHER ELEMENTS REQUIRED TO STABILIZE THE STRUCTURE DURING ERECTION UNDER ALL LOADING CONDITIONS SHALL BE DESIGNED, FURNISHED AND INSTALLED BY CONTRACTOR.
  2. THE STRUCTURE IS DESIGNED IN ACCORDANCE WITH THE 1988 STANDARD BUILDING CODE.
  3. DESIGN LOADS ARE AS FOLLOWS:  
ROOF LOADS:  
DEAD LOAD = STRUCTURE WEIGHT  
LIVE LOAD = 20 PSF
  4. UNLESS NOTED OTHERWISE, MINIMUM CONCRETE COVER FOR REINFORCEMENT SHALL BE AS FOLLOWS:  
CONCRETE CAST AGAINST EARTH ----- 3"  
FORMED CONCRETE EXPOSED TO EARTH OR WEATHER ----- 1 1/2"  
INTERIOR SLABS, WALLS ----- 3/4"
  5. UNLESS NOTED OTHERWISE LONGITUDINAL REINFORCING IN FOOTINGS SHALL BE PLACED CONTINUOUS AT CORNERS AND INTERSECTIONS.
  6. UNLESS NOTED OTHERWISE, CONCRETE SLAB ON GRADE SHALL BE 6" THICK, REINFORCED WITH 6 x 6 - W 2.9 x W 2.9 WELDED WIRE FABRIC, CAST ON COMPACTED SUBGRADE APPROVED BY A QUALIFIED SOILS ENGINEER. MAXIMUM OUTSIDE DIAMETER OF CONDUIT PLACED IN SLAB ON GRADE SHALL NOT EXCEED 1/4 OF THE SLAB THICKNESS. ALL CONDUITS SHALL BE CENTERED IN THE SLAB.
  7. WELDING OR TACK WELDING OF REINFORCING STEEL SHALL NOT PERMITTED EXCEPT AS AUTHORIZED OR DIRECTED BY STRUCTURAL ENGINEER OR HIS REPRESENTATIVE.
  8. FOUNDATIONS ARE DESIGNED FOR AN ALLOWABLE SOIL BEARING CAPACITY OF 3.0 KSF, TO BE VERIFIED BY A QUALIFIED SOILS ENGINEER BEFORE PLACING CONCRETE (SEE SOIL REPORT).
  9. MASONRY WALLS MUST BE BRACED DURING ERECTION FOR WIND AND CONSTRUCTION LOADS. BRACES MUST BE DESIGNED, CONSTRUCTED AND ERECTED IN A FASHION AS TO PREVENT PERMANENT SCARRING OF MASONRY SURFACES AT EXPOSED CONDITIONS.



1 FOUNDATION PLAN  
SCALE: 1/4" = 1'-0"

2 TYPICAL SLAB ON GRADE JOINT DETAILS  
NOT TO SCALE





3 TYPICAL SLAB ON GRADE DETAIL FOR PARTITION WALLS  
NOT TO SCALE

5 TYPICAL STEPPED FOOTING DETAIL  
NOT TO SCALE



3 TYPICAL WALL DETAILS  
NOT TO SCALE

SYMBOL	DATE	BY	REVISION	DEPARTMENT
				STRUCTURAL
FOR:	FINISHED WATER PUMPING STATION			FOUNDATION PLAN
	CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			SCALE: AS SHOWN
	Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			DWG. NO. 91016-C2-S01
DESIGN:	A.O.	DRAWN:	F.K.	CHECKED: A.O.
				DATE MAY 3, 1991
				SHEET 14 OF SHEETS

NOT Released For Construction



**1** ROOF FRAMING PLAN  
SCALE: 1/4" = 1'-0"



**2** CRANE SUPPORT FRAMING PLAN  
SCALE: 1/8" = 1'-0"




**NOTES.**


1. ROOF LIVE LOAD = 20 PSF
2. 8" PRECAST ROOF SLABS  
(SEE SPECIFICATION SECTION 03431).
3. PROVIDE OPENING AND NECESSARY DETAILS  
FOR AN EQUIPMENT WEIGHING 750 lbs.  
FOR EXACT SIZE AND LOCATION SEE APPROVED  
EQUIPMENT SHOP DRAWINGS.

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				STRUCTURAL
FOR:	CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			ROOF FRAMING PLAN
Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			DWG. NO.	91016-C2-S02
DESIGN:	A.O.	DRAWN:	F.K.	CHECKED:
			DATE	MAY 3, 1991
			SHEET	1 OF 5 SHEETS


NOT Released For Construction




**A SECTION**  
S01/S03  
SCALE: 3/4" = 1'-0"




**1 DETAIL**  
S01/S03  
SCALE: 1" = 1'-0"




**2 TYPICAL MASONRY WALL ANCHOR DETAIL AT COLUMN**  
S03/S03  
SCALE: 3/4" = 1'-0"



**B SECTION**  
S03/S03  
SCALE: 1" = 1'-0"




**3 TYPICAL PLAN DETAIL OF WALL REINFORCING AT OPENING**  
S03/S03  
SCALE: 3/4" = 1'-0"




AT 7'-0" WIDE AND SMALLER OPENINGS  
AT 12'-0" WIDE OPENING

**4 TYPICAL LINTEL DETAILS AT WALLS**  
S03/S03  
SCALE: 3/4" = 1'-0"




**C SECTION**  
S01/S03  
SCALE: 1/2" = 1'-0"




**D SECTION**  
S01/S03  
SCALE: 1/2" = 1'-0"

SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT STRUCTURAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			SECTIONS AND DETAILS
Robert and Company Architects-Engineers-Planners 98 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119			SCALE: AS SHOWN
DWR. NO. 91016-C2-S03			DATE: MAY 3, 1991
DESIGN: A.O.	DRAWN: F.K.	CHECKED: A.O.	SHEET 1 OF SHEETS


NOT Released For Construction



**A SECTION**  
 S02 | S04 SCALE: 3/4" = 1'- 0"




**B SECTION**  
 S02 | S04 SCALE: 3/4" = 1'- 0"




NOTE: SEE SECTION A ON THIS DWG. FOR ITEMS SHOWN AND NOT CALLED OUT.

**C SECTION**  
 S02 | S04 SCALE: 3/4" = 1'- 0"




**1 DETAIL**  
 S04 | S04 SCALE: 1 1/2" = 1'- 0"

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				STRUCTURAL
FOR:	CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			SECTIONS AND DETAILS
Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				SCALE: AS SHOWN
DESIGN:	DRAWN:	CHECKED:	DWG. NO.	DATE
A.O.	F.K.	A.O.	91016-C2-S04	MAY 3, 1991
SHEET 17 OF SHEETS				NOT Released For Construction




TOP OF SLAB ELEVATION 930.50'

**1**  
PLAN AT BOTTOM SLAB -  
ALTITUDE VALVE VAULT  
SCALE: 1/4" = 1'-0"




TOP OF SLAB ELEVATION 930.50'

**2**  
TOP SLAB REINFORCING PLAN -  
ALTITUDE VALVE VAULT  
SCALE: 1/4" = 1'-0"




**A**  
SECTION  
SCALE: 1/2" = 1'-0"



TOP OF SLAB ELEVATION 935.75'

**3**  
PLAN AT BOTTOM SLAB -  
METER PIT  
SCALE: 1/4" = 1'-0"



TOP OF SLAB ELEVATION 930.50'


**4**  
TOP SLAB REINFORCING PLAN -  
METER PIT  
SCALE: 1/4" = 1'-0"

**NOTES.**


- BACKFILL SIMULTANEOUSLY AROUND PITWALLS.

SYMBOL	DATE	BY	REVISION	DEPARTMENT
				STRUCTURAL
FINISHED WATER PUMPING STATION				ALL PITS - PLANS, SECTIONS AND DETAILS
FOR:	CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			SCALE: AS SHOWN
<b>Robert and Company</b> Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				DWG. NO. 91016-C2-S05
DESIGN: A.O.	DRAWN: F.K.	CHECKED: A.O.	DATE: MAY 3, 1991	SHEET 18 OF SHEETS

NOT Released For Construction



1 PUMP HOUSE - PLAN  
3/16" = 1'-0"



A PUMP HOUSE - SECTION  
3/16" = 1'-0"

MARK	CFM	ELECTRICAL		HEAT	BASIS OF DESIGN	LOCATION
		KW	V/Ø/HZ	MBH		
H-1	670	7.5	480/3/60	25.6	CHROMALOX LUH-07-43	WALL MTD.
H-2	670	7.5	480/3/60	25.6	CHROMALOX LUH-07-43	WALL MTD.
H-3	670	7.5	480/3/60	25.6	CHROMALOX LUH-07-43	WALL MTD.
H-4	310	2.6	208/1/60	8.9	CHROMALOX LUH-02-81	WALL MTD.
H-5	420	5	480/3/60	17.1	CHROMALOX LUH-05-43	WALL MTD.

NOTES: HEATER FANS SHALL HAVE "BUILT-IN" THERMOSTATS

MARK	TYPE	CFM	EXT. S.P. IN. W.G.	DRIVE	MOTOR		REMARKS	BASIS OF DESIGN
					H.P.	V/Ø/HZ		
EF-1	GREENHECK GB-330H	12250	.25	BELT	3	460/3/60	ROOF MTD.	GREENHECK GB-330H
EF-2	GREENHECK GB-330H	12250	.25	BELT	3	460/3/60	ROOF MTD.	GREENHECK GB-330H

PROVIDE BIRDSCREEN, GRAVITY BACKDRAFT DAMPER, BALANCING DAMPER, AND EXHAUST GRILLE ON INTAKE WITH FANS.

GENERAL NOTES

- I. MATERIALS
  - A. HEATERS
    - 1. HEATERS SHALL HAVE A 480 VOLT HEATER AND A 480 VOLT FAN MOTOR. HEATER H-1 SHALL HAVE BUILT IN CONTACTORS, CONTROL POWER TRANSFORMER, RELAYS, THERMOSTAT, AND DISCONNECT SWITCH MADE BY MANUFACTURER OF HEATER.
  - B. LOUVERS AND DAMPERS
    - 1. 88 X 96 LOUVER SHALL BE MADE OF EXTRUDED ALUMINUM AND BE PROVIDED WITH BIRDSCREEN
    - 2. PROVIDE MOTOR ACTUATED 44 X 96 DAMPERS BEHIND 88 X 96 LOUVER RUSKIN MODEL #CD35
    - 3. LOUVER SHALL PREVENT WATER PENETRATION AT FACE VELOCITY LESS THAN 900 FEET PER MINUTE. RUSKIN MODEL #ELF6375D OR APPROVED EQUAL
  - C. EXHAUST FAN
    - 1. PROVIDE EXHAUST FAN WITH BIRDSCREEN, BACKDRAFT DAMPER
    - 2. EXHAUST FAN SHALL BE OF THE DOWNBLAST ROOF MOUNTED CENTRIFUGAL BELT DRIVEN TYPE. THE FAN WHEELS SHALL BE BACKWARD INCLINED CENTRIFUGAL TYPE. WHEELS SHALL BE STATICALLY AND DYNAMICALLY BALANCED TO ASSURE MINIMAL NOISE AND VIBRATION ISOLATION.
    - 3. PROVIDE ALL NECESSARY RELAYS AND SWITCHES TO ALLOW FAN OPERATION. PROVIDE CONTROL POWER AND TRANSFORMER AND DISCONNECT SWITCH FOR EACH FAN
  - D. HOSE BIBB
    - 1. PROVIDE HOSE BIBB BLD'G W/ NON-REMOVABLE VACUUM BREAKER, WOODFORD MODEL 25CP3-3/4 OR APPROVED EQUAL
    - 1. PROVIDE FREEZE PROOF HOSE BIBB OUTSIDE BLD'G W/ NON-REMOVABLE VACUUM BREAKER, WOODFORD MODEL 24CP3-3/4 OR APPROVED EQUAL
  - E. BACKFLOW PREVENTER
    - 1. PROVIDE WATTS TYPE 709 BACKFLOW PREVENTER OR APPROVED EQUAL
  - F. PRESSURE GAUGE
    - 1. PROVIDE PRESSURE GAUGE WITH GAUGE COCK AND A RANGE FROM 0-150 PSIG, ASHCROFT MODEL #4 1/2-1009-A
  - G. PRESSURE REDUCING VALVE
    - 1. PROVIDE PRESSURE REDUCING VALVE WATTS #U5 OR APPROVED EQUAL
- II. INSTALLATION
  - A. HOSE BIBBS
    - 1. INSTALL OUTSIDE HOSE BIBB 24" ABOVE GRADE. INSTALL INSIDE HOSE BIBB 24" A.F.F.
  - B. HEATER
    - 1. INSTALL HEATERS NO LESS THAN 7'-0" A.F.F. INSTALL HEATERS SUCH THAT AIR FLOW TO EXHAUST FANS IS NOT OBSTRUCTED, AND AIR FLOW TO THE HEATER IS NOT OBSTRUCTED BY SUPPORT BEAM.
  - C. THERMOSTATS
    - 1. INSTALL EXHAUST FAN CONTROLLING THERMOSTATS 5'-0" A.F.F.
    - 2. LOCATION OF THERMOSTAT ON DRAWING IS APPROXIMATE AND MAY BE MOVED 2'-0" IN THE HORIZONTAL DIRECTION TO COORDINATE WITH OTHER DISCIPLINES EQUIPMENT, LIGHT SWITCHES, ETC...
    - 3. PROVIDE SEPERATE THERMOSTATS FOR EXHAUST FANS
    - 4. HEATERS SHALL HAVE FACTORY INSTALLED THERMOSTATS MOUNTED ON EQUIPMENT
  - D. EXHAUST FAN
    - 1. MOUNT EXHAUST FAN ON ROOF. PROVIDE ROOF CURB, FLASH AND COUNTERFLASH TO PREVENT WATER PENETRATION THROUGH ROOF OPENING
  - E. LOUVERS
    - 1. MOUNT BOTTOM OF 88x96" LOUVER APPROX. 24" ABOVE GRADE
- III. OPERATION
  - A. EXHAUST FAN
    - 1. THERMOSTAT FOR EF-1 WILL SIGNAL LEFT DAMPER TO OPEN AND ENERGIZE EF-1 AT A READING OF 80°F OR GREATER
    - 2. THERMOSTAT FOR EF-2 WILL SIGNAL RIGHT DAMPER TO OPEN AND ENERGIZE EF-2 AT A READING OF 85°F OR GREATER
  - B. HEATER
    - 1. HEATER SHALL BE CONTROLLED BY AN EXTERNAL THERMOSTAT. THERMOSTAT SHALL HAVE A RANGE OF SETTINGS, BUT SHALL BE SET AT 55°F.
  - C. LOUVERS AND DAMPERS
    - 1. LEFT 44" X 96" MOTORIZED DAMPER WILL ENERGIZE TO FULLY OPEN WHEN EXHAUST FAN EF-1 IS ENGAGED. RIGHT 44 X 96 MOTORIZED DAMPER WILL ENERGIZE TO FULLY OPEN WHEN EXHAUST FAN EF-2 IS ENGAGED

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				MECHANICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				MECHANICAL PLAN
SCALE: AS SHOWN				DWG. NO. 91016-C2-M1
<b>Robert and Company</b> Architects-Engineers-Planners 96 Foster Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 577-7119				DATE: MAY 3, 1991
DESIGN: ABL	DRAWN: MAK	CHECKED: THS	SHEET 19 OF SHEETS	

NOT Released For Construction

**ABBREVIATIONS**

-A-			
A	AMPERES		
AFF	ABOVE FINISHED FLOOR		
-B-			
BKR	BREAKER	-N-	NATIONAL ELECTRICAL CODE
BLDG	BUILDING	NEC	NATIONAL ELECTRICAL
		NEMA	MANUFACTURE'S ASSOCIATION
		NTS	NOT TO SCALE
-C-			
CAT	CATALOG	-O-	
CAP	CAPACITOR	OL	OVERLOAD
CKT	CIRCUIT		
CB	CIRCUIT BREAKER	-P-	
CO	COMPANY	P	POLE
CPT	CONTROL POWER TRANSFORMER	PH OR Ø	PHASE
CT	CURRENT TRANSFORMER	PL	PILOT LIGHT OR PLATE
		PE	PNEUMATIC ELECTRIC OR
			PHOTO-ELECTRIC
		PVC	POLYVINYLCHLORIDE
-D-			
DN	DOWN		
DWG	DRAWING	-R-	
DM	DAMPER MOTOR	RVAT	REDUCED VOLTAGE
			AUTO TRANSFORMER
-E-			
EA	EACH		
ELECT	ELECTRICAL	-S-	
ENG	ENGINE	SCH	SCHEDULE
		SEC	SECONDARY
		SW	SWITCH
-F-			
FLEX	FLEXIBLE	-T-	
FVNR	FULL VOLTAGE NON-REVERSING	TEL	TELEPHONE
FVR	FULL VOLTAGE REVERSING	T*STAT	THERMOSTAT
		TYP	TYPICAL
-G-			
GND OR G	GROUND	-U-	
		UOI	UNLESS OTHERWISE INDICATED
-H-			
H	HEATER	-V-	
HOA	HAND OFF AUTOMATIC	V	VOLT(S)
HP	HORSEPOWER	VA	VOLT-AMPERE(S)
HID	HIGH INTENSITY DISCHARGE		
HPS	HIGH PRESSURE SODIUM		
-K-			
KV	KILOVOLT(S)	-W-	
KVA	KILOVOLT-AMPERE(S)	W	WATTS OR WIRE
KW	KILOWATT(S)	WP	WEATHERPROOF
KWH	KILOWATT HOUR(S)	WT	WATERTIGHT NEMA 4
KWHD	KILOWATT HOUR METER W/		CONSTRUCTION STAINLESS STEEL
	DEMAND REGISTER	W/	WITH
		W/O	WITHOUT
-L-			
LA	LIGHTNING ARRESTER	-X-	
LS	LIMIT SWITCH	X*FMR	TRANSFORMER
-M-			
MCC	MOTOR CONTROL CENTER		
MTD	MOUNTED		
MTG	MOUNTING		
M HT	MOUNTING HEIGHT		
MCP	MOTOR CIRCUIT PROTECTOR		

**LEGEND**


	<b>WALL MTD.</b>	<b>CEIL. MTD.</b>	
			HID LIGHTING FIXTURE AND OUTLET
			FLUORESCENT LIGHTING FIXTURE AND OUTLET
			BATTERY POWERED, AUTOMATIC, EMERGENCY LIGHTING UNIT; ARROWS INDICATE NUMBER OF HEADS AND/OR AIMING DIRECTION
			OUTLET BOX WITH BLANK COVER
	<b>FLUSH MTD.</b>	<b>SURF. MTD.</b>	
			LOCAL TUMBLER SWITCH, SPST.
			DUPLEX RECEPTACLE, 120V, 20A, 3W WALL OR COLUMN MOUNTED
			MOTOR, SINGLE PHASE, AC, NUMERAL INDICATES DESIGN HORSEPOWER. SUBSCRIPT: DM = DAMPER MOTOR
			MOTOR, POLYPHASE, AC, NUMERAL INDICATES DESIGN HORSEPOWER
			SINGLE SPEED MANUAL MOTOR CONTROLLER.
			NON-FUSED SAFETY SWITCH, SIZE AS NOTED OR REQUIRED
			FUSED SAFETY SWITCH, FUSE SIZE AS NOTED OR REQUIRED
			INDIVIDUALLY MTD CIRCUIT BREAKER, TRIP RATING AS NOTED
			NON-AUTOMATIC (WITHOUT OVERLOADS) CIRCUIT BREAKER, FRAME SIZE AS NOTED
			PANELBOARD, LIGHTING TYPE
			TRANSFORMER, KVA AS NOTED.
			CONTACTOR
			THERMOSTAT
			LIMIT SWITCH
			SOLENOID VALVE
			RACEWAY CONCEALED IN CEILING OR WALL
			RACEWAY CONCEALED IN OR UNDER FLOOR
			RACEWAY EXPOSED ON CEILING OR WALL
			JUNCTION, TAP OR PULLBOX
			RACEWAY TURNED TOWARD VIEWER
			RACEWAY TURNED AWAY FROM VIEWER
			JUNCTION BY CONDULET OR BOX AS REQUIRED
			HOMERUN, PANELBOARD AND CIRCUIT NO. AS INDICATED
			MARKS ACROSS RACEWAY INDICATE NUMBER OF #12 AWG CONDUCTORS THEREIN, UNLESS OTHERWISE INDICATED UNMARKED RUNS INDICATE 3 #12 AWG CONDUCTORS INSIDE RACEWAY (1 PH WIRE, 1 NEUT AND 1 GREEN GROUND CONDUCTOR).
			MOTOR OPERATED VALVE
			ELECTRIC UNIT HEATER WITH BUILT-IN CONTACTOR, AND THERMOSTAT.
			3/4" x 10'-0" COPPERCLAD GROUND ROD
			THERMALLY WELDED GROUND CONNECTION
			GROUND CONDUCTOR, 4/0 A.W.G. BARE COPPER, U.O.I.
			UNDERGROUND DUCT BANK

**LEGEND (CONT.)**

	<b>FOR DIAGRAMS</b>	
	POTENTIAL TRANSFORMER, QUANTITY AND RATIO AS INDICATED	
	CURRENT TRANSFORMER, QUANTITY AND RATIO AS INDICATED	
	AMMETER	
	SELECTOR SWITCH: AS = AMMETER SW, VS = VOLTMETER SW	
	VOLTMETER	
	GROUND FAULT SENSOR	
	CIRCUIT BREAKER	
	TRANSFORMER	
	LIGHTNING ARRESTER	
	SURGE CAPACITOR	
	"HAND-OFF-AUTOMATIC" SELECTOR SWITCH	
	CONTACTS NORMALLY OPEN (N.O.)	
	CONTACTS NORMALLY CLOSED (N.C.)	
	CONTROL RELAY	
	OPERATING COIL OF MOTOR	
	MOTOR SPACE HEATER OR HEATER ELEMENTS	
	PILOT LIGHT	
	THERMAL CUTOUT DEVICE LOCATED IN MOTOR WINDINGS	

**GENERAL NOTES:**


- DRAWINGS SHOWING ELECTRICAL WORK ARE IN PART DIAGRAMMATIC. THE CONTRACTOR SHALL REFER TO ARCHITECTURAL, CIVIL, STRUCTURAL AND MECHANICAL DRAWINGS FOR GUIDANCE AS TO DIMENSIONS, FINISHED GRADES, CEILING HEIGHTS, DOOR SWINGS, STRUCTURAL AND ARCHITECTURAL DETAILS, LOCATION OF DUCTS, PIPES, MECHANICAL SYSTEM EQUIPMENT AND OUTLETS, AND THE LIKE, AND SHALL: (A) INSTALL THE ELECTRICAL SYSTEMS WITHOUT INTERFERENCE WITH DUCTS, PIPES, BEAMS, REINFORCING, AND OTHER OBSTRUCTIONS; (B) LOCATE LIGHTING FIXTURES SYMMETRICALLY, OR AS INDICATED ON PLANS, IN CORRECT RELATION TO FINISHED AREAS; AND (C) PROVIDE ADDITIONAL STEEL SUPPORTS FOR SWITCHES, MOTOR CONTROLLERS, FIXTURES, RACEWAYS, CABINETS, AND THE LIKE, WHERE THE BUILDING STRUCTURE IS NOT ADAPTED TO MOUNTING SAME DIRECTLY THEREON.
- SYMBOLS IN THE LEGEND ARE APPLICABLE GENERALLY. FOR EXACT REQUIREMENTS SEE THE APPLICABLE SCHEDULES, LAYOUTS, DETAILS, AND THE SPECIFICATIONS.
- ON INTERIOR WIRING PLANS A NUMERAL BESIDES A BRANCH CIRCUIT INDICATES THE PANELBOARD CIRCUIT CONNECTION. WHERE OUTLETS ARE LOCALLY SWITCHED, A LOWER CASE LETTER BESIDE THE OUTLET INDICATES THE SWITCH LEG CONNECTION. A NUMERAL WITH INCH (") MARK BESIDE DEVICE INDICATES THE MOUNTING HEIGHT OTHER THAN INDICATED IN SCHEDULE.
- UPPER CASE LETTER BESIDE LIGHTING FIXTURE INDICATES FIXTURE TYPE, SEE LIGHTING FIXTURE SCHEDULE.



**GROUNDING LAYOUT**  
SCALE: 3/32" = 1'-0"


SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			LEGEND, ABBREVIATIONS, GENERAL NOTES, AND GROUNDING LAYOUT
SCALE: AS SHOWN			DWG. NO. 91016-C2-E1
DESIGN: BIB			DATE
DRAWN: SIV & PRICE			CHECKED:
SHEET			OF SHEETS

NOT Released For Construction



TYPICAL MOUNTING FOR TYPE "FA" FLUORESCENT FIXTURE

DETAIL 1  
N.T.S. E2/E2




LIGHTING AND RECEPTACLE LAYOUT  
SCALE: 3/16" = 1'-0"


SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			LIGHTING AND RECEPTACLE LAYOUT AND DETAILS
Robert and Company Architects - Engineers - Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335			SCALE: AS SHOWN DWG. NO. 91016-C2-E2
DESIGN: BIB	DRAWN: RLP	CHECKED:	DATE: SHEET ___ OF ___ SHEETS

NOT Released For Construction







**ELECTRIC UNIT HEATER H-1**  
(TYPICAL FOR H-2, H-3, & H-5)



**EXHAUST FAN EF-1 & DIMPER MD-1**  
(TYPICAL FOR EF-2 & DIMPER MD-2)



**ELECTRIC UNIT HEATER H-4**



**HEATING AND VENTILATION LAYOUT**  
SCALE: 3/16" = 1'-0"

SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			HEATING & VENTILATION LAYOUT AND DIAGRAMS
Robert and Company Architects - Engineers - Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335			SCALE: DWG. NO. 91016-C2-E3
DESIGN: BIB	DRAWN: RLP	CHECKED:	DATE: SHEET ___ OF ___ SHEETS

NOT Released For Construction


WIRE AND CONDUIT SCHEDULE	
①	3-750 KCMIL $\frac{1}{2}$ " 1-4/0 NEUTRAL-4"
②	3-350 KCMIL $\frac{1}{2}$ " 2-6-3"
③	6#14-1"
④	3#10#1#100-3/4"
⑤	4#6#1#100-1"
⑥	3" EMPTY CONDUIT
⑦	1" EMPTY CONDUIT (STUB UP ABOVE FLOOR AND CAP)
⑧	2#12 $\frac{1}{2}$ " 1#12G-1"
⑨	40#14-1 1/4"
⑩	30#14-1"
⑪	20#14-1"
⑫	10#14-1"
⑬	10#14-1/2" FLEX.
⑭	2#14 $\frac{1}{2}$ " 1#14G-1"
⑮	20#12 $\frac{1}{2}$ " 1#12G-1 1/4"
⑯	15#12 $\frac{1}{2}$ " 1#12G-1"

CONT.	
⑰	10#12 $\frac{1}{2}$ " 1#12G-1"
⑱	5#12 $\frac{1}{2}$ " 1#12G-1"
⑲	4#2-1 1/4"
⑳	2#8-1"
㉑	1-3/8" 1#10 SHIELDED-1/2"
㉒	3-3/8" 1#10 SHIELDED-1"
㉓	2-3/8" 1#10 SHIELDED-3/4"
㉔	3#12 $\frac{1}{2}$ " 1#12G-1/2" FLEX

- LEGEND**
- (LT) LEVEL TRANSMITTER
  - (PT) PRESSURE TRANSMITTER
  - (FT) FLOW TRANSMITTER
  - (SV) POWER FAILURE SURGE SOLENOID VALVE
  - (PS) OIL PRESSURE ACTUATOR CUT-OUT SWITCH
- SEE SPECIFICATIONS SECTION 13600

**NOTE:**  
ALL CONTROL WIRING SHALL BE NO. 14 AWG STRANDED COPPER CONDUCTORS, U. S. I.

- NOTES:**
- ① PROVIDE GALVANIZED STEEL SUPPORT STRUCTURE FOR SAFETY SWITCH.
  - ② EXTEND 5#12 TO PULLBOX, LEAVE 6" EXTRA LENGTH AND TAPE FOR FUTURE MOV AND SOLENOID VALVE
  - ③ STUB-UP EMPTY CONDUITS 6" FROM FLOOR AND CAP.
  - ④ EXTEND 10#14 TO PULLBOX, LEAVE 6" EXTRA LENGTH AND TAPE FOR FUTURE MOV LIMIT SWITCHES.
  - ⑤ OVERSIZED MOTOR TERMINAL BOX. FOR 150HP-10" X 10" X 6" MIN. FOR 300HP-14" X 14" X 10" MIN.
  - ⑥ INSTALL SURGE & LIGHTING PROTECTION AT MOTOR IN A PROPERLY SIZED GALVANIZED SHEET STEEL BOX AND SCREW-ON COVER. MOUNT BOX AT FLOOR LEVEL.




**POWER LAYOUT**  
SCALE: 3/16" = 1'-0"

SYMBOL	DATE	BY	REVISION
FINISHED WATER PUMPING STATION			DEPARTMENT ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA			POWER LAYOUT AND DETAILS
			SCALE: AS SHOWN
			DWG. NO. 91016-C2-E4
DESIGN: BIB			DATE:
DRAWN: SIV, RLP			CHECKED:
			SHEET ___ OF ___ SHEETS

DRAWING 44-242 301175




NOT Released For Construction

**NOTES:**  
 1. CONTRACTOR SHALL PROVIDE WIRE TO REVERSING STARTER FOR FUTURE MOTOR OPERATED VALVE INSTALLATION.



SINGLE LINE DIAGRAM  
 N.T.S.

SYMBOL		DATE	BY	REVISION	
FINISHED WATER PUMPING STATION				DEPARTMENT ELECTRICAL	
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				SINGLE LINE DIAGRAM	
Robert and Company Architects - Engineers - Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335				SCALE: AS SHOWN DWG. NO. 91016-C2-E5	
DESIGN: M. S.	DRAWN: R.L.P.	CHECKED:	DATE:	SHEET ___ OF ___ SHEETS	



EAGLE SIGNAL CORP. H.F. SERIES  
PULSE PROGRAM TIMER,  
CAT. NO. HF 54, 8 CIRCUIT  
10, 20, 40 SEC. CYCLE

TIMER DIAGRAM

OPERATING SEQUENCE FOR PUMPS AND GATE VALVES:

- REMOTE CONTROL STARTING (H.O.A.'S SET AT "AUTO"):
- "SR" ENERGIZED VIA TELEPHONE CIRCUIT, PICKING UP "CR1" COIL.
  - "CR1" CLOSING SO THAT WHEN PULSE TIMER CONTACT "1PT" IS CLOSED, COIL "CR2" IS ENERGIZED. "CR2" COIL IS THEN SEALED IN THROUGH "CR1" & "CR2" CONTACTS.
  - "CR2" CONTACT ENERGIZES "M5-O" AND STARTS BUTTERFLY VALVE MOTOR OPERATOR TO OPEN.
  - WHEN GATE VALVE OPENS TO A PRESET POINT, BETWEEN 2% AND 10% OF FULLY OPEN, "LS1" CLOSING, ENERGIZING COIL "M-1" WHICH STARTS PUMP. COIL "M-1" IS SEALED IN THROUGH CONTACT "M-1" AND "LS2".
  - WHEN VALVE OPENS TO 100% "LS3" OPENS, DE-ENERGIZING "M5-O" AND STOPPING VALVE OPERATOR MOTOR.
- REMOTE CONTROL STOPPING (H.O.A.'S SET "AUTO"):
- "SR" DE-ENERGIZED VIA TELEPHONE CIRCUIT, DROPPING OUT "CR1" COIL.
  - WHEN PULSE TIMER CONTACT "2PT" OPENS, "CR2" IS DE-ENERGIZED.
  - "CR2" CLOSING, ENERGIZING "M5-C" AND STARTING BUTTERFLY VALVE TO CLOSE.
  - WHEN VALVE CLOSES TO A PRESET POINT, BETWEEN 90% AND 98% OF FULLY SEALED, "LS2" OPENS AND DE-ENERGIZES "M-1" AND STOPS PUMP MOTOR.
  - WHEN VALVE IS FULLY SEALED (OR BUTTERFLY VALVE STRIKES AN OBSTRUCTION), "TLS" OPENS AND DE-ENERGIZES "M5-C", STOPPING OPERATOR MOTOR.

TELEMETRY TONE EQUIPMENT (SEE SPECIFICATIONS)	CONTROL RELAY AND PROGRAM TIMER SECTION	CORNER TRANSITION SECTION		PUMP No. 4 300 H.P.	PUMP No. 3 FUTURE 300 H.P.	PUMP No. 2 150 H.P.	PUMP No. 1 150 H.P.	VM AS	AM AS
		⊗	⊙						
NOTE 2	3P-204 H-1 7.5 KW	3P-204 H-2 7.5 KW	MOTORIZED VALVE NO. 1 1 H.P.	⊗	⊙	⊗	⊙	3P-2200 A. MAIN BREAKER	⊗ ⊙
	3P-204 H-3 7.5 KW	3P-204 H-5 5 KW	MOTORIZED VALVE NO. 2 (FUTURE) 2 H.P.	⊙	⊗	⊙	⊗		
	3P-254 1 1/2" TRAFFIC	SPACE	MOTORIZED VALVE NO. 3 2 H.P.	⊙	⊗	⊙	⊗	INCOMING SECTION & SURGE PROTECTION	⊗ ⊙
	SPACE	SPACE	MOTORIZED VALVE NO. 4 2 H.P.	⊙	⊗	⊙	⊗		
		SPACE	EF-1 3 H.P.						
			SPACE	EF-2 3 H.P.					

FRONT ELEVATION MOTOR CONTROL CENTER

LEGEND

- ⊗ VALVE CONTROL AMBER LIGHT (VALVE OPEN)
- ⊙ VALVE CONTROL BLUE LIGHT (VALVE CLOSED)
- SEL. SW. (OPEN-CLOSED-AUTO)
- ⊕ PUMP CONTROL RED LIGHT (PUMP RUNNING)
- ⊕ SEL. SW. WITH KEY OPERATOR ARRANGED FOR KEY REMOVAL IN ALL POSITIONS AND REQUIRING A KEY TO OPERATE. (HAND-OFF-AUTO)
- ⊕ MAIN BREAKER
- ⊕ RED LIGHT (BREAKER CLOSED)
- ⊕ GREEN LIGHT (BREAKER OPEN)

NOTES:

- SPACE HEATERS FOR MOTORS SHALL BE SIZED BY MOTOR MANUFACTURER. CONTRACTOR SHALL COORDINATE HEATER SIZE WITH C.P.T. RATING TO INSURE ADEQUATE SIZED C.P.T. FOR TOTAL LOAD.
- TELEMETRY TONE EQUIPMENT CABINET SHALL BE FURNISHED & INSTALLED COMPLETE BY THE CONTRACTOR. SEE SPECIFICATIONS.



SCHEMATIC DIAGRAM PUMP AND VALVE NO. 1

- ▲ INDICATES DEVICE MOUNTED IN MOTOR CONTROL CENTER.
- \* INDICATES DEVICE MOUNTED IN TELEMETRY SECTION.
- INDICATES DEVICE LOCATED IN MOTOR WINDINGS.
- SR — SUPERVISORY CONTROL RECEIVER RELAY.
- CR1, CR2, CR3 — CONTROL RELAYS, COILS, OR CONTACTS.
- PT — PROGRAM TIMER COIL OR CONTACTS.
- M5-O — VALVE MOTOR STARTER OPERATING COIL OR AUX. CONTACTS FOR OPEN DIRECTION.
- M5-C — SAME AS M4-O EXCEPT FOR CLOSE DIRECTION.
- ITR — PNEUMATIC TIMING RELAY, TR ON ENERGIZATION.
- TR — TEMPERATURE RELAY CONNECTED TO MOTOR RTD OR OTHER THERMAL CUTOUT DEVICE TO PROTECT MOTOR WINDINGS, (TCD).
- ⊗ — PILOT LIGHT, COLOR CAP AS DESIGNATED.
- LS1 — CLOSING MOMENTARILY AT A PRE-SET POINT BETWEEN 2% AND 10% OF VALVE OPENING ONLY. IT MUST NOT CLOSE DURING VALVE CLOSURE.
- LS2 — OPEN MOMENTARILY AT A PRE-SET POINT BETWEEN 90% AND 98% OF VALVE CLOSING ONLY. IT MUST NOT OPEN DURING VALVE OPENING.
- LS3 — OPENS ONLY WHEN VALVE IS 100% OPEN.
- LS4 — CLOSING ONLY WHEN VALVE IS SEATED.
- LS5 — CLOSING ONLY WHEN VALVE IS 100% OPEN.
- TLS — STANDARD THERM. LIMIT SWITCH.
- SV — POWER FAILURE SURGE COLENOID VALVE.
- ⊗ — OIL PRESSURE SWITCH LOCATED ON ENGINE TO PREVENT MOTOR START WHEN ENGINE IS RUNNING (PUMP NO. 3 ONLY).

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				MOTOR CONTROL CENTER, WIRING DIAGRAMS, AND DETAILS
Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335				SCALE: NOT TO SCALE DWG. NO. 91016-C2-E6
DESIGN: M.S.	DRAWN: R.L.P.	CHECKED:	DATE:	SHEET ___ OF ___ SHEETS


### LIGHTING FIXTURE SCHEDULE

FIXTURE TYPE	MANUFACTURER	NO. OF LAMPS, TYPE & WATTAGE	REMARKS
FA	LUMAX CAT. NO. TP 240 048-BH13A	2-F40 T12 CW/RB FOR	4' INDUSTRIAL FLUORESCENT UNIT WITH PORCELAIN REFLECTOR, SNAP-IN PRESSURE SOCKETS, CODE-GAUGE STEEL, BAKED WHITE ENAMEL FINISH. 20% UP LIGHT. 120 VOLT BALLAST.
HA	SYLVANIA CAT. NO. AK-50 HPS-120 H	1-50W MEDIUM BASE HPS (LU 50)	SMALL WALL PACK HIGH PRESSURE SODIUM LIGHT FIXTURE U.L. LISTED FOR WET LOCATIONS WITH TAMPER PROOF FASTENERS INJECTION-MOLDED POLYCARBONATE REFLECTOR AND 120 VOLT HPP BALLAST. MOUNT 10'-0" A.F.F.
HB	SYLVANIA CAT. NO. AK-150 HPS-120 H W/ADAP. P.E. CELL AND PECK ADAPTOR	1-150W MEDIUM BASE HPS (LU 150)	WALL PACK HIGH PRESSURE SODIUM LIGHT FIXTURE U.L. LISTED FOR WET LOCATIONS WITH IES CUTOFF REFLECTOR STAINLESS STEEL EXTERNAL HARDWARE INJECTION-MOLDED POLYCARBONATE LENS, PHOTOELECTRIC CONTROL AND 120 VOLT HPP BALLAST. MOUNT 12'-0" A.F.F.
BA	EMERGENCY LIGHTING & SYSTEMS CAT. NO. ELC-2	2-12W HALOGEN	WALL MOUNTED EMERGENCY LIGHT WITH 120/277 VAC INPUT, 6 VOLT CALCIUM BATTERY, INDICATOR LIGHTS AND TEST SWITCHES. BRACKET MOUNT 8'-0" A.F.F.




### NOTES:

- CONTRACTOR SHALL FURNISH AND INSTALL THE FOLLOWING ITEMS OF EQUIPMENT IN THE EXISTING METERING PANEL:
  - ONE (1) 3-PEN RECORDER (SEE SPECIFICATIONS), SECTION 13000.
  - FOUR (4) OFF-RUN-PILOT LIGHT SELECTOR SWITCHES FOR NEW PUMPS.
  - COORDINATE EXACT LOCATION OF (a) & (b) WITH OWNER AND ENGINEER.



1 ADDITIONS TO EXISTING METERING PANEL N.T.S.

SYMBOL DATE BY REVISION	
FINISHED WATER PUMPING STATION	DEPARTMENT ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA	LIGHTING FIXTURE SCHEDULE, LIGHTING PANELBOARD, AND EXIST-FILTER BUILDING
Robert and Company Architects - Engineers - Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335	SCALE: AS SHOWN DWG. NO. 91016-C2-E7
DESIGN: BIB	DRAWN: RLP
CHECKED:	DATE:
SHEET	OF SHEETS



**TELEMETRY CONTROL WIRING DIAGRAM**


**NOTES**

1. CONTRACTOR SHALL INSTALL NEW 3 PEN RECORDER IN SPACE PROVIDED IN EXISTING METERING PANEL. AT W.J. HOOPER FILTER PLANT. CONTRACTOR SHALL FURNISH AND INSTALL RECORDER SPECIFIED.
2. CONTRACTOR SHALL FURNISH AND INSTALL ALL TELEMETRY ITEMS OF EQUIPMENT AS SPECIFIED.
3. ALL INSTRUMENTATION AND ACCESSORIES, SUCH AS TRANSMITTERS, ETC., SHALL BE FURNISHED AND INSTALLED BY THE CONTRACTOR.
4. ALL WIRING SHALL BE #14 AWG STRANDED COPPER.
5. CONTRACTOR SHALL INSTALL TONE EQUIPMENT IN SPACE PROVIDED FOR THIS PURPOSE LOCATED IN BACK OF EXISTING METERING PANEL.
6. SIGNAL TO TONE EQUIPMENT IS 4-20 M.A. COORDINATE WITH SPECIFIED TONE EQUIPMENT.


SEE SCHEMATIC WIRING DIAGRAM DWG. E 6

SYMBOL		DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION					ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA					TELEMETRY AND INSTRUMENTATION
Robert and Company Architects - Engineers - Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335					SCALE: AS SHOWN DWG. NO. 91016-C2-E8
DESIGN: M.S.	DRAWN: RLP, SIV	CHECKED:			DATE: SHEET ___ OF ___ SHEETS


NOT Released For Construction



**1** DUCT BANK SECTION  
E4 E9 N.T.S.



**2** DETAIL - TRANSFORMER PAD  
E4 E9 N.T.S.



**3** ELEVATION - MAIN SERVICE CONDUCTORS INSTALLATION DETAIL  
E4 E9 N.T.S.

SYMBOL	DATE	BY	REVISION	DEPARTMENT
FINISHED WATER PUMPING STATION				ELECTRICAL
FOR: CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA				ELECTRICAL DETAILS
Robert and Company Architects-Engineers-Planners 96 Poplar Street, N.W. Atlanta, Georgia 30335 404 577-4000 FAX: 404 571-7119				DWG. NO. 91016-C2-E9
DESIGN: BIB	DRAWN: SIV & PRICE	CHECKED:	DATE	SHEET OF SHEETS

NOT Released For Construction

T:\DRAFTING DWGS\CD File\CD #1 (90-95)\1991 DRAWINGS\9123CLAYTONCO-GA.DWG, 11/16/2005 4:25:49 PM




TABLE OF CONTENTS

1. TITLE SHEET
2. SITE PLAN & NOTES
3. PLAN, SECTION-ELEVATION TANK #1
4. PLAN, SECTION-ELEVATION TANK #2
5. TYPICAL WALL DETAILS & PRESTRESSING SCHEDULE
6. PIPING DETAILS
7. SEISMIC RESTRAINT CABLE DETAILS
8. ACCESSORY DETAILS

# 2-2.70 MG RESERVOIRS

OWNER: CLAYTON COUNTY WATER AUTHORITY  
MORROW, GEORGIA

CONSULTING ENGINEERS: ROBERT AND COMPANY  
ATLANTA, GEORGIA



**THE CROM CORPORATION**  
Prestressed Composite Tanks


REV	COMMENTS	DATE

Revisions are designated by a letter following the FILE NUMBER . UPPER CASE letters indicate APPROVED distribution.

DATE:	FILE NUMBER :	SHEET
DRAWN:	<b>9123</b>	<b>1 OF 8</b>
CHKD:		
APPVD:		



T:\DRAFTING DWGS\CD File\CD #1 (90-95)\1991 DRAWINGS\9123CLAYTONCO-GA.DWG, 11/16/2005 4:30:14 PM



NOTES



DATE:  
 DRAWN:  
 CHKD:  
 APPVD:  
 TANK DESCRIPTION:  
**2-2.7 MG RESERVOIRS**  
 TANK DIMENSIONS:  
**90'0" ID x 57'0" SWD**  
 TANK BUILDER:  
**THE CROM CORPORATION  
 GAINESVILLE, FLORIDA**  
 OWNER:  
**CLAYTON COUNTY  
 WATER AUTHORITY  
 MORROW, GEORGIA**  
 CONSULTING ENGINEER:  
**ROBERT AND COMPANY  
 ATLANTA, GEORGIA**

REV.	DESCRIPTION	DATE	CK.BY


WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRE-STRESSING OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED. THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE: 10' 0 20'

FILE NO. **9123**


SHEET **2** OF **8**

PLACE 13/4" LONG BARS TO 46'2" RADIUS IN TRANSITION OF FLOOR THICKNESS IN SAME PLANE WITH REGULAR FLOOR REINFORCEMENT. USE #4 @ 8". OMIT AT EXTRA MATS OVER PIPES




**13** TRANSITION RESTEEL DETAIL

T:\DRAFTING DWGS\CD File\CD #1 (90-95)\1991 DRAWINGS\9123CLAYTONCO-GA.DWG, 11/16/2005 4:30:29 PM





**SECTION-ELEVATION**



**TANK #1**

**PLAN**

NOTE: FIELD VERIFY ALL ACCESSORY & PIPE LOCATIONS WITH ENGINEER PRIOR TO PLACEMENT.


 DENOTES DETAIL NUMBER  
 DENOTES PAGE NUMBER  
 WHERE DETAIL APPEARS  
 DENOTES SECTION LETTER  
 DENOTES PAGE NUMBER  
 WHERE SECTION APPEARS



DATE:	
DRAWN:	
CHKD:	
APPVD:	
TANK DESCRIPTION:	<b>2-2.7 MG RESERVOIRS</b>
TANK DIMENSIONS:	<b>90'0" ID x 57'0" SWD</b>
TANK BUILDER:	<b>THE CROM CORPORATION GAINESVILLE, FLORIDA</b>
OWNER:	<b>CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA</b>
CONSULTING ENGINEER:	<b>ROBERT AND COMPANY ATLANTA, GEORGIA</b>

REV.	DESCRIPTION	DATE	CK.BY

WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRACTICES OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED.  
 THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE: 

FILE NO. **9123**

SHEET **3** OF **8**

T:\DRAFTING DWGS\CD #1 (90-95)\1991 DRAWINGS\9123CLAYTONCO-GA.DWG, 11/16/2005 4:30:43 PM



DATE:  
 DRAWN:  
 CHKD:  
 APPVD:  
 TANK DESCRIPTION:  
**2-2.7 MG RESERVOIRS**  
 TANK DIMENSIONS:  
**90'0" ID x 57'0" SWD**  
 TANK BUILDER:  
**THE CROM CORPORATION  
 GAINESVILLE, FLORIDA**  
 OWNER:  
**CLAYTON COUNTY  
 WATER AUTHORITY  
 MORROW, GEORGIA**

CONSULTING ENGINEER:  
**ROBERT AND COMPANY  
 ATLANTA, GEORGIA**



REV.	DESCRIPTION	DATE	CK.BY

WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRACTICES OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED.  
 THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE: 2'0 5' 10'


FILE NO.  
**9123**

SHEET **4** OF **8**




NOTE: FIELD VERIFY ALL ACCESSORY & PIPE LOCATIONS WITH ENGINEER PRIOR TO PLACEMENT.


DENOTES DETAIL NUMBER  
 DENOTES PAGE NUMBER  
 WHERE DETAIL APPEARS  
 DENOTES SECTION LETTER  
 DENOTES PAGE NUMBER  
 WHERE SECTION APPEARS



**DOME RING DETAIL**



**HORIZONTAL WALL SECTION**




**FLOOR-WALL DETAIL  
TYPICAL WALL DETAILS**




INITIAL PRESTRESSING FORCE IN POUNDS

207,000	23	23
21,000	7	
30,000	10	
30,000	10	
30,000	10	
30,000	10	
30,000	10	
30,000	10	
30,000	10	
30,000	10	
30,000	10	
33,000	11	
36,000	12	
39,000	13	
42,000	14	
45,000	15	
51,000	17	
54,000	18	
57,000	19	
60,000	20	
63,000	20	
69,000	21	
72,000	20	
75,000	4 20	
78,000	5 20	
81,000	6 20	
87,000	7 20	
90,000	9 20	
93,000	10 20	
96,000	11 20	
99,000	12 20	
99,000	13 20	
102,000	14 20	
108,000	16 20	
111,000	17 20	
114,000	18 20	
117,000	19 20	
120,000	20 20	
126,000	21 21	
129,000	3 20 20	
132,000	4 20 20	
135,000	5 20 20	
138,000	6 20 20	
141,000	7 20 20	
147,000	9 20 20	
150,000	10 20 20	
153,000	11 20 20	
156,000	12 20 20	
159,000	13 20 20	
165,000	15 20 20	
168,000	16 20 20	
171,000	17 20 20	
174,000	18 20 20	
177,000	19 20 20	
246,000	20 20 21 21	
312,000	20 21 21 21 21	
321,000	21 21 21 21 21	
312,000	20 21 21 21 21	



**PRESTRESSING SCHEDULE**



COPYRIGHT © 1991 BY THE CROM CORPORATION-ALL RIGHTS RESERVED



DATE:  
DRAWN:  
CHKD:  
APPVD:  
TANK DESCRIPTION:  
**2-2.7 MG RESERVOIRS**  
TANK DIMENSIONS:  
**90'0" ID x 57'0" SWD**  
TANK BUILDER:  
**THE CROM CORPORATION  
GAINESVILLE, FLORIDA**  
OWNER:  
**CLAYTON COUNTY  
WATER AUTHORITY  
MORROW, GEORGIA**  
CONSULTING ENGINEER:  
**ROBERT AND COMPANY  
ATLANTA, GEORGIA**


REV.	DESCRIPTION	DATE	CK. BY

WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRESTRESSING OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED. THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE:  
**AS NOTED**  
FILE NO.  
**9123**  
SHEET **5** OF **8**

T:\DRAFTING DWGS\CD File\CD #1 (90-95)\1991 DRAWINGS\9123CLAYTONCO-GA.DWG, 11/16/2005 4:31:28 PM

T:\DRAFTING DWGS\CD #1 (90-95)\1991 DRAWINGS\9123CLAYTONCO-GA.DWG, 11/16/2005 4:31:55 PM




**1** 12" DIP DRAIN

PIPE SCHEDULE FOR 12" DIP DRAIN


- ① 12" DIP x 1'6" ?" LG., PE-PE W/WATERSTOP RING 4" FROM PE
- ② 12" DIP x 90° ELBOW, MJ-MJ (COMPACT)
- ③ 12" DIP x 10'0" LG., PE-PE

PIPE SCHEDULE FOR 24" DIP INLET

- ① 24" DIP x 4'2" LG., PE-PE W/WATERSTOP RING 10" FROM PE
- ② 24" DIP x 90° ELBOW, MJ-MJ (COMPACT)
- ③ 24" DIP x 9'2" LG., PE-MJ
- ④ 24" DIP MJ PLUG




**2** 24" DIP INLET




**3** TYPICAL PIPE ENCASEMENT

PIPE SCHEDULE FOR 24" DIP OUTLET

- ① 24" DIP x 4'2" LG., PE-PE W/WATERSTOP RING 10" FROM PE
- ② 24" DIP x 90° ELBOW, MJ-MJ (COMPACT)
- ③ 24" DIP x 9'2" LG., PE-MJ
- ④ 24" DIP MJ PLUG



**4** 24" DIP OUTLET




DATE:  
 DRAWN:  
 CHKD:  
 APPVD:  
 TANK DESCRIPTION:  
**2-2.7 MG RESERVOIRS**  
 TANK DIMENSIONS:  
**90'0" ID x 57'0" SWD**  
 TANK BUILDER:  
**THE CROM CORPORATION  
 GAINESVILLE, FLORIDA**  
 OWNER:  
**CLAYTON COUNTY  
 WATER AUTHORITY  
 MORROW, GEORGIA**

CONSULTING ENGINEER:  
**ROBERT AND COMPANY  
 ATLANTA, GEORGIA**


REV.	DESCRIPTION	DATE	CK. BY

WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRE-STRESSING OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED. THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE:  
**AS NOTED**  
 FILE NO.  
**9123**  
 SHEET **6** OF **8**



NOTE: SPREAD CABLES 1 ?" c/c ALONG FULL LENGTH ON WALL



DATE:
DRAWN:
CHKD:
APPVD:
TANK DESCRIPTION: <b>2-2.7 MG RESERVOIRS</b>
TANK DIMENSIONS: <b>90'0" ID x 57'0" SWD</b>
TANK BUILDER: <b>THE CROM CORPORATION GAINESVILLE, FLORIDA</b>
OWNER: <b>CLAYTON COUNTY WATER AUTHORITY MORROW, GEORGIA</b>
CONSULTING ENGINEER: <b>ROBERT AND COMPANY ATLANTA, GEORGIA</b>

REV.	DESCRIPTION	DATE	CK. BY


WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRE-STRESSING OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED. THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE: AS NOTED

FILE NO. **9123**

SHEET **7** OF **8**


**QUANTITIES ARE FOR ONE TANK**



DIMENSION SCHEDULE			
A	44'0"	D	1'8 5/8"
B	12'0"		
C	2'6"		

NOTES: 1. ALL TUBULAR MATERIAL TO BE NOMINAL DIAMETER SCHEDULE 40 ALUMINUM PIPE 6061-T6.  
2. PLATES AND GUSSETS TO BE STRUCTURAL GRADE ALUMINUM 6061-T6.


**5 EXTERIOR ALUMINUM LADDER WITH TS SAFETY RAIL & LADDER SECURITY DOOR**




DIMENSION SCHEDULE			
A	59'0"		
B	4'0"		
C	4'0"		

NOTE: 1/4" x 2" FLAT BAR FIBERGLASS CROSS-BRACE TO BE PROVIDED FOR BRACING WALL BRACKET SUPPORTS ON LADDERS OVER 20'0" TALL. INSTALL ON EVERY OTHER BRACKET.


**6 INTERIOR FIBERGLASS LADDER WITH TS SAFETY RAIL**




**7 50" FIBERGLASS VENTILATOR**




**8 WALL MANHOLE (2 REQ.)**



**9 #675 PRECAST CONCRETE OVERFLOW (3 REQ.)**



**10 FIBERGLASS HATCH COVER**



**11 FIBERGLASS LIQUID LEVEL INDICATOR**



DATE:  
DRAWN:  
CHKD:  
APPVD:  
TANK DESCRIPTION:  
**2-2.7 MG RESERVOIRS**  
TANK DIMENSIONS:  
**90'0" ID x 57'0" SWD**  
TANK BUILDER:  
**THE CROM CORPORATION  
GAINESVILLE, FLORIDA**  
OWNER:  
**CLAYTON COUNTY  
WATER AUTHORITY  
MORROW, GEORGIA**

CONSULTING ENGINEER:  
**ROBERT AND COMPANY  
ATLANTA, GEORGIA**

REV.	DESCRIPTION	DATE	CK.BY


WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRE-STRESSING OR SHOTCRETE PRACTICES THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED. THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORPORATION.

SCALE:  
**NTS**

FILE NO.  
**9123**


SHEET **8** OF **8**

- 16" INLET**
- 1 8" PIPE PE-PE
  - 2 90° ELBOW 15' CF MJ-MJ
  - 3 7'-0" PIPE PE-FL
- 16" FUTURE INLET**
- 1 8" PIPE PE-PE
  - 2 90° ELBOW MJ-MJ
  - 3 7'-0" PIPE PE-FL
  - 4 BLIND FLANGE
  - 5 FL. ACCESSORY SET.




**16" INLETS**  
SECTION C-C SCALE: 1/2" = 1'-0"

- 24" OUTLET**
- 1 8" PIPE PE-PE
  - 2 90° ELBOW MJ-MJ 22' CF
  - 3 0'-6" PIPE PE-FL
- 24" FUTURE OUTLET**
- 1 8" PIPE PE-PE
  - 2 90° ELBOW MJ-MJ
  - 3 0'-6" PIPE PE-FL
  - 4 BLIND FLANGE
  - 5 FL. ACCESSORY SET.




**24" OUTLETS**  
SECTION B-B SCALE: 1/2" = 1'-0"


THICKEN FLOOR OVER ENCASEMENT AND ADD #4 @ 6" EA. WAY  
FLOOR STEEL #5 @ 8" EA. WAY



**SECTION G-G**  
16" INLETS SCALE: 1/2" = 1'-0"




**SECTION F-F**  
24" OUTLETS SCALE: 1/2" = 1'-0"



**FORMING DETAIL - FLOOR JOINT**  
SCALE: 3" = 1'-0"

NOTE: VIBRATE CONCRETE VERY CAREFULLY AROUND WATERSTOP

ADD 6-#4 CONT. ALONG BOTH EDGES



**SECTION E-E**  
DETAIL OF FLOOR JOINT SCALE: 1/2" = 1'-0"

NOTE: WORK CONCRETE VERY CAREFULLY TO INSURE TOTAL ENCASEMENT OF WATERSTOP BOTH SIDES

WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRESTRESSING OR SHOTCRETE PRACTICES, THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED.

**DESIGN SPECIFICATIONS**

**SHOTCRETE:**  
f<sub>c</sub>  
f<sub>t</sub>  
f<sub>ci</sub> < 0.55 f<sub>ci</sub> at winding

**CONCRETE:**  
f<sub>c</sub>  
f<sub>t</sub>

**PRESTRESS WIRE:**  
MEETS ASTM SPEC.  
AW = 1/2" IN PLACE  
DIA = 1/2" IN PLACE  
ULTIMATE STRESS PSI  
INITIAL STRESS PSI  
WORKING STRESS: WALL PSI  
DOME RING PSI

THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORP.







5 M.G. WATER STORAGE RESERVOIR  
CLAYTON COUNTY WATER AUTHORITY,  
MORROW, GEORGIA.  
ROBERT & COMPANY ASSOCIATES  
ATLANTA, GEORGIA.

**THE CROM CORPORATION**  
250 S.W. 36TH TERRACE  
GAINESVILLE, FLORIDA 32601



SCALE AS NOTED	REVISIONS APPROVAL & CLARIFICATIONS	SHEET
DATE: 10-23-71	10-4-71	3
DRAWN: M.M.		OF 4
CHKD: HEP		
APPRD:	FILE NO. 7128	





WHERE STANDARD SPECIFICATIONS ARE IN CONFLICT WITH CROM CORPORATION SPECIFICATIONS OR WITH GOOD PRESTRESSING OR SHOTCRETE PRACTICES, THE STANDARD SPECIFICATIONS SHALL BE SUBORDINATED.

**DESIGN SPECIFICATIONS**

- SHOTCRETE:**  
 f'c  
 f'c < 0.55 f'c at winding
- CONCRETE:**  
 f'c  
 f'c
- PRESTRESS WIRE:**  
 MEETS ASTM SPEC.  
 AW = \_\_\_\_\_ (1) IN PLACE  
 DIA = \_\_\_\_\_ (1) IN PLACE  
 ULTIMATE STRESS \_\_\_\_\_ PSI  
 INITIAL STRESS \_\_\_\_\_ PSI  
 WORKING STRESS: \_\_\_\_\_ PSI  
 WALL \_\_\_\_\_ PSI  
 DOME RING \_\_\_\_\_ PSI


THIS DESIGN AND DRAWING ORIGINATED BY AND THE EXCLUSIVE PROPERTY OF THE CROM CORP.

5 M. G. WATER STORAGE RESERVOIR  
 CLAYTON COUNTY WATER AUTHORITY  
 MURROW, GEORGIA.  
 ROBERT & COMPANY ASSOCIATES  
 ATLANTA, GEORGIA.

**THE CROM CORPORATION**  
 250 S.W. 36TH TERRACE  
 GAINESVILLE, FLORIDA 32601




SCALE AS NOTED	REVISIONS: APPROVAL & CLARIFICATIONS	SHEET
DATE: 9-23-71	10-4-71	2
DRAWN: N.M.		OF 4
CHKD: HEP		
APPVD:	FILE NO. 7128	



TYPICAL PUMP BASE - PLAN

DETAIL	1
1" = 1'-0"	



SECTION A-A  
1" = 1'-0"




Autodesk Docs/02457-027\_Jonesboro and Nobles A&RPS IMP/02457-027\_GENERAL-STRU/14  
4/15/2024 6:11:57 PM

1	ADDENDUM No. 1	04/2024	BCJ
REV	ISSUED FOR	DATE	BY

PROJECT ENGINEER:	B. JONES
DESIGNED BY:	D. OLADIMEJI
DRAWN BY:	D. OLADIMEJI
CHECKED BY:	A. THURSTON
IF THIS BAR DOES NOT MEASURE 1" THEN DRAWING IS NOT TO FULL SCALE	

ISSUED FOR BID



**Hazen**  
HAZEN AND SAWYER  
1300 ALTMORE AVE SUITE 520  
ATLANTA, GEORGIA 30342  
GBPE LIC #: PEF003685 EXP: 6/30/2024


CLAYTON COUNTY WATER AUTHORITY  
CLAYTON COUNTY, GA

JONESBORO  
RPS IMPROVEMENTS

GENERAL  
STRUCTURAL  
GENERAL STRUCTURAL DETAILS

DATE:	MARCH 2024
HAZEN NO.:	32457-027
CONTRACT NO.:	HS-RE-21-06
DRAWING NUMBER:	S3

2



ADDENDUM NO.	DATE	CLAYTON COUNTY WATER AUTHORITY CLAYTON, GA	HAZEN JOB NUMBER 32457-027	REFER TO CONTRACT DRAWING NUMBER
ATTACHMENT NO.	BY	JONESBORO AND NOAH'S ARK RPS IMPROVEMENTS	CONTRACT NUMBER 2024-WP-12	SHEET OF

**SECTION 40 66 54**  
**CELLULAR COMMUNICATION SYSTEM**

**PART 1 – GENERAL**

**1.01 THE REQUIREMENT**

- A. The Contractor shall furnish, test, install and place in satisfactory operation the cellular communication system, with all spare parts, accessories, and appurtenances as herein specified and as shown on the Drawings.
- B. The cellular communication system shall utilize 4G LTE cellular Ethernet. The Contractor shall construct the system in accordance with all applicable FCC rules. In addition, the Contractor shall prepare and submit any other required documentation as required.
- C. Owner will have a service agreement with a cellular service provider (4G LTE carrier) directly and will pay the activation and monthly cost to the provider. Contractor shall provide a cut-over schedule to the cellular service provider and coordinate with the provider to activate the cellular modem and test communications before cut-over at site.

**1.02 RELATED WORK SPECIFIED ELSEWHERE**

- A. Section 40 61 13 – Process Control System General Provisions
- B. Section 40 67 00 – Control System Equipment Panels and Racks
- C. Section 40 78 56 – Isolators and Surge Suppressors

**1.03 TOOLS, SUPPLIES AND SPARE PARTS**

- A. The following tools shall be provided:
  - 1. One set of coaxial cable preparation tools required for installing coaxial cable ground clamps and all types of coaxial cable connectors supplied under this Contract. Tools shall be specifically designed for the size and type of cables supplied under this Contract.
  - 2. Cellular router remote management software as described herein.
- B. The following spare parts shall be provided:
  - 1. One (1) spare 4G LTE router

2. Two (2) of each type of coaxial cable connector furnished under this Contract

#### **1.04 SUBMITTALS**

- A. In addition to submittals required under Section 40 61 15 – Process Control System Submittals, submit antenna installation details for antenna installations required under this Contract. The details shall include scaled drawings of the antenna, antenna mounting hardware and support structures, coaxial cables, connectors, ground clamps, fasteners, and lightning surge protectors. An equipment list shall be included identifying each component. Submit product literature for each component.

#### **1.05 TELEMETRY SYSTEM EQUIPMENT LOCATIONS**

- A. Cellular router shall be mounted on a DIN rail in the Pump Station PLC control panel. Refer to the Drawings for the LCP and cellular antenna locations.

### **PART 2 – PRODUCTS**

#### **2.01 GENERAL**

- A. The Contractor shall provide a multicarrier 4G LTE cellular communications system.
- B. All communications equipment shall be installed in accordance with the manufacturer's recommendations, FCC rules and regulations, and details on the Contract Drawings.
- C. All cellular communications equipment power and signal lines that extend or are located outside of an enclosed structure shall be protected from lightning and voltage surges in accordance with the requirements of Section 40 78 56 – Isolators, Intrinsically-Safe Barriers, and Surge Suppressors.

#### **2.02 CELLULAR ANTENNAS AND APPURTENANCES**

- A. Type and specification of the cellular antenna should be coordinated with the cellular service provider.
- B. Antennas for the remote station cellular routers shall be cross-polarized directional wide band antennas.
- C. Cellular antennas shall be RSRF ANT627-NF-PANEL-MIMO-OD, or owner-approved equal.
- D. Cellular antenna shall meet the following requirements:
  1. Rotation pattern: Omni-Directional

2. Antenna Gain: 698-960 MHz 1.5 dBi, 1710-2700 MHz 4.5 dBi
  3. Bandwidth VSWR: less than 2:1
  4. Impedance: 50 ohms
  5. Maximum input power rating: 20 watts or higher
  6. RF Connector: SMA Plug
- E. Cellular antennas shall be supplied as a complete kit including mounting hardware, coaxial antenna cable, surge suppressor, weatherproofing kit, and other appurtenances required for a reliable installation.

### **2.03 CELLULAR ROUTERS**

- A. Cellular routers shall utilize 4G LTE to transmit and receive Ethernet/IP PLC communications data. The routers shall be completely compatible with the control and information system's hardware and communication protocols. Cellular router shall have dual SIM card and multi-carrier support for link redundancy.
- B. Cellular routers shall be a Semtech (Sierra Wireless) Airlink RV50X or approved equal.
- C. Cellular routers shall have the following operation and performance specifications:
1. Environmental
    - a. Temperature Range: -40°C to +70°C
    - b. Humidity: 90% at 60°C; non-condensing
  2. Standards and Certifications:
    - a. Safety: UL 60950
    - b. EMI: FCC Part 15B Class A or B.
    - c. Radio: FCC Rules Part 22H, FCC Part 24E.
  3. General Router Requirements
    - a. Protocol Support: The router shall support the following network protocols:
      - 1) HTTP, HTTPS, FTP, SFTP, SSL, SMTP, Device Cloud SNMP, SNMP (v1/v2c/v3), SSH, Telnet and CLI for web management.

- 2) Remote management; SMS management, protocol analyzer, ability to capture PCAP for use with Wireshark.
  - 3) DynDNS, Dynamic DNS client compatible with BIND9/No-IP/DynDNS.
  - 4) DHCP.
  - 5) DNS client compatible with BIND9/No-IP/DynDNS.
  - 6) QoS via TOS/DSCP/WRED.
  - 7) Ethernet, serial I/O and Modbus bridging for connecting diverse field assets.
- b. Routing/Failover: The router shall support the following routing and failover features:
- 1) IP pass-through.
  - 2) NAT, NATP with IP Port Forwarding.
  - 3) Ethernet Bridging.
  - 4) GRE.
  - 5) Multicast Routing.
  - 6) Routing Protocols: PPP, PPPoE, RIP (v1,v2) OSPF, SRI, BGP, iGMP routing (multicast).
  - 7) RSTP (Rapid Spanning Tree Protocol).
  - 8) IP Failover: VRRP, VRRP+TM.
  - 9) Automatic failover/failback to second GSM network/Standby APN.
- c. Security: The router shall support the following security features:
- 1) IP filtering.
  - 2) Stateful inspection firewall with scripting address and port translation;
  - 3) VPN: IPSec with IKEv1, IKEv2, NAT Traversal.
  - 4) SSL, SSLv2, SSLv3, FIPS 197, Open VPN client and server; PPTP, L2TP.

- 5) VPN Tunnels: 5. Cryptology: SHA-1, MD5, RSA.
  - 6) Encryption: DES,3DES and AES up to 256-bit (CBC mode for IPsec).
  - 7) Authentication: RADIUS, TACACS+, SCEP for X.509.
  - 8) certificates;.
  - 9) Content Filtering(via 3rd party).
  - 10) MAC Address Filtering; VLAN support.
- d. Hardware Interfaces: The router shall support the following interfaces:
- 1) 1 x RJ45 10/100/1000 Ethernet,
  - 2) 1 x RS-232/RS-485 serial
  - 3) 1 x USB 2.0
  - 4) 3 x Antenna connectors: SMA
- e. Cellular Modem (WWAN)
- 1) The cellular modem shall be equipped with two SIM card slots capable of supporting two different cellular service providers. The modem shall be capable of automatically switching between providers to ensure optimal cellular signal quality.
  - 2) The cellular modem shall be capable of supporting at least two of the following 4G LTE carriers through a Machine-to-Machine (M2M) data plan:
    - a) Verizon
    - b) AT&T
    - c) Sprint
    - d) T-Mobile
  - 3) The cellular modem shall have fall back capability and automatically switch to 3g or 2g service should 4G LTE become degraded or unavailable.



- 4) Input Power: The cellular router shall be capable operating on 24V DC power.
- 5) Remote Configuration: The user shall have the ability to configure any cellular radio over-the-air from the SCADA network.
- 6) PLC Programming: The modem shall provide the user the capability to program any remote site PLC over-the-air from any computer in the SCADA network.
- 7) Active Ports: The modem shall have, as a minimum, two active ports that can sequentially manage the transfer of Ethernet and serial data messages: 1 serial and 2 Ethernet. In addition, router shall have 1 USB 2.0 port.

#### **2.04 TRANSMISSION CABLE AND MISCELLANEOUS REQUIREMENTS**

- A. Provide all cables and connectors to connect the radio to the antenna. Provide flexible jumper cables with appropriate connectors within panels to connect the radio to the surge suppressor. Attenuation including connectors from the radio to the surge suppressor shall not exceed 0.25 dB.
- B. Provide weatherproof connections that are suitable for direct environmental exposure. Weatherproof connections shall include heat shrink tubing that provides a waterproof and corrosion resistant seal. The heat shrink tubing shall be polyolefin lined with thermoplastic adhesive as manufactured by 3M, or equal. Heat shrink tubing shall be provided for all RF transmission cable connections located outside of panels or air conditioned rooms.
- C. Utilize appropriate bulkhead RF transmission cable surge suppression devices at cable entrances, Polyphaser or equivalent.

#### **2.05 CELLULAR ROUTER MANAGEMENT SOFTWARE**

- A. Cellular router management software shall be provided to view each radio's cellular latency, dropped signal, link activation, signal strength, network traffic conditions, alarms, notifications and configuration data remotely from a Microsoft Windows computer connected to any node on the network.
- B. The software shall allow for remote cellular router firmware updates.
- C. The software shall obtain the data unobtrusively without affecting the transmission of wireless communication data. The software shall allow viewing the data from multiple cellular routers simultaneously in a user friendly graphical format. The software shall log the data and allow viewing of historical data on graphical charts. The network

management software shall be Digi Remote manager or equivalent from the manufacturer of the supplied cellular routers.

- D. The cellular router management software shall be installed on a network connected workstation or server, supplied by the Owner. Provide the required software license to allow continuous operation with all cellular routers connected, plus 10 future cellular routers on each telemetry system. Software license shall be registered in the Owner's name.

## **PART 3 – EXECUTION**

### **3.01 CELLULAR ROUTER TESTING**

- A. After the cellular routers have been installed, the Contractor shall test the following items and make all necessary adjustments to maximum performance of the communication links:
  - 1. Signal strength
  - 2. Cellular protocol mode (LTE, 4G, 3G, etc.)
  - 3. Standing wave ratio (SWR)
  - 4. Radio temperature
  - 5. Software revision
  - 6. Hardware revision
- B. The Contractor shall test the integrity of the antenna cable after installation to ensure that the insertion losses do not exceed 2.0 dBs.
- C. Prior to the PLC panel Factory Acceptance Test, the I&C subcontractor shall request and receive one activated SIM card from the Owner and coordinate with the Owner to establish communications with the City SCADA system. During the test the I&C subcontractor shall demonstrate internet to M2M (machine to machine) cellular internet connectivity with the City SCADA System.
- D. The Contractor shall submit all test results of the above-described test for approval by the Engineer. The Contractor shall provide a copy of the approved test results in the final O&M Manuals.

### **3.02 WARRANTY**

- A. Cellular routers shall be furnished with a minimum 5-year manufacturer's warranty. The warranty shall cover hardware and software provided by the manufacturer.
- B. The warranty period shall begin upon Final Acceptance as described in Part 3 of Section 40 61 21.73.

**END OF SECTION**

THIS PAGE INTENTIONALLY LEFT BLANK