

**Indian River County  
Purchasing Division  
1800 27<sup>th</sup> Street  
Vero Beach, FL 32960  
Phone (772) 226-1416**



---

## **ADDENDUM NO. 5**

Date: **October 25, 2019**

Project Name: **SR 60 and 43<sup>rd</sup> AVENUE INTERSECTION IMPROVEMENTS  
(IRC-0853)**

Bid Number: **2019073**

Bid Opening Date: **Wednesday, October 30, 2019 at 2:00 p.m.**

This addendum is released to answer the following questions and to update the Itemized Bid Schedule as shown in Question 2. All information provided herein is hereby incorporated into the bid documents.

**Question 1.** Does all the survey work and layouts need to be performed by Florida Registered Surveyor?

**Answer 1.** *While a Florida Registered Surveyor is required to establish horizontal and vertical control as well as Record Drawings, it is not required for general construction layout activities.*

**Question 2.** On the Addendum #3 Bid Form, there is a Pay Item with an incorrect quantity. See below:  
**Item # 0660 4 11 Vehicle Detection (F&I) (Video) (Cabinet Equipment)** – This item has a quantity of 4 on the bid form. This item is utilized for the actual cabinet equipment (Video Controller), and not the cameras. **This item should be a quantity of 1, as is shown on Sheet T-1 and Sheet T-4.** Please revise the Bid Form to reflect the correct quantity.

**Answer 2.** **The quantity has been revised on bid item #0660 4 11 to reflect the quantity of (1)  
As shown on sheet T-1 and T-4.**

**Question 3.** In Section 01009 Special Provisions 1.1 C All salvageable material and equipment for which specific use, relocation or other disposal is not specifically noted, shall remain the property of the OWNER and shall be delivered to the OWNER at the following location: 4550 41<sup>st</sup> Street, at the CONTRACTOR's expense. Does this include asphalt millings?

**Answer 3.** **Yes, all asphalt millings on the project are to be taken to the above location.**

**Attachment:**

Revised Itemized Bid Schedule.