

OJAI UNIFIED SCHOOL DISTRICT

BID ADDENDUM NO. 3 ISSUED 10/03/2019

TO THE CONTRACT DOCUMENTS, SPECIFICATIONS AND PLANS FOR OJAI UNIFIED SCHOOL DISTRICT

DINING HALL AND KITCHEN (BLDG B) AT MATILIJA JUNIOR HIGH SCHOOL PROJECT NO. 2019-1604

NOTE: ALL PLANS, SPECIFICATIONS, AND CONTRACT DOCUMENTS REMAIN UNCHANGED EXCEPT SECTIONS OR PARTS ADDED TO, REVISED, DELETED, OR CLARIFIED BY THIS ADDENDUM. THIS ADDENDUM SHALL TAKE PRECEDENCE OVER PREVIOUSLY ISSUED ADDENDA. THE BIDDER SHALL ACKNOWLEDGE RECEIPT OF EACH ADDENDUM ON THE BID FORM TO CERTIFY THAT THE BID ADDENDUM INFORMATION WAS RECEIVED.

The following additions, modifications, corrections, deletions and clarifications are hereby made to the Contract Documents of the subject Project and constitute **Addendum Number 3**. This Addendum is hereby incorporated into the contract documents by reference.

I. GENERAL INFORMATION

Contract Documents


No revisions.

II. REVISED SPECIFICATIONS AND DRAWINGS

Specifications (revisions are *italicized*)

DINING HALL & KITCHEN (BUILDING B)
AT MATILIJA JUNIOR HIGH SCHOOL
PROJECT NO 2019-1604

ADDENDUM NO. 3



Item 01 **Specification 051200 – Structural Steel Framing**, Section 1.7 is revised as follows:


A. Fabricator Qualifications: A qualified fabricator shall have a minimum of five year experience in similar types of fabrication, and participated in the AISC Quality Certification Program and is *either* designated an AISC-Certified Plant, Category STD, is an LA City Certified Fabricator, *or is an AWS Certified Welding Fabricator.*

B. Drawings

No revisions.

END OF **BID ADDENDUM NO. 3** ISSUED 10/03/2019

---- Revised documents attached at end. ----




RESPONSES TO REQUESTS FOR INFORMATION

No.	QUESTION	RESPONSE	RESPONSE BY
30	Provide the location of the completion time, start and end date.	This information can be found in the Formal Bid Docs, Item 3 of AGREEMENT FOR CONSTRUCTION SERVICES.	RNT
31	<p>Please consider either option below as a substitution for the AISC qualification.</p> <p>Option 1: Is it acceptable to allow a structural steel fabricator with an American Welding Society (CWF Certification) in lieu of the AISC Certification as noted in the bid documents to bid the Matilija Dining Hall Project. The Certified Welding Fabricator Certification recognizes select companies and employees who prove they have the resources, procedures, and personnel to apply a quality management system to welding fabrication activities.</p> <p>Option 2: Is it acceptable to allow a structural steel fabricator with the following company qualifications:</p> <ul style="list-style-type: none"> The structural steel subcontractor has 10+ years' experience with similar projects. The structural steel subcontractor has developed a Quality 	<p>Due to limited local availability of structural steel fabricators and rigorous requirements of the AWS certification, AWS Certified Welding Fabricator certification is additionally acceptable as a qualification for the structural steel fabricator. Option 1 is acceptable. Option 2 is not acceptable. Refer to Addendum 3, Item 01.</p>	RNT

DINING HALL & KITCHEN (BUILDING B)
 AT MATILIJA JUNIOR HIGH SCHOOL
 PROJECT NO 2019-1604

ADDENDUM NO. 3



Control manual using AWS
D1.1, AISC, ASTM
standards.

- The structural steel subcontractor has a material control program demonstrating how different grade steels are identified.
- The structural steel subcontractor has previously passed inspections on similar projects by a certified AISC Inspector.