

ADDENDUM NUMBER 1

April 19, 2022

To The Request For Pricing

Electronic Message Board Construction
PW22-0015

To Request For Pricing (RFP) Packet Holders:

This Addendum Number 1 to the above referenced RFP is controlling over any other provisions of the RFP Document to the contrary. This addendum shall be considered a material part of the RFP.

This addendum includes a clarification of the following question submitted by a registrant:

Question: Listed on the Firm Price Quote sheet on page 42 of the packet, lines #7 and #8 request pricing for 770 LF of trenching, backfill, and installation of city supplied conduit and 3050 LF of #6 electrical conductors. However, on page 51 the sign specifications state that the city will provide power within 3' of each sign location. Please clarify whether the city will be responsible for this scope or us, the sign contractor.

Answer: Registrants will disregard the specification on page 51. The City of Kingman will not provide power within 3' of each location. It will be contractor's responsibility to provide trenching and power to the nearest known power site.

Offerors must acknowledge receipt of this addendum in the SOP PROPOSAL.