



Springfield Electric Department  
Wood Pole Specification  
(Revised 1-30-2014)

General Specifications:

- (1) All poles to be Southern yellow pine, ASA Class and length shall be as specified in the accompanying purchase order.
- (2) All poles shall meet the latest revision of ANSI 05.1 and ANPA standards for treatment of .60 lbs/cu.ft.
- (3) All poles shall be treated as specified in bid invitation.
- (4) All poles shall be inspected (unless otherwise specified).
- (5) All poles shall be shipped by truck unless otherwise specified, based on a full truckload of 800 ft<sup>3</sup>. DO NOT ADJUST POLE QUANTITIES OR SIZES.
- (6) Specify delivery date with bid. All vendors are expected to meet delivery date specified. Orders that do not meet delivery will be subject to cancellation.
- (7) Include unloading cost with bid.