



Opportunity in every direction.

Office of the Purchasing Director

---

TO: ALL VENDORS  
FROM: LINDA E. JONES, CPPB  
DATE: November 29, 2021  
RE: Request for Bid

The City of Waycross, Georgia will receive sealed bids until 10:00 a.m., Thursday  
December 16, 2021

---

For : Complete SCBA Fill Station

---

As specified in the attached specifications.

The city reserves the right to accept or reject any or all bids, to waive formalities and technicalities, to make an award in the best interest of the City and to make an award item by item or as a whole. Bidder must comply with all Federal, State and Local Laws.

Factors to be considered in making this award, if awarded, will be prices, availability and quality. The City will be the sole judge of the weights given these factors.

Bids will be opened and read aloud in the conference room at City Hall, on the second floor – 417 Pendleton Street, Waycross, Georgia, on the hour and date specified above. No bids will be accepted after bid opening time. No faxed or emailed bids will be accepted.

**BIDS SHOULD BE MAILED TO: CITY OF WAYCROSS, PURCHASING DIRECTOR  
P. O. DRAWER 99  
WAYCROSS, GEORGIA 31502-0099**

**OR HAND DELIVERED TO: CITY HALL – PURCHASING DEPARTMENT  
(PRIOR TO OPENING) 417 PENDLETON STREET, ROOM 201  
WAYCROSS, GEORGIA 31501**

**BID ENVELOPE SHOULD BE MARKED: Bid #** FY 22-23 SCBA Fill Station

---

The city has provided a quote sheet for your convenience. All blank spaces shall be completed and returned with your bid package. Prices quoted shall be firm prices and remain firm until delivery is made. If awarded, the City will place an order with the successful bidder within 60 (sixty) days after bid opening. Price to remain firm for 60 days.



**CITY OF WAYCROSS  
REQUEST FOR BID  
FIRE SCBA FILL STATION  
FY22-23  
November 22, 2021**

**GENERAL**

The City of Waycross will be accepting sealed bids from Fire Equipment Vendors for the purchase of a new SCBA Fill Station for the City of Waycross Fire Department. Bids will be accepted until **10:00 a.m., Thursday, December 16, 2021**. Envelope must be sealed and marked Bid # FY22-23.

The City of Waycross does not accept late, faxed or emailed bids.

**Product Description**

**Required minimum Specifications** - System must be complete to successfully fill 2 SCBA cylinders at one time.

- 6000 psi system

**Product Description**

**Containment Fill Station**

- 2 SCBA cylinder containment fill station with control panel.
- Separate controls for each cylinder being filled.
- NFPA 1901 compliant
- Four inlet connectors from cascade
- Fill hoses include a bleed valve and SCBA fill adapter
- Venting at back and bottom for operator safety
- 4 bank cascade controls
- 2 1/2" gauges for: each cascade cylinder and fill positions
- 1 inlet connector from compressor.
- 1 auxiliary outlet with valve

### **Enclosed Compressor**

- 240 Volt, three-phase operation enclosed compressor system
- 7.5 HP minimum - 10 HP maximum
- CO Monitor
- Low oil level shutdown
- High temperature indicator and/or shutdown
- Moisture and Carbon visual indicators
- Liquid filled inter-stage gauges
- Hour meter
- Auto drain system
- All NFPA required filtration and purification systems

### **Storage Cylinders**

- (4) - 6000 psi UN/DOT Storage Cylinders and gauges
- All required hoses, couplings, elbows, fittings, etc to make entire system operational. (Please identify/specify these in bids sheets)
- Storage cylinder rack

### **STANDARD INSTRUCTIONS:**

1. All warranties must be listed and included with bid.
2. Bid must include training in use of equipment.
3. List any accessories that are standard to the unit.
4. Complete specifications and pictures of unit must be included in bid.
5. Include 5 references of business currently using this equipment with contact name, number and location of equipment.
6. Price shall include delivery.
7. Request for Quote sheet has been included and must be completed and returned with bid.
8. If any of the above specifications are not met, bidder must list these items separately on a sheet of paper and reference specification number and reason for not meeting specification.
9. Expected Delivery time frame if awarded project.
10. Bids must include installation and pricing in bid.
11. Does company offer annual maintenance? Pricing? Detail any offerings on a separate page.
12. Price to remain firm for 60 days.

