

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Stephen Russell	<b>Date:</b> 2018-01-12
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 1 of

**General Location:** 8 N. Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> P.E.	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b> Washington Gas

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b> 2"	<b>Material:</b> Steel	<b>See Test Hole No.:</b>
<b>Utility Type:</b> Electric Conduit		<b>Utility Owner:</b> Dominion

### SITE CONDITIONS

<b>Field Condition:</b> Grass Area	<b>Pavement thickness:</b>
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> 60 D Nail	<b>Elevation:</b> 215.45'
<b>Offset/Direction:</b> Nail is set C/L of the Configuration.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>See Notes</u> <b>Elevation:</b>
	<b>Bottom of utility field measurement:</b> <b>Elevation:</b>

<b>Facing:</b> Northwest	<b>Utility Width/Spacing:</b> 12"
--------------------------	-----------------------------------

### PLAN VIEW

### COORDINATES

	<b>Northing:</b> <b>Easting:</b>  <b>COMMENTS/NOTES</b> A = 1.11' to the top and carries an elevation of 214.34' (2" Steel) B = 2.43' to the top and carries an elevation of 213.02' (2 1/2" P.E.)
---	---

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Yassin Aloumouati	<b>Date:</b> 2018-01-12
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 2 of

**General Location:** 32 N. Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> Epoxy Coated Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line	<b>Utility Owner:</b> Washington Gas	

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None	<b>Utility Owner:</b>	

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Area	<b>Pavement thickness:</b> 10"
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 220.79'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>3.86'</u> <b>Elevation:</b> <u>216.93'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<b>Northing:</b>  <b>Easting:</b>  <b>COMMENTS/NOTES</b>
---	--

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Yassin Aloumouati	<b>Date:</b> 2018-01-12
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 3 of

**General Location:** 118 N. Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> Epoxy Coated Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b> Washington Gas

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Area	<b>Pavement thickness:</b> 10"
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 228.41'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>4.22'</u> <b>Elevation:</b> <u>224.19'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<table border="1"> <tr> <td><b>Northing:</b></td> <td><b>Easting:</b></td> </tr> <tr> <td colspan="2" style="text-align: center;"><b>COMMENTS/NOTES</b></td> </tr> </table>	<b>Northing:</b>	<b>Easting:</b>	<b>COMMENTS/NOTES</b>	
<b>Northing:</b>	<b>Easting:</b>				
<b>COMMENTS/NOTES</b>					

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Yassin Aloumouati	<b>Date:</b> 2018-01-12
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 4 of

**General Location:** N. Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> Epoxy Coated Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b> Washington Gas

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Area	<b>Pavement thickness:</b> 10"
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 234.67'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>3.65'</u> <b>Elevation:</b> <u>231.02'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<p><b>Northing:</b></p> <p><b>Easting:</b></p> <p><b>COMMENTS/NOTES</b></p>
---	---

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Yassin Aloumouati	<b>Date:</b> 2018-01-12
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 5 of

**General Location:** N. Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 3 1/2"	<b>Material:</b> PVC	<b>Good Condition:</b> YES
<b>Utility Type:</b> Electric Conduit		<b>Utility Owner:</b> Dominion

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b>		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Grass Area	<b>Pavement thickness:</b>
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 243.30'
<b>Offset/Direction:</b> Nail is set C/L of the Configuration.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>1.37'</u> <b>Elevation:</b> <u>241.93'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<table border="1"> <tr> <td><b>Northing:</b></td> <td><b>Easting:</b></td> </tr> <tr> <td colspan="2" style="text-align: center;"><b><u>COMMENTS/NOTES</u></b></td> </tr> </table>	<b>Northing:</b>	<b>Easting:</b>	<b><u>COMMENTS/NOTES</u></b>	
<b>Northing:</b>	<b>Easting:</b>				
<b><u>COMMENTS/NOTES</u></b>					

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Yassin Aloumouati	<b>Date:</b> 2018-01-12
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 6 of

**General Location:** N. Oakland St. and N Pershing St.

### UTILITY INFORMATION

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> Epoxy Coated Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b> Washington Gas

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Area	<b>Pavement thickness:</b> 10"
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 244.14'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>3.41'</u> <b>Elevation:</b> <u>240.73'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<table border="1"> <tr> <td><b>Northing:</b></td> <td><b>Easting:</b></td> </tr> <tr> <td colspan="2" style="text-align: center;"><b>COMMENTS/NOTES</b></td> </tr> </table>	<b>Northing:</b>	<b>Easting:</b>	<b>COMMENTS/NOTES</b>	
<b>Northing:</b>	<b>Easting:</b>				
<b>COMMENTS/NOTES</b>					

# TEST HOLE FORM

4501 DALY DRIVE | CHANTILLY, VA 20151 | 703.378.0100 | WWW.MIDATLANTICLOCATING.COM

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Yassin Aloumouati	<b>Date:</b> 2018-01-12
---	---------------------------------------	-------------------------

<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 7 of
------------------------	------------------	------------------------

**General Location:** N. Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 4 1/2"	<b>Material:</b> PVC	<b>Good Condition:</b> YES
-----------------------------	----------------------	----------------------------

<b>Utility Type:</b> Communication Conduit	<b>Utility Owner:</b>
--	-----------------------

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
----------------------	------------------	---------------------------

<b>Utility Type:</b> None	<b>Utility Owner:</b>
---------------------------	-----------------------

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Area	<b>Pavement thickness:</b> 6" / 5" Concrete
--------------------------------------	---

<b>Ground Condition:</b> Brown Soil
-------------------------------------

### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
-----------------------	-----------------------------------

<b>BM Check:</b>
------------------

<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
-----------------------	-----------------------------------


<b>Elevation Datum:</b>
-------------------------

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 244.49'
---------------------------	---------------------------

<b>Offset/Direction:</b> Nail is set C/L of the Utility.
--

### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>2.10'</u> <b>Elevation:</b> <u>242.39'</u>  <b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>
---	---

<b>Facing:</b> East	<b>Utility Width/Spacing:</b>
---------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<table border="0"> <tr> <td style="width: 50%;"><b>Northing:</b></td> <td style="width: 50%;"><b>Easting:</b></td> </tr> <tr> <td colspan="2" style="text-align: center;"><b>COMMENTS/NOTES</b></td> </tr> </table>	<b>Northing:</b>	<b>Easting:</b>	<b>COMMENTS/NOTES</b>	
<b>Northing:</b>	<b>Easting:</b>				
<b>COMMENTS/NOTES</b>					

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-02
---	--------------------------------	-------------------------

<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 10 of
------------------------	------------------	-------------------------

**General Location:** Pershing and N. Oakland St

### UTILITY INFORMATION

<b>Utility Size:</b> 1 1/4"	<b>Material:</b> Rubber Jacketed	<b>Good Condition:</b> YES
-----------------------------	----------------------------------	----------------------------

<b>Utility Type:</b> Communication Cable	<b>Utility Owner:</b>
--	-----------------------

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
----------------------	------------------	---------------------------

<b>Utility Type:</b> None	<b>Utility Owner:</b>
---------------------------	-----------------------

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 9"
--------------------------------------	-------------------------------

**Ground Condition:** Brown Soil

### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
-------------------------------	---------------------------------------

**BM Check:** -0.04'

<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
-------------------------------	---


**Elevation Datum:**

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 241.37'
---------------------------	---------------------------

**Offset/Direction:** Nail is set C/L of the Utility.


### PROFILE VIEW

	<p><b>Top of utility field measurement:</b> <u>4.74'</u>      <b>Elevation:</b> <u>236.63'</u></p> <p><b>Bottom of utility field measurement:</b> <u>None</u>      <b>Elevation:</b> <u>None</u></p>
---	--

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<p><b>Northing:</b>      <b>Easting:</b></p> <p style="text-align: center;"><b><u>COMMENTS/NOTES</u></b></p> <p>Crew notes that the communication line was between wood.</p>
---	--



<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Robb Lloyd	<b>Date:</b> 2018-04-04
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 11 of

**General Location:** 3208 Pershing Dr

### UTILITY INFORMATION

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> Epoxy Coated Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b>

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Rd	<b>Pavement thickness:</b> 10 1/2" Asphalt
<b>Ground Condition:</b> Brown Dirt	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
<b>BM Check:</b> -0.04'	
<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 240.46'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>3.35'</u> <b>Elevation:</b> <u>237.11'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<b>Northing:</b> _____ <b>Easting:</b> _____ <b>COMMENTS/NOTES</b>
---	--

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Robb Lloyd	<b>Date:</b> 2018-04-04
---	--------------------------------	-------------------------

<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 12 of
------------------------	------------------	-------------------------

**General Location:** 227 N. Oakland St.

**UTILITY INFORMATION**

<b>Utility Size:</b> 1"	<b>Material:</b> Paper Wrapped Steel	<b>Good Condition:</b> YES
-------------------------	--------------------------------------	----------------------------

<b>Utility Type:</b> Gas Line	<b>Utility Owner:</b>
-------------------------------	-----------------------

**ADDITIONAL UTILITY INFORMATION**

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
----------------------	------------------	---------------------------

<b>Utility Type:</b> None	<b>Utility Owner:</b>
---------------------------	-----------------------

**SITE CONDITIONS**

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 6 1/2"
--------------------------------------	-----------------------------------

**Ground Condition:** Brown Dirt/Clay

**FIRST & SECOND BENCHMARK INFORMATION**

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
-------------------------------	---------------------------------------

**BM Check:** -0.04'

<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
-------------------------------	---


**Elevation Datum:**

**FIELD MARKER INFORMATION**

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 239.46'
---------------------------	---------------------------


**Offset/Direction:** Nail is set C/L of the Utility.

**PROFILE VIEW**

	<p><b>Top of utility field measurement:</b> <u>2.78'</u>      <b>Elevation:</b> <u>236.68'</u></p> <p><b>Bottom of utility field measurement:</b> <u>None</u>      <b>Elevation:</b> <u>None</u></p>
---	--

<b>Facing:</b> East	<b>Utility Width/Spacing:</b>
---------------------	-------------------------------

**PLAN VIEW      COORDINATES**

	<p><b>Northing:</b>      <b>Easting:</b></p> <p style="text-align: center;"><b><u>COMMENTS/NOTES</u></b></p>
---	--

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Robb Lloyd	<b>Date:</b> 2018-04-04
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 13 of

**General Location:** 223 N. Oakland St

### UTILITY INFORMATION

<b>Utility Size:</b> 1 1/4"	<b>Material:</b> Paper Wrapped Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b>

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 7"
<b>Ground Condition:</b> Brown Dirt	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
<b>BM Check:</b> -0.04'	
<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 237.64'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>2.54'</u> <b>Elevation:</b> <u>235.10'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> West	<b>Utility Width/Spacing:</b>
---------------------	-------------------------------

### PLAN VIEW

### COORDINATES

 <p>N. Oakland. St.</p>	<table border="1"> <tr> <td><b>Northing:</b></td> <td><b>Easting:</b></td> </tr> <tr> <td colspan="2" style="text-align: center;"><b>COMMENTS/NOTES</b></td> </tr> </table>	<b>Northing:</b>	<b>Easting:</b>	<b>COMMENTS/NOTES</b>	
<b>Northing:</b>	<b>Easting:</b>				
<b>COMMENTS/NOTES</b>					

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-05
---	--------------------------------	-------------------------

<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 14 of
------------------------	------------------	-------------------------

**General Location:** 207 N Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 1 1/4"	<b>Material:</b> Paper Wrapped Steel	<b>Good Condition:</b> YES
-----------------------------	--------------------------------------	----------------------------

<b>Utility Type:</b> Gas Line	<b>Utility Owner:</b> Washington Gas
-------------------------------	--------------------------------------

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
----------------------	------------------	---------------------------

<b>Utility Type:</b> None	<b>Utility Owner:</b>
---------------------------	-----------------------

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 7"
--------------------------------------	-------------------------------

**Ground Condition:** Brown soil

### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
-------------------------------	---------------------------------------

**BM Check:** -0.04'

<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
-------------------------------	---


**Elevation Datum:**

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 243.06'
---------------------------	---------------------------

**Offset/Direction:** Nail is set C/L of the Utility.


### PROFILE VIEW

	<p><b>Top of utility field measurement:</b> <u>2.50'</u>      <b>Elevation:</b> <u>240.56'</u></p> <p><b>Bottom of utility field measurement:</b> <u>None</u>      <b>Elevation:</b> <u>None</u></p>
---	--

<b>Facing:</b> West	<b>Utility Width/Spacing:</b>
---------------------	-------------------------------

### PLAN VIEW

### COORDINATES

 <p>N. Oakland St.</p>	<p><b>Northing:</b></p> <p><b>Easting:</b></p> <p><b>COMMENTS/NOTES</b></p>
---	---

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-05
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 15 of

**General Location:** 133 N Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 1 1/4"	<b>Material:</b> Paper Wrapped Steel	<b>Good Condition:</b> YES
<b>Utility Type:</b> Gas Line		<b>Utility Owner:</b>

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 7"
<b>Ground Condition:</b> Brown Soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
<b>BM Check:</b> -0.04'	
<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 231.29'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>2.32'</u> <b>Elevation:</b> <u>228.97'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> West	<b>Utility Width/Spacing:</b>
---------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<p><b>Northing:</b></p> <p><b>Easting:</b></p> <p><b>COMMENTS/NOTES</b></p>
--	---

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-05
---	--------------------------------	-------------------------

<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 16 of
------------------------	------------------	-------------------------

**General Location:** 129 N Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 1/2"	<b>Material:</b> P.E.	<b>Good Condition:</b> YES
---------------------------	-----------------------	----------------------------

<b>Utility Type:</b> Gas Line	<b>Utility Owner:</b>
-------------------------------	-----------------------

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
----------------------	------------------	---------------------------

<b>Utility Type:</b> None	<b>Utility Owner:</b>
---------------------------	-----------------------

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 8"
--------------------------------------	-------------------------------

**Ground Condition:** Brown soil

### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
-------------------------------	---------------------------------------

**BM Check:** -0.04'

<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
-------------------------------	---


**Elevation Datum:**

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 230.76'
---------------------------	---------------------------

**Offset/Direction:** Nail is set C/L of the Utility.


### PROFILE VIEW

	<p><b>Top of utility field measurement:</b> <u>3.33'</u>      <b>Elevation:</b> <u>227.43'</u></p> <p><b>Bottom of utility field measurement:</b> <u>None</u>      <b>Elevation:</b> <u>None</u></p>
---	--

<b>Facing:</b> West	<b>Utility Width/Spacing:</b>
---------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<p><b>Northing:</b></p> <p><b>Easting:</b></p> <p><b>COMMENTS/NOTES</b></p>
---	---

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-05
---	--------------------------------	-------------------------

<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 17 of
------------------------	------------------	-------------------------

**General Location:** 130 N Oakland St.

**UTILITY INFORMATION**

<b>Utility Size:</b> 2 1/2"	<b>Material:</b> Epoxy Coated Steel	<b>Good Condition:</b> YES
-----------------------------	-------------------------------------	----------------------------

<b>Utility Type:</b> Gas Line	<b>Utility Owner:</b>
-------------------------------	-----------------------

**ADDITIONAL UTILITY INFORMATION**

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
----------------------	------------------	---------------------------

<b>Utility Type:</b> None	<b>Utility Owner:</b>
---------------------------	-----------------------

**SITE CONDITIONS**

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 11"
--------------------------------------	--------------------------------

**Ground Condition:** Brown soil

**FIRST & SECOND BENCHMARK INFORMATION**

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
-----------------------	-----------------------------------

**BM Check:**

<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
-----------------------	-----------------------------------


**Elevation Datum:**

**FIELD MARKER INFORMATION**

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 230.22'
---------------------------	---------------------------


**Offset/Direction:** Nail is set C/L of the Utility.

**PROFILE VIEW**

	<p><b>Top of utility field measurement:</b> <u>4.51'</u>      <b>Elevation:</b> <u>225.71'</u></p> <p><b>Bottom of utility field measurement:</b> <u>None</u>      <b>Elevation:</b> <u>None</u></p>
---	--

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

**PLAN VIEW      COORDINATES**

	<p><b>Northing:</b></p> <p><b>Easting:</b></p> <p style="text-align: center;"><b><u>COMMENTS/NOTES</u></b></p>
---	--

<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-05
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 18 of

**General Location:** 210 N Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 6 1/2 "	<b>Material:</b> Cast Iron	<b>Good Condition:</b> YES
<b>Utility Type:</b> Water Line		<b>Utility Owner:</b>

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 5"
<b>Ground Condition:</b> Brown soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b> 220.06'	<b>1st Benchmark Description:</b> 580
<b>BM Check:</b> -0.04'	
<b>2nd Elevation:</b> 243.39'	<b>2nd Benchmark Description:</b> 11997
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 235.19'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>2.41'</u> <b>Elevation:</b> <u>232.78'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<table border="1"> <tr> <td><b>Northing:</b></td> <td><b>Easting:</b></td> </tr> <tr> <td colspan="2" style="text-align: center;"><b><u>COMMENTS/NOTES</u></b></td> </tr> </table>	<b>Northing:</b>	<b>Easting:</b>	<b><u>COMMENTS/NOTES</u></b>	
<b>Northing:</b>	<b>Easting:</b>				
<b><u>COMMENTS/NOTES</u></b>					



<b>Project:</b> M-0618-0201-5302 ( N. Oakland & N. Pershing )	<b>Prepared By:</b> Cody Brown	<b>Date:</b> 2018-04-06
<b>City:</b> Arlington	<b>State:</b> VA	<b>Test Hole:</b> 19 of

**General Location:** 40 N Oakland St.

### UTILITY INFORMATION

<b>Utility Size:</b> 6 1/2"	<b>Material:</b> Cast Iron	<b>Good Condition:</b> YES
<b>Utility Type:</b> Water Line		<b>Utility Owner:</b>

### ADDITIONAL UTILITY INFORMATION

<b>Utility Size:</b>	<b>Material:</b>	<b>See Test Hole No.:</b>
<b>Utility Type:</b> None		<b>Utility Owner:</b>

### SITE CONDITIONS

<b>Field Condition:</b> Asphalt Road	<b>Pavement thickness:</b> 8"
<b>Ground Condition:</b> Brown soil	


### FIRST & SECOND BENCHMARK INFORMATION

<b>1st Elevation:</b>	<b>1st Benchmark Description:</b>
<b>BM Check:</b>	
<b>2nd Elevation:</b>	<b>2nd Benchmark Description:</b>
<b>Elevation Datum:</b>	

### FIELD MARKER INFORMATION

<b>Type set:</b> Mag Nail	<b>Elevation:</b> 222.36'
<b>Offset/Direction:</b> Nail is set C/L of the Utility.	


### PROFILE VIEW

	<b>Top of utility field measurement:</b> <u>4.14'</u> <b>Elevation:</b> <u>218.22'</u>
	<b>Bottom of utility field measurement:</b> <u>None</u> <b>Elevation:</b> <u>None</u>

<b>Facing:</b> North	<b>Utility Width/Spacing:</b>
----------------------	-------------------------------

### PLAN VIEW

### COORDINATES

	<b>Northing:</b> _____ <b>Easting:</b> _____ <b>COMMENTS/NOTES</b>
---	--