



## ADDENDUM NO. 2

Issue Date: July 23, 2024

Project Name: Gifford Aquatic Center Slide Replacement

RFP Number: 2024054

RFP Opening Date: July 26, 2024

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the request for proposals.

### Questions and Answers

1.	What size is 34 sf x 34 sf? Do you mean 34' x34'?
	<b>Yes, 34' x 34' is correct.</b>
2.	What length should the slides be?
	<b>The length is up to the Contractor.</b>
3.	Water source for an enclosed slide is typically much higher at 300 GPM? Please confirm a cap on the water usage @ 15-25 gallons?
	<b>Correct, the GPM is 15-25.</b>
4.	FRP treads are a much better choice than aluminum. Can the contractor use FRP treads?
	<b>We want the stairs to be Aluminum, but the tread can be a different material.</b>
5.	Can you please supply an as-built of the existing foundations?
	<b>We cannot locate any as-built's for the slides that are currently on site.</b>