



**CITY OF CALLAWAY  
GORE PARK BUILDING WORK  
BID NO.: LS2022-06**

**ADDENDUM #1**

Date Issued: February 22, 2022

This addendum is being released to address the following questions:

1. Would the City of Callaway accept an equal to for the 2 pavilions in steel in lieu of wood?

**No, but we may consider an alternate post bid from the successful bidder. This should be included in the bid packet in a separate envelope labeled "Alternate Bid."**

2. It looks like we have to hold price for 90 days. Considering the market right now, is there any way this could be reduced to 30 days?

**The price shall be held for a period of 60 days in lieu of 90 days.**

3. Are pole barn trusses to be wood or metal? Plans say both.

**Trusses shall be metal and shall be hot dipped galvanized.**

4. Is roof metal to be standing seam or R-panel? **Standing Seam.**

5. Are all wood purlins and/or trusses to be PT. **Yes**

6. All exposed wood to be painted. Does this mean purlins and trusses also? **Yes.**

7. Metal trusses are to be Galvanized? Very expensive.

**Yes. It is not that expensive to hot dip galv. the trusses. Probably \$5,000 and it will make them last 20 years longer.**

  
Janice L. Peters, City Clerk

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date