

Ojai Unified School District

414 East Ojai Avenue, P.O. Box 878, Ojai, CA 93024 (805) 640-4300 • Fax (805) 640-4419 • www.ojaiusd.org

April 9, 2020

## Addendum #2

**RESPONSES TO REQUESTS FOR INFORMATION:** 

1) Now that we have the plans you sent, may I count on the "Reflected Ceiling" plans to accurately reflect the sizes and counts of the lighting fixtures? OUSD Response: The count should be correct. The make and model could be different.

2) Which bathrooms had no electrical available for the hand dryers that we spoke about on site? OUSD Response: Please assume there is no power in place for buildings A, B & D. Buildings A and B will likely require more finishing work since we are less invasive in those areas.

3) Do we have any specs called out for the Back pack hooks?(Color, style, ??). OUSD Response: No spec. A stainless dual coat hook will do. Should match new switch plates.

4) Bobrick lists a 24" x 60" as their longest standard size mirror. Will that suffice for the "FULL LENGTH" callout in the specs, or do I need to go more custom than that? Also, what size are we to bid out for the other mirrors not listed as "full length"? 18" x 24", 30, 36 or 24" x30 / 36 are a few choices.

OUSD Response: Full length mirrors should be 24"x72". This is not on the cut sheet, but is an option in the B-165 model. All over the sink mirrors should match existing or appropriately fit the space.

5) Do you have a location in mind where we can store all the fixtures that will be removed in order to facilitate tile repairs etc.? (Sinks and Toilets and mirrors etc that have to come off the walls), or should we provide a container to do so?

OUSD Response: While we certainly have space on-site, it would probably be best and easier to arrange for a container to be placed in a convenient location.

6) "Replace Damaged Signage": Should I be replacing faded signage or just really beat up signage?

OUSD Response: As discussed on the job walk, only missing or broken sign are to be replaced.

The Heart and Future of the Community.