



THE LOCUST PROJECT
The Design Office of
Michael Jones

Memorandum

Project: PW 2022-08 Kingsbury-OHB Entry Improvements

Wednesday, September 12, 2022

Page 1 of 1

To: All Bidders

From: Michael C. Jones, LAR

Re: **ADDENDUM #1**

Project: PW 2022-08 Kingsbury-OHB Entry Improvements

This addendum is for construction proposals due on September 15, 2022, at 10:00 A.M. (CST) at the City of Forest Hills, 6300 Hillsboro Pike, Nashville, TN 37215.

This addendum must be signed and submitted with the bid documents for this project. This addendum will clarify the following:

Clarification:

Guard Rail Refinishing – All paint, primer and final 2 coats may be applied by spraying in lieu of brush applied as noted on Sheet LC1.1 (Refer to specific notes for “GAURD RAIL REFINISHING NOTES.”)

The contractor will be responsible for containment to prevent overspray of paint onto surrounding areas and passing vehicles. This also applies to brush applied painting and/or the combination of brush and spray application. The contractor will provide the containment plan and contingency plan for cleanup to the city prior to beginning work.

Date

Contractor Signature

COMPANY: _____

ADDRESS: _____

*******ADDENDUM TO BE INCLUDED WITH BID FORMS*******

Addendum #1 PW 2022-08 Kingsbury-OHB Entry Improvements