## BOARD OF COMMISSIONERS

Meetings Second Tuesday

MARTIN H. MOSELEY, JR. Chairman

> WALTER SMITH Vice-Chairman

BETTY C. HILL

ROY LEWIS

WADE YODER

MARCIA W. JOHNSON County Administrator

APRIL H. HODGES County Clerk



213 Persons Street Fort Valley, Georgia 31030 Phone 478-825-2535 Fax 478-825-2678

## **COUNTY OFFICIALS**

KIM WILSON Probate Judge

JOE WILDER Clerk of Superior Court

> TERRY DEESE Sheriff

W. L. BROWN Tax Commissioner

KERRY ROOKS Coroner

LAURENS C. LEE Magistrate

RFB: 18-008 Addendum #1 June 8, 2018

Purpose: Address Written Questions

- 1. Who is responsible for the electrical upgrades for the 20 K.W. heat strips and the 10-ton outdoor unit?
- 2. Should we change the scope and specifications for the 10-ton unit from a 20 KW heat strip to a 10 KW heat strip?

Answer – Change the scope of work and the specifications on the 10-ton unit to require 10 KW heat strips instead of the 20 KW heat strips.

3. Are the supplied thermostats already in use and integrated into the system?

## Answer – The units must operate via the existing thermostats. The controls vendor is Mallory and Evans in Clarkston, Ga.

4. Would (2) 5-ton condensing units be allowed instead of (1) 10-ton unit?

Answer - (2) 5-ton will be considered as long as (2) separate air handlers are being proposed