



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: 17-S2-2308488
APPLICATION #: AP1678141
DATE PAID: 6-3-21
FEE PAID: \$350.00
RECEIPT #: 17-PID-503135
DOCUMENT #: PR1578891

CONSTRUCTION PERMIT FOR: OSTDS Repair

APPLICANT: (Escambia county Facilities Mgt)

PROPERTY ADDRESS: 9350 Gulf Beach Hwy Pensacola, FL 32507

LOT: 018 BLOCK: 004 SUBDIVISION: METES AND BOUNDS

PROPERTY ID #: 15-3S-31-1001-018-004 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [0] GALLONS / GPD Septic CAPACITY
A [0] GALLONS / GPD CAPACITY
N [0] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @[] DOSES PER 24 HRS #Pumps []

D [550] SQUARE FEET SYSTEM

R [0] SQUARE FEET SYSTEM

A TYPE SYSTEM: [x] STANDARD [] FILLED [] MOUND []

I CONFIGURATION: [x] TRENCH [] BED []

LOCATION OF BENCHMARK: ORANGE PAINTED NAIL- TREE-NEAR N.E. LOT CORNER

ELEVATION OF PROPOSED SYSTEM SITE [43.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

BOTTOM OF DRAINFIELD TO BE [67.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [30.00] INCHES

APPROVED FOR THE ABOVE DESCRIBED DRAINFIELD REPAIR TO THE EXISTING CERTIFIED 1000 GALLON SEPTIC TANK SYSTEM. EXCAVATE TO REMOVE ALL EXISTING DRAINFIELD AND RELATED SPOIL. DISPOSE OF THE MATERIAL AS PER CODE. BACKFILL THE EXCAVATED AREA WITH CLEAN SAND TO ACHIEVE THE PERMITTED DRAINFIELD ELEVATION. INSTALL THE DRAINFIELD AS HIGH AS POSSIBLE. RELOCATE THE EXISTING WATERLINE AS NEEDED TO MAINTAIN THE REQUIRED SETBACK. INSTALL THE DRAINFIELD IN THE PREPARED AREA. INSTALL PERMANENT TRAFFIC BARRIERS AROUND THE ENTIRE SEPTIC TANK AREA. ECHD RECOMMENDS INSTALLING A GREASE INCEPTOR. REPAIR ALL INTERIOR WATER LEAKS PRIOR TO INSTALLING THE REPAIR.

SPECIFICATIONS BY: Joseph E Hardin TITLE: ESII

APPROVED BY: Joseph E Hardin TITLE: ESII Escambia CHD

DATE ISSUED: 06/07/2021 EXPIRATION DATE: 09/05/2021

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM
EXISTING SYSTEM AND SYSTEM REPAIR
EVALUATION

APPLICATION # AP1678141
PERMIT # 17-S2-2308488
DOC # RE645621

17-S2-2308488

REMARKS/ADDITIONAL CRITERIA

[Empty box for remarks/additional criteria]

SUBMITTED BY: _____ TITLE/LICENSE _____ DATE: 06/04/2021

Joseph Hardin E 000000010 (00000001

DH 4015, 08/09 (Obsoletes previous editions which may not be used)
Incorporated 64E-6.001, FAC

1" = 15'

AP1678141
9355 Golf
Beach Hwy.

[Signature]
6/7/21

Concrete Parking
and Driveway

Building

Stairs

Generator

Fuel
Tank

New drain field
550 sq ft

Existing Septic field
1000 gal. Septic Tank

New Waterline
Location

A/C

Concrete

Parking
+
Driveway

Benchmark

Back Flow
Valve

