

**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT**

INVITATION TO BID NO. 23-DES-ITB-555

ADDENDUM NO. 1

Arlington County Invitation to Bid No. 23-DES-ITB-555 for Rosslyn Ballston Corridor Improvements Phase II received the following questions:

- Please confirm that the 24" zebra crosswalk at the intersection of N. Glebe Rd. and 11th St. will be eradicated and replaced by the pavement per drawings up to the median.
 - Per construction drawing, Site B-5, sheet #11 of 13, pavement will be milled and overlaid, and "24" zebra crosswalk" will be reinstalled between the two proposed handicapped ramps on 11th St. N. There is no median on 11th St. N.
- Will Arlington County provide the VDOT LUP?
 - Yes, LUP was obtained already for B-5 and C-3 sites by the County.
- Please confirm that all tree protections are to be wood frame with plywood.
 - Confirmed, the contractor is to protect trees per DPR Design Standard 311300.14NS.
- Can you provide a website or documentation showing actual existing utilities?
 - Known utilities were designated on plans. The county's public GIS map site: <https://geocortex.arlingtonva.us/Html5Viewer/index.html?viewer=ACMaps.HTML5> can be accessed by the contractor, if desired.
- When actual conditions are different from the geotechnical report/information provided, will the contractor be entitled for additional compensation?
 - See General Conditions B.2, B.3, E.1
- Due to current supply chain issues, will the owner consider issuing a second NTP for delays due to material availability?
 - The owner will not be issuing a second NTP for delays at this time. See General Conditions F.3, G.4, G.7.
- Will the owner reimburse for existing utilities damaged if not shown on the plans?
 - See General Conditions B.2, B.3, E.1
- May we have a geotechnical report?
 - There is no geotechnical report produced for any of the sites
- Will you provide a staging area?
 - No, the scope of work for the individual sites is small enough not to warrant an individual staging area.

- Is an LUP Permit required? If so, can you provide a budget cost for the LUP Estimate so we may factor in the bond cost?
 - LUP was obtained already for B-5 and C-3 sites by the County. The Contractor should be able to estimate the value of improvements to facilitate any bonding if required by VDOT

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Lucas Alexander, VCO/A
Procurement Officer
lalexander@arlingtonva.us

RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 1.

FIRM NAME: _____

**AUTHORIZED
SIGNATURE:** _____ **DATE:** _____