

OJAI UNIFIED SCHOOL DISTRICT

BID ADDENDUM NO. 2 ISSUED 6/13/2019

TO THE CONTRACT DOCUMENTS, SPECIFICATIONS AND PLANS FOR OJAI UNIFIED SCHOOL DISTRICT

LIBRARY QUAD REMODEL AT NORDHOFF HIGH SCHOOL PROJECT NO. 2019-1714

THE BIDDER SHALL ATTACH THE ADDENDUM TO THE DOCUMENTS SUBMITTED WITH THE BID TO OJAI UNIFIED SCHOOL DISTRICT TO CERTIFY THAT THE BID ADDENDUM INFORMATION WAS RECEIVED.

BID DUE DATE: 2:00 pm (local) Friday, June 21, 2019

The following additions, modifications, corrections, deletions and clarifications are hereby made to the Contract Documents of the subject Project and constitute **Addendum Number 2**. This Addendum is hereby incorporated into the contract documents by reference.

I. GENERAL INFORMATION

A. Contract Documents

No Change.


II. REVISED SPECIFICATIONS AND DRAWINGS

A. Specifications – All Projects

No Change.

LIBRARY QUAD REMODEL
AT NORDHOFF HIGH SCHOOL
PROJECT NO 2019-1714

ADDENDUM NO. 2



B. Drawings

No Change.

END OF **BID ADDENDUM NO. 2** ISSUED 6/13/2019

---- Revised documents attached at end. ----

RESPONSES TO REQUESTS FOR INFORMATION

No.	QUESTION	RESPONSE	RESPONSE BY
1	During the site visit, it was stated there was asbestos pipe in the ground. Please give location and approximate length.	We do not know the extent of this pipe but it is assumed to run from the NE corner to the SE corner to the Middle of the area in front of the Cafeteria, then towards the SW corner of the quad.	District
2	Please confirm a broom finish for concrete walls and flatwork.	Per the revised drawings issued in Bid Addendum 1, broom finish will be for flatwork and a sponge finish for the concrete walls. All concrete will be uncolored.	District
3	Please confirm 90 days for project length and which portion will need to be completed prior to school starting in August.	90 days should be sufficient. It would be best to have the heavy equipment portion complete and be on the installation of landscaping portion by August 20th.	District