

Wastewater Construction Permit

Bureau of Water



PROJECT NAME: Maryville Lift Station	COUNTY: Georgetown
LOCATION: 2125 Poplar St Georgetown SC 29440	

PERMISSION IS HEREBY GRANTED TO: City of Georgetown
2377 Maybank Dr
Georgetown, SC 29440

For the construction of a sanitary sewer system in accordance with the construction plans, specifications, design calculations and the Construction Permit Application signed by Aaron Marshall, Wooten Company, Registered Professional Engineer, S.C Registration Number: 38780.

Project Description: The plans call for the existing lift station to be abandoned after construction of the new station is completed with the exception of the existing 8' diameter wet well. Closure of the lift station will consist of removing the existing pumps and removing the unused 8" force main and lift station components. The new lift station will consist of a new 12' diameter wet well, approximately 40 LF of 8" force main piping, and gravity sewer connecting to the existing wet well. The new wet well will pump max out at 780 gpm.

TREATMENT FACILITY: The wastewater will be discharged to the GEORGETOWN CITY OF WWTP - SC0040029 at a design flow rate of 0 GPD.

STANDARD CONDITION:

NOTE: In accepting this permit, the owner agrees to the admission of properly authorized persons at all reasonable hours for the purpose of sampling and inspection. This is a permit for construction only and does not constitute DHEC approval, temporary or otherwise, to place the system in operation. An Approval to Place in Operation is required and can be obtained following the completion of construction by contacting the Pee Dee EA Myrtle Beach at 843-238-4378. Additional permits may be required prior to construction (e.g., Stormwater).

SPECIAL CONDITIONS:

- See attached (to original construction permit) DHEC Office of Ocean and Coastal Resource Management (DHEC-OCRM) certification for additional conditions related to the Coastal Zone Consistency determination.

PERMIT NUMBER:	WW043330
ISSUANCE DATE:	June 11, 2021
EXPIRATION DATES:	Construction must be completed and the Approval to Place in Operation granted prior to June 11, 2024 or this permit will expire.

A handwritten signature in black ink, appearing to read 'Douglas B. Kinard', is written over a horizontal line.

Douglas B. Kinard, P.E., Director
Drinking Water and Recreational
Waters Protection Division

GBA