



St. Johns River Water Management District

Ann B. Shortelle, Ph.D., Executive Director

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • 386-329-4500
On the internet at www.sjrwmd.com.

DATE: December 12, 2019
TO: Prospective Respondents
FROM: Pam Paulk, Contracts Administrator
SUBJECT: Addendum #1 to Invitation for Bids 35281 Refurbish Marsh Flow-Way Pump Station (5 Pumps)

As a result inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your solicitation documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

QUESTIONS AND ANSWERS

- Q.1. What are the names of the manufactures for the pumps and motors that are to be refurbished under this contract?
A.1. All 5-pumps at the Apopka Flow-way are Couch/MWI Pumps. Four of the electric motors at the Apopka Flow-way are Lincoln TEFC 100-HP Hostel Duty Motors and one is an Emerson 125-HP US Motor.

NOTE: The Bid Opening remains the same January 6, 2020, at 2:00 PM, EST.
Please acknowledge receipt of this Addendum on the BID FORM provided in the bid package.
If you have any questions, please call me at (386) 329-4469 or e-mail ppaulk@sjrwmd.com.