



St. Johns River Water Management District

Ann B. Shortelle, Ph.D., Executive Director

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • 386-329-4500
On the internet at www.sjrwmd.com.

DATE: December 26, 2019
TO: Prospective Respondents
FROM: Pam Paulk, Contracts Administrator
SUBJECT: Addendum #3 to Invitation for Bids 35281 Refurbish Marsh Flow-Way Pump Station (5 Pumps)

As a result of additional inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your solicitation documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

QUESTIONS AND ANSWERS

- Q.1. We respectfully would like to point that \$250,000 estimate seems to be on the low side, in order to cover the required scope of work. Please advise?
A.1. The \$250K is the engineer's estimate. The Respondent may submit their bid whether it be higher or lower.
- Q.2. When or around what time the NTP is expected to be issued?
A.2. An NTP will not be issued. The District anticipates providing the lowest responsive and responsible Respondent's bid for approval to the District's Board at their meeting on February 11, 2020. A payment and performance bond and insurance will be required from the awarded contractor and an agreement will be executed as well. It is anticipated that all documents will be in place for the Contractor to begin work in March.
- Q.3. The specs called for "Refurbish all five (5) axial flow pumps and motors", but "Exhibit 2 page C-1 Note 2 called for PUMPS 1, 2, 3 to be replaced." Does it mean that for Pumps 1, 2, 3 pumps and motors should be furnished as new?
A.3. Please note that these drawings are dated June 1, 1999 and are the design drawings for the pump station and are/were intended to show what is in place not the work that is expected under this contract. We are only requesting that the pumps and motors be refurbished per the Statement of Work.
- Q.4. Coatings Specifications - Surface Preparation: Is water washing the correct and accepted method for the surface preparation of the structural components above the walk platform?
A.4. A light pressure washing with water is adequate.
- Q.5. While water washing the structure will the water & debris have to be contained or will it be acceptable to allow water, dirt etc. to flow in basin?
A.5. The water and debris will not need to be contained.
- Q.6. Please provide a list of the current plan holders.
A.6. The current plan holders list from Demandstar is attached.

NOTE: The Bid Opening remains the same January 6, 2020, at 2:00 PM, EST.
Please acknowledge receipt of this Addendum on the BID FORM provided in the bid package.
If you have any questions, please call me at (386) 329-4469 or e-mail ppaulk@sjrwmd.com.



[My DemandStar](#)

[Buyers](#)

[Account Info](#)

[FAQs](#)

[Log Bid](#) [\[View Bids\]](#)

[Log Quote](#)

[View Quotes](#)

[Supplier Search](#)

[Build Broadcast List](#)

Planholders List

Member Name St. Johns River Water Management District

Bid Number IFB-35281-0-2019/PP

Bid Name REFURBISH MARSH FLOW-WAY PUMP STATION (5 PUMPS)

8 Document(s) found for this bid

19 Planholder(s) found.

[Add Planholder](#)

Supplier Name	Phone	Fax	Doc Count	Attributes	Programs	Actions
Barney's Pumps, Inc.	8636658500	8636663858	4			Documents
Boromei Construction, Inc	8636234314	8637636337	8			Documents
ConstructConnect	8772271680	8665708187	8			Documents
Construction Journal, Ltd.	8007855165	8005817204	7			Documents
Dodge Data	4133767032		8			Documents
Douglas N. Higgins, Inc.	7349969500	7349968480	7			Documents
Grove Welders, Inc.	7725691222	7725696362	3	1. Small Business		Documents
Industrial Reliability \$ Alignments, LLC	3865465866	3862673149	7			Documents
MWI Pumps	8138992863	8138992862	4			Documents
Paint BidTracker	4124318300	4124315428	1			Documents
Pivotal Pumps	2623092162		6			Documents
Power & Pumps, Inc.	9043565881	9043568717	1	1. Small Business		Documents
Prime Construction Group, Inc.	4078568180	4078568182				Documents
Revere Control Systems, Inc.	8632260219	7274930764	1			Documents
Sawcross, Inc.	9047517500	9047510600	4			Documents
Tampa Armature Works, Inc. (TAW)	8138403500	8132178462	4			Documents
Tom Evans Environmental , Inc.	8636193789	8636198098	3			Documents
Vermana, Inc.	4076013943	8885192283	3			Documents
Wastewater Solutions, LLC	9544839269	9544839269	2	1. Small Business		Documents

Format for Printing Yes No