




ATTACHMENT #3



LEGEND

-  Sewer Lines
-  Streets
-  Gas Lines



0 200 400 800 Feet



ATTACHMENT #3

Roadside Beautification Assistance Program
SR 10/ US 90 from Avalon Blvd to Jamiee Leigh Dr
FDIP# 440107-3-58-01

1. Well installation (see attached location) to include the following:
 - 4" State Well Permit
 - Set back exemption and paperwork
 - Drilling per foot 4" well steel casing
 - 4" 188ft wall steel
 - 4" * 20' stainless steel well screen
 - Grouting of well for setback exemption
 - 7.5 hp 3 phase 230 volt motor
 - 85 gpm 7.5hp pump end
 - 7.5 1 PH in 3/ PH out 230 volt
 - PC 66 Flexcon tank
 - Misc fittings/pipe/pressure gauge and relief valve
 - 2" Sch 80 PVC drop pipe
 - 2" galvanized coupling
 - 10/4 flat double insulated wire
 - 2" galvanized T
 - Vac truck to remove drill mud from site

Specifications provided by Clydes Well Service

Contact Clydes Well Service for pricing: (850) 675-6230

5624 Pasture Ln. Jay, FL 32565