



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: October 9, 2020
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #2 to Invitation for Bids # 36128, Fellsmere Grade CS2 Sliplining

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

- Q1: For the CIPP option; should the bidders use a Fully Deteriorated (FD) pipe design or a Partially Deteriorated (PD) pipe design to calculate the liner thickness?
A1: The existing pipes should be considered “partially deteriorated”
- Q2: If the CIPP lining process is utilized, can the curing water be released back into the existing water way once it has been cooled down to ambient temperature?
A2: Yes.
- Q3: Are the methodology details outlined in Attachment A – Statement of Work Item III Scope required with the Bid?
A3: No.

NOTE: The Bid Opening **remains** 2:00 p.m., **Thursday, October 22, 2020**

Please acknowledge receipt of this Addendum on the **BID FORM** provided in the bid package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.