



ADDENDUM NO. 3

Issue Date: October 11, 2019

Project Name: Oslo Water Treatment Plant Blower Replacement

Bid Number: 2020009

Bid Opening Date: October 23, 2019

This addendum is being released to answer questions received to date and to add pre-bid meeting discussion.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

The following items were discussed at the pre-bid meeting and are hereby incorporated into the specifications:

- Work hours: Monday through Friday 7am to 5pm. Weekend and after hours with prior authorization from the Chief Operator.
- Only one Blower can be down at any given time. Will require 3 separate start-ups.
- Any heaters needed for uninstalled blower motor storage is the responsibility of the Contractor.
- Awarded bidder will coordinate with the Chief Operator on storage of material at the water treatment plant

Questions and Answers

- Regarding applicable plans sheets with the 4-0x5-6x11.25 concrete housekeeping pad callouts, has
1. any consideration been given to alternate equipment supports/foundations? (i.g; stainless steel support framing). If so, would the Engineer provide an alternate engineering detail to bid on?
Steel frame will not be acceptable for the blower supports. IRCU and engineer of record desire reinforced concrete support pads as designed and shown on the plans. Please prepare bid accordingly.
 2. The lead time for the blowers is 21 weeks after approved submittal. Can the contract timeframe please be increased?

Addendum 3

3.02 Days to Achieve Substantial Completion, Final Completion and Final Payment

- A. The Work will be completed and ready for final payment on or before the 240th day after the date when the Contract Times commence to run.

We agree to increase *Days to Achieve Substantial Completion, Final Completion and Final Payment* to 270 days.