



ADDENDUM NO. 5

Issue Date: July 2, 2024

Project Name: Gifford Elevated Storage Tank Modification and Rehabilitation

ITB Number: 2024047

ITB Opening Date: **July 11, 2024**

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid.

Questions & Answers

1.	Addendum 4 states to paint the interior in the same manner as the exterior, however for the interior you wouldn't need urethane since it's not being exposed to the UV rays. A zinc, 2 coat epoxy will suffice on the interior.
	The coating system of the interior of the tank shall be per the project specifications to protect from the abrasiveness of the ballast material.
2.	If phase two is not to be done, I'm assuming the logo will not be repainted on the tank?
	Correct, if phase 2 is not awarded, the tank will not be sand blasted and the existing logo will remain on the tank.
3.	The touch-up repair coating won't match what's on the existing tank if option 1 is chosen and not option 2.
	Owner will work with Contractor for appropriate actions, in the event Phase 2 is not awarded