



St. Johns River Water Management District

Ann B. Shortelle, Ph.D., Executive Director

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • (386) 329-4500
On the Internet at www.sjrwm.com.

DATE: November 14, 2018
TO: Prospective Respondents
FROM: Pam Paulk, Sr. Procurement Specialist
SUBJECT: Addendum #4 to Invitation for Bids, IFB #33711 PRARIE CREEK DIVERSION
STRUCTURE REPLACEMENT

As a result of inquiries, the following clarifications are provided for your information.

QUESTION AND ANSWER:

Q.1. Can trees be mulched onsite?

A.1. Vegetation can be chipped on site and blown in the surrounding tree line, on either side of the access road. Chipped vegetation cannot be dumped in piles.

Q.2. Will the District accept Type IL cement, #57 coarse aggregate, and FDOT Class IV 5500 PSI?

A.2. Type IL cement, #57 coarse aggregate, and FDOT Class IV 5500 PSI concrete are all acceptable to the District.

NOTE: The Bid Opening remains the same, November 19, 2018 at 2:00 PM.

Please acknowledge receipt of this Addendum on the BID FORM provided in the bid package.

If you have any questions, please call me at (386) 329-4469 or e-mail ppaulk@sjrwm.com.