



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 5

DATE: March 30, 2018
PROJECT: ITB 0318-1020
RIVERFRONT DAY DOCKS

OPENING DATE: APRIL 2, 2018

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~striketrough~~.

1. Questions and Answers:

Q1: Will the City allow additional days if Bellingham Marine can't provide supplies need on time?

A1: **See addendum 3**

Q2: Do you have a coordinates control establishing the dock and channel markers?

A2: **The survey includes a control point establishing the project location in State Plane Florida East coordinates, and will be included with the ~~construction documents provided to the selected Contractor,~~**

Q3: Is the type two turbidity barrier going to be mandatory being that the dredging isn't going to in the scope of work?

A3: **Type 2 turbidity barrier will be mandatory due to anticipated jetting of piles and other construction activities.**

2. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach

Kirk Zimmerman, CPPB
Buyer