



CITY OF CALLAWAY  
CALLAWAY POINT  
DRAINAGE IMPROVEMENT PROJECT  
BID NO.: CM2020-05


ADDENDUM #1

Date Issued: July 22, 2020

\*\*\*\*\*

This addendum is being release to clarify information within the bid packet as follows:

1. Can an uncertified contractor use sub-contractors who are certified for the Hot Plant Mixed Bituminous Courses and/or Roadway Signing & Marking?  
A. Yes, the prime contractor can use certified sub-contractors for the required work.
2. Does this project include Signing and Striping?  
A. No, signing and markings are not required for this project.
3. What type of binder is required for the asphalt?  
A. For this project, use Asphalt Binder Grade PG 58-22. Cost shall be included in the Resurfacing Asphalt SP 9.5, bid item 0337-7-80. For more information regarding the asphalt binder, please refer to the FDOT Standard Specification, Section 334-2.3.5.
4. What is the estimated Engineer budget for the project?  
A. The Engineers Estimate for this project is approximately \$270,000.
5. Is the Contractor allowed to keep the millings?  
A. Yes, the Contractor can keep the milling materials.
6. SPECIAL INSTRUCTIONS & CONDITIONS - Clarification  
Please disregard the 3<sup>rd</sup> paragraph on page 1 of 2, that states "Only Registered Bid Set Holders, who receive Plans & Specifications directly from DRMP, Inc., will be authorized to submit bids on this project. This is NOT a requirement.
7. MINIMUM TECHNICAL SPECIFICATIONS – Correction to Schedule of Events  
Please note that the Bid Due date is July 31, 2020, not July 28, 2020, as stated in the Schedule of Events.

  
Janice L. Peters, City Clerk

\*\*\*\*\*

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date