

ADDENDUM NO. ONE

The above-named documents are hereby amended, modified, or supplemented as enumerated hereinafter. All such amendments, modifications or supplements shall be considered as though originally specified and/or shown on the drawings.

ARCHITECTURAL

ITEM #1

Refer to Section 076100, Sheet Metal Roofing, Part II Products, 2.01 Acceptable manufacturer. Add "B. MRS System – 2500 Panel."

ITEM #2

As a matter of clarification, snow guards are required at the perimeter of the entire building.

END OF ADDENDUM