

ADDENDUM NO. 1 TO CONTRACT DOCUMENTS

Project: MacDonald Downs Pump Station H&S Project No. 30906-006

Owner: City of Havelock

Date: 10/10/2017

To All Bidders:

Contractors submitting Proposals for the above named Project shall take note of the following changes, additions, deletions, clarifications, etc., in the Contract Documents, which shall become part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Contractor's Bid Proposal.

All other general items, conditions, drawings, and specifications shall remain the same. Please acknowledge the receipt of Addendum No. 01 with the Bid Form.

Refer to the Attached Sheets.

The return receipt requested with the communication will be deemed evidence that the bidder has received the Addendum and has followed the instructions herein.

Company Name

Acknowledgement of Receipt

Date



Nichole Johnson
HAZEN AND SAWYER

MacDonald Downs Pump Station

Addendum No. 01

DRAWING CHANGES:

- | | |
|---|---|
| <u>Item 1.</u> Drawing C-1 | Add the following NOTE:
"3. Install a 2 inch water service connection, including a meter and backflow preventer, from the existing 10 inch PVC water line in the US70 right of way to the new pump station site. Meter and backflow preventer shall be to City of Havelock standards. Install approximately 700 lf of 2 inch Schedule 40 PVC water line and fittings in the existing force main easement along the property line. PVC pipe shall conform to ASTM D 1785 and fittings shall conform to ASTM D2466. Terminate the water service with a yard hydrant per detail 1511502. Owner shall designate location of the yard hydrant inside the new pump station fence." |
| <u>Item 2.</u> Drawing M-01
Section A/M-1 | Change "8" SS, INV EL. 6.69" to "8" SS, INV EL. 4.20" |
| <u>Item 3.</u> Drawing M-01
Section A/M-1 | Change the bottom invert elevation from "EL. -1.40" to "EL. -3.88" |
| <u>Item 4.</u> Drawing M-01
Section A/M-1 | Change the top of the concrete fillet in the pump station manhole elevation from "EL. -0.1" to "EL. 0.45" |
| <u>Item 5.</u> Drawing M-01
Section A/M-1 | Change the bottom of the concrete fillet in the pump station manhole elevation from "EL. -0.73" to "EL. -1.88" |
| <u>Item 6.</u> Drawing E-01 | Add the following to the NOTES:
"11. CONTRACTOR SHALL COORDINATE THE PROVISION AND INSTALLATION OF THE METER BASE WITH THE SERVING ELECTRICAL UTILITY PRIOR TO PERFORMING ANY ELECTRICAL WORK." |
| <u>Item 7.</u> Drawing D-01
Detail 0260102
Doghouse Precast Manhole | Delete Note 2 text "This detail shall be used for stormwater structures only. Doghouse type manholes shall not be used for process structures." and replace with "Not used" |
| <u>Item 8.</u> Drawing D-03 | Add attached Yard Hydrant Detail 1511502 |

Additional Information

1. For informational purposes links to PDFs of the plans and specifications are provided below. Complete bidding documents must be obtained from the office of the engineer. All bidders must be plan holders on record with the office of the engineer.

Plans: <https://hazenandsawyer.filetransfers.net/downloadPublic/qe7ns837fkvqkhhb>

Project Manual:


<https://hazenandsawyer.filetransfers.net/downloadPublic/smryatb2ahmeo9p>

These links will expire on Friday October 20th, 2017.

2. Attached is the sign in sheet from the Pre-Bid Meeting held on October 4, 2017.

Attachment 01

Detail 1511502 Yard Hydrant



YARD HYDRANT

1511502

Attachment 02

Pre-bid Meeting Sign in Sheet



CITY OF HAVELock
1 GOVERNMENTAL AVE
HAVELock, NC 28532

MacDonald Downs Pre-bid Meeting

10/4/17 at 11:00am

<u>NAME</u>	<u>TITLE</u>	<u>COMPANY</u>	<u>PHONE NUMBER</u>	<u>EMAIL</u>
Tripp Todd	Area Manager	DRI Pumps	252-671-0842	Tripp.Todd@dripumps.com
Martin G Cieseko	Pres	Cieseko Const Co	252-670-8108	Martin.Ciesekoconstruction.com
NED CIESZKO	V.P.	CIESZKO CONST CO	252-447-2096	ned@cieszkoconstruction.com
Kyle Becher	Estimator	Sackville Mechanical Inc	910-455-1830	Kyle@jvillemach.com
DONNIE FIBEE	Superintendent	JACKSONS MACH	910 3890774	Sandakent.litres@gmail.com
Eddie Mullen	P.M.	Caroline Civilworks Inc	919 624 7481	emullen@carolinecivilworks.com
David Durham	V.P.	East Coast Electric	252-444-4488	David@eastcoastelectric.us
Nichole Johnson	Engineer	Hazen and Sawyer	919-755-8619	njohnson@hazensawsawyer.com
Timothy Bart	Collection ORC	City of Havelock	252-444-6409	thart@havelocknc.us
Mark Soyeger	Public Sals Dir	City of Havelock	252-444-6410	MSOYGER@HAVELockNC.US
Tiffini Bingham	finance	City of Havelock	252-444-6404	TBingham@havelocknc.us
Steven Byrum	est	Sunland Builders	252 393 2504	sunland2504@yahoo.com