



July 13, 2023

Barry Vickery
Capital Project Manager
Jackson County Government
67 Athens Street
Jefferson, GA 30549
Phone : (706) 286-6353
Email: bvickery@jacksoncountygov.com

Subject: **Commerce Roof Replacement - Addendum 2**
Commerce Service Center
623 S. Elm Street
Commerce, Georgia
PM&A Project No. 23-019

Addendum Summary

This addendum answers questions submitted by contractors.

Addendum

The following questions have been submitted by contractors.

1. *Question:* Asbestos report states two areas that have asbestos in the silver coating. Is there a map locating all the areas of the testing to determine the amount of removal required?
 - A. *PM&A Answer:* Please refer to Section 01 11 00 Paragraph 1.03.D. Asbestos was detected in the silver coating on the **flashings** of the subject roof system. All flashings of the roof system must be abated.

2. *Question:* What are the requirements for the asbestos removal? Please Clarify.
 - A. *PM&A Answer:* Please refer to Section 02 82 33 *Removal of Asbestos Containing Roofing Materials*, for requirements for asbestos removal.

Closure

All other sections of the project manual remain in full force and effect.

Respectfully Submitted,

Robert Bounnakhom
PM&A Engineering Services