

BOARD OF COMMISSIONERS

OSBORN NESBITT, SR., CHAIRMAN  
Sherri L. Washington, Commissioner Post I  
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE  
MARK LEWIS, FINANCE DIRECTOR  
TELEPHONE: 770-278-7555  
FACSIMILE: 770- 278-8910

**Addendum No. 5**

**ITB No. 21-18**

**REMOVE AND REPLACE CHILLER AND CONTROL SYSTEM AT COURTHOUSE ANNEX**

**August 20, 2021**

**ITB #21-18** is hereby amended as follows:

**1. Below are questions received and corresponding answers:**

**A. Question:** Will the awarded contractor be expected to provide means of temporary cooling for the space while the changeout is occurring?

**Answer:** No. We anticipate this to be completed in the winter so we will utilize the existing PIU's to heat, and the county will supplement with space conditioners as needed. We do ask that the schedule of construction accommodate as minimal down time as possible.

**B. Question:** Is Honeywell an acceptable product for the controls system replacement?

**Answer:** Please provide information on the requested substitution for the controls system and engineering will review.

2. All other conditions remain in full force and effect.

3. If a Bid has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the Bid price, the new price and/or changes will be inserted below:

---

---

BOARD OF COMMISSIONERS

OSBORN NESBITT, SR., CHAIRMAN  
Sherri L. Washington, Commissioner Post I  
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE  
MARK LEWIS, FINANCE DIRECTOR  
TELEPHONE: 770-278-7555  
FACSIMILE: 770- 278-8910

4. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on page 14 of the Bid Form.

*Tina Malone*

---

Tina Malone, CPPB CPPO  
Procurement Manager  
Department of Finance, Purchasing Division