

BOARD OF COMMISSIONERS

OSBORN NESBITT, SR., CHAIRMAN
Sherri L. Washington, Commissioner Post I
Dr. Doreen Williams, Commissioner Post II



DEPARTMENT OF FINANCE
MARK LEWIS, FINANCE DIRECTOR
TELEPHONE: 770-278-7555
FACSIMILE: 770- 278-8910

Addendum No. 6

ITB No. 21-18

REMOVE AND REPLACE CHILLER AND CONTROL SYSTEM AT COURTHOUSE ANNEX

August 26, 2021

ITB #21-18 is hereby amended as follows:

1. Below are questions received and corresponding answers:

A. Question: I've attached the specification document for Honeywell controls for approval.

Answer: Honeywell controls are allowed as an approved substitute provided; they meet all the other requirements in the specification. All bidders are requested to provide a short narrative in their bid packet indicating which controls system they will provide, how it will be configured, and how it will back feed the existing PIU's.

2. All other conditions remain in full force and effect.

3. If a Bid has been submitted and anything in this Addendum causes the bidder to change the item offered or to increase or decrease the Bid price, the new price and/or changes will be inserted below:

4. All bidders under this Invitation to Bid are kindly requested to acknowledge receipt of this Addendum on page 14 of the Bid Form.

Tina Malone

Tina Malone, CPPB CPPO
Procurement Manager
Department of Finance, Purchasing Division