



# City of Kingman

310 NORTH FOURTH STREET • KINGMAN • ARIZONA • 86401 • 928.753.5561  
WWW.CITYOFKINGMAN.GOV

## CITY OF KINGMAN EASTERN STREET IMPROVEMENTS, PHASE 1

**ADDENDUM NO. 1**  
**(Total of 1 Page with Attachments)**  
**Prepared: March 17, 2023**  
ENG21-0001

The following information is provided to supplement the project Bid Documents for EASTERN STREET IMPROVEMENTS, PHASE 1. This Addendum #1 is being issued to address the following comments. Receipt of this Addendum No. 1 shall be acknowledged on the Proposal Form.

### COMMENT RESOLUTION:

1. What specification should we be using for the mix design and reinforcement?  
**RESPONSE: Channel lining shall follow M.A.G. Specification Section 505 – Concrete Structures (See Sheet 6 and Sheet 13 of Stantec as-built plans).**
2. Will there be any reinforcement (fiber mesh, wire mesh or rebar)?  
**RESPONSE: Reinforcing steel shall conform to M.A.G. Specification Section 727 (See Sheet 13 of Stantec as-built plans for rebar size and spacing).**
3. Is there a detail for joining new and old shotcrete channel (i.e., thickened edge with drilling and pinning with epoxy or otherwise)?  
**RESPONSE: A detail has been provided (See Sheet 13 of Stantec as-built plans).**
4. Will we need any special finish other than standard nozzle finish?  
**RESPONSE: Rough broom finish.**
5. Are joints required and if so could we get some details or spec to reference?  
**RESPONSE: Joints shall be installed per attached details (See Sheets 6 and 13 of Stantec as-built plans).**
6. Is there a chosen preferred supplier for the concrete already or should we just use our preferred ready mix supplier?  
**RESPONSE: There is not a preferred concrete supplier.**
7. For the box culvert would the City accept precast in lieu of cast in place?  
**RESPONSE: For this bid the box culvert shall be cast in place.**

**END OF ADDENDUM NO. 1**  
**Total of 1 Page with Attachments**


Addendum #1 Prepared by:  
Eric Sparkman, P.E.  
Assistant City Engineer  
Attachments: Stantec As-Built (3 pages)





**Stantec**

Stantec Consulting Inc.  
8211 South 48th Street  
Phoenix AZ 85044 U.S.A.  
Tel. 602.438.2200  
Fax. 602.431.9562  
www.stantec.com



MAYOR  
MONICA GATES


COUNCIL MEMBERS

DAVE FRENCH  
TOM SPEAR  
PHILLIP MOON  
JIM BAKER  
TOM CARTER  
RAY LYONS

CITY MANAGER  
PAUL BEECHER

CITY ENGINEER  
PETER R. JOHNSON, P.E.

PUBLIC WORKS DIRECTOR  
JACK KRAMER



VICINITY MAP  
NO SCALE

# CITY OF KINGMAN PUBLIC WORKS DEPARTMENT

310 N. Fourth Street  
Kingman, AZ 86401  
928-753-8122

# (AS-BUILT)

AS-BUILT  
11/1/06

I HEREBY CERTIFY THAT THE AS-BUILT INFORMATION SHOWN HEREON SATISFIES THE INTENT OF THE DESIGN.



STANTEC CONSULTING, INC.  
REGISTERED CIVIL ENGINEER  
FIRM NAME:

9365  
REGISTRATION NO.

11/1/06  
DATE

### SHEET INDEX

SHT. NO.	DESCRIPTION
1	COVER SHEET
2	KEYMAP & LINETYPES
3	GENERAL NOTES
4	DEMOLITION & UTILITY RELOCATION PLAN
5-6	TYPICAL SECTIONS
7	HORIZONTAL CONTROL
8-9	GRADING PLANS
10-13	DETAILS
14-16	SHOO FLY PLAN & PROFILE
17	UNDERPASS DETAIL
18-25	AIRWAY AVENUE PLAN & PROFILE
26	APACHE STREET PLAN & PROFILE
27	DIAMOND STREET PLAN & PROFILE
28-35	RAILROAD CHANNEL PLAN & PROFILE
36	YAVAPAI DRAINAGE CHANNEL PLAN & PROFILE
37-38	NORTH DRAINAGE CHANNEL PLAN & PROFILE
39	TRANSITION WALL DETAILS
40	YAVAPAI CHANNEL INLET STRUCTURE DETAILS
41-44	STORMDRAIN PLAN & PROFILE
45-47	STORMDRAIN CONNECTOR PIPE PROFILES
48-51	SEWER PLAN & PROFILE
52-53	WATERLINE PLAN & PROFILE
54-59	PUMP STATION PLANS & DETAILS
60-66	PUMP STATION ELECTRICAL PLANS
67-71	STREET LIGHT PLANS
72-75	TRAFFIC SIGNAL PLANS
76-84	SIGNING & PAVEMENT MARKING PLANS
85-91	B.N.S.F. BRIDGE PLANS
92-95	AGENCY DETAILS

# Airway Avenue Railroad Crossing Improvement District Andy Devine to Castle Rock Road

THE NORTH 1/2 OF SECTION 8, T.21 N., R. 16 W.,  
G. & S.R.M., MOHAVE COUNTY, ARIZONA.

## PROJECT NO. 05-ID-0015

APPROVED:

\_\_\_\_\_  
DIRECTOR OF PUBLIC WORKS

\_\_\_\_\_  
DATE

\_\_\_\_\_  
CITY ENGINEER

\_\_\_\_\_  
DATE

## NOVEMBER 2006

### STANTEC JOB NO.: 81760059

05-ID-0015



