

Date: September 12, 2019

RE: Bid No.: 19-2234 Levings Park Accessible Path Construction
Opening: Tuesday, September 17, 2019 at 2:00 p.m., Rockford
Park District, Webbs Norman Center Board Room, 401
S. Main St., Rockford, IL 61101



ADDENDUM NUMBER TWO

This addendum is issued to modify, clarify or correct the original Project Manual and/or Drawings and is hereby made a part of the contract documents. Please attach this addendum to the Project Manuals and Drawings in your possession. Include acknowledgement of this addendum in your bid. Omission of acknowledgement may be cause for rejection of bid. Bidders shall review changes to all portions of work, as changes to one portion may affect work of another.

- A. **REQUEST FOR INFORMATION AND RESPONSE:**
- Q. What is the spec for the turf reinforcement mat to be used for the inlet reconstruction?
- A. Contractor shall use NAG SC250 turf reinforcement mat for the inlet reconstruction.

END OF ADDENDUM NUMBER TWO