

**ADDENDUM NUMBER 3
BID NUMBER IFB 21-004**

Monument Sign for Washington High School

ISSUED: March 22, 2021

**PURCHASING DEPARTMENT
UNIFIED SCHOOL DISTRICT 500
2010 N. 59th STREET, ROOM 370
KANSAS CITY, KANSAS 66104
(913) 551-3200**

Note the following changes to the above-mentioned bid. This information is to be taken into consideration when responding to the original bid document.

1. Response to Bidder Question:

1	Will the existing sidewalk pad be left in place where the existing sign is located? Or will this need to be removed and mulched to match the surrounding mulch?
KCKPS	The pad for the existing sign will be left in place. The existing sign will be taken down and left for the District to Salvage.
2	Can you clarify where we can anticipate hooking up power at the for the new sign? Is there an existing conduit under the road that we will be able to tie onto to feed the new sign?
KCKPS	The power source for Washington connects at the front of the building approximately 40' west of the main door. Condition of conduit and existing wire is unknown.
3	Is the existing sign illuminated and functioning? If so, the best option would be to demolish that concrete pad and re-route the electrical to the new location. Would you be opposed to installing the sign on the west side of the sidewalk versus the east?
KCKPS	The existing sign does not light up for unknown reasons. KCKPS would not consider moving the sign on the west side of the sidewalk and the existing pad will be left in place.

2. No Other Changes: No other changes or modification are intended by this Addendum. All other terms and conditions of the solicitation remain in effect.

WE HEREBY ACKNOWLEDGE AND UNDERSTAND THE ABOVE NOTED CHANGES TO THE ORIGINAL BID DOCUMENT AND AGREE TO FURNISH THE ITEMS ON WHICH PRICES ARE QUOTED IN ACCORDANCE WITH ALL TERMS AND CONDITIONS PREVIOUSLY LISTED AND ANY ATTACHED SPECIFICATIONS AND AMENDMENTS.

BY: _____ DATE: _____
TITLE: _____ PHONE: _____
FIRM _____