



ADDENDUM NO. 1

Issue Date: January 7, 2020

Project Name: NCAC Activity Pool Resurfacing Project

Bid Number: 2020022

Bid Opening Date: January 15, 2020

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Questions and Answers

1. The scope asks that the surface be sound out for hollows. How many SF of hollow area removal should be included in this bid?
At least 40 SF of hollow area should be included in this bid.
2. The scope specifies the installation of new nonskid waterline/gutter tiles however the bullet just below that specifies only to remove all pool tile. Please clarify what tile you want removed and replaced for this bid.
It is to remove and replace all tiles at the water line and gutter tiles with nonskid per the county code.
3. The scope requests that new belly band tile be installed across pool at 4 ½ depth. The deepest part of the activity pool appears to be 4 ½ feet deep. Please clarify the area of the belly band tile you desire.
The belly band is to be added if it is required per code.
4. The scope asks for the installation of 2 new 18"x18" VGB main drain frame and grates – our count was a total of 5. Please advise.
It is to replace all the drain covers.

5. The scope requires that all light be repaired to working order. Assuming there are no fixture problems we can include the cost to install new bulbs and gaskets. Do you want an add alternative for the fixtures as well in the event the issue is beyond the bulbs and gaskets?
Just bulbs and gaskets at this time.

6. The scope asks that we install floor return frame and grates. The covers or frame and grates for those are not sold. The fixture would need to be replaced in its entirety. Should we include the cost for the fixture or we can cut around them and save the existing ones currently in place.
If the fixture is in good shape it could be used but we would like all the tops replaced.

7. There is mention of a 10 year warranty specified at the bullet outlining the pool finish. Please confirm that this would be a manufactures warranty on the pool finish materials.
Yes the 10 year manufactures warranty.