
TECHNICAL SPECIFICATIONS

**HORRY COUNTY SCHOOLS
PHASE 2 TRACKS
Bid Set**

FEBRUARY 22, 2021

CHA PROJECT #: 065245.000

Prepared by:

**CHA
110 Traders Cross
Suite 201
Bluffton, South Carolina 29909
(843) 705-8020**

TABLE OF CONTENTS

Division 01 – General Requirements

011000	Summary
011400	Work Restrictions
012100	Allowances
012300	Alternates
013000	Project Management and Coordination
013300	Submittal Procedures
017700	Closeout Procedures

Division 11 – Equipment

116833	Outdoor Sports Equipment
116833.43	Track and Field Equipment

Division 26 – Electrical

260001	Electrical
--------	------------

Division 31 – Earthwork

310519.13	Geotextiles
311000	Site Clearing
312000	Earth Moving
312319	Dewatering
312333	Trenching and Backfilling

Division 32 – Exterior Improvements

320116.71	Cold Milling Asphalt Pavement
321116	Subbase Courses
321216.36	Athletic Track Asphalt Paving
321630	Concrete Sidewalks
321815	Athletic Channel Drain System
321823.38	Synthetic Running Track Surveying
321823.39	Synthetic Running Track Surfacing
321823.40	Synthetic Running Track Line Markings
321823.41	Synthetic Running Track Certification Survey
323113	Chain Link Fence and Gates
329110	Amended Topsoil for Athletic Fields
329113	Soil Preparation
329200	Turf and Grasses
329223.10	Sodded Athletic Fields

Division 33 – Utilities

330500	Common Work Results for Utilities
334100.20	High Density Polyethylene Storm Utility Drainage Piping

SECTION 011000 – SUMMARY

PART 1 – GENERAL

1.1 WORK COVERED BY CONTRACT DOCUMENTS

- A. Project Identification: Project consists of replacing the existing track and field facilities at three (3) Horry County, SC high schools.
 - 1. Project Locations:
 - a. Aynor High School, 201 Jordanville Road, Aynor, SC 29511
 - b. Green Sea Floyds High School, 4990 Tulip Grove Road, Green Sea, SC 29545
 - c. North Myrtle Beach High School, 3750 Sea Mountain Hwy, Little River, SC 29566
 - 2. Owner: Horry County Schools, 335 Four Mile Road, P.O. Box 260005, Conway, SC 29528-6005
- B. Engineer Identification: The Contract Documents, dated February 22, 2021, were prepared for Project by CHA Consulting, Inc., 110 Traders Cross, Bluffton, SC 29909.
- C. The Work consists of replacement of existing asphalt track and field facilities at three (3) high schools.
 - 1. The Work includes the following:
 - a. Demolition of the existing asphalt tracks;
 - b. Grading and drainage improvements;
 - c. Irrigation system improvements;
 - d. Athletic channel drain systems;
 - e. HDPE underdrain and header pipe systems;
 - f. Concrete sidewalks;
 - g. Concrete curbing;
 - h. Asphalt paving;
 - i. Synthetic track surfacing;
 - j. Fencing; and
 - k. Athletic equipment

1.2 CONTRACT

- A. Project will be constructed under a general construction contract.

1.3 SPECIFICATION FORMATS AND CONVENTIONS

- A. Specification Format: The Specifications are organized into Divisions and Sections using the 48-division format and CSI/CSC's "MasterFormat" numbering system.
 - 1. Section Identification: The Specifications use section numbers and titles to help cross-referencing in the Contract Documents. Sections in the Project Manual are in numeric sequence; however, the sequence is incomplete. Consult the table of contents at the beginning of the Project Manual to determine numbers and names of sections in the Contract Documents.
- B. Specification Content: The Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:

1. Abbreviated Language: Language used in the Specifications and other Contract Documents is abbreviated. Words and meanings shall be interpreted as appropriate. Words implied, but not stated, shall be inferred as the sense requires. Singular words shall be interpreted as plural, and plural words shall be interpreted as singular where applicable as the context of the Contract Documents indicates.
2. Imperative mood and streamlined language are generally used in the Specifications. Requirements expressed in the imperative mood are to be performed by Contractor. Occasionally, the indicative or subjunctive mood may be used in the Section Text for clarity to describe responsibilities that must be fulfilled indirectly by Contractor or by others when so noted.
 - a. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.

PART 2 – PRODUCTS (Not Used)

PART 3 – EXECUTION (Not Used)

END OF SECTION

SECTION 011400 – WORK RESTRICTIONS

PART 1 – GENERAL

1.1 USE OF PREMISES

- A. Use of Site: Limit use of premises to work in areas indicated. Do not disturb portions of site beyond areas in which the Work is indicated.
 - 1. Limits: Confine constructions operations to areas within the contract limits indicated.
 - 2. Owner Occupancy: Allow for Owner occupancy of site and use by the public.
 - 3. Driveways and Entrances: Keep driveways and entrances serving premises clear and available to Owner, Owner's employees, and emergency vehicles at all times. Do not use these areas for parking or storage of materials.
 - a. Schedule deliveries to minimize use of driveways and entrances.
 - b. Schedule deliveries to minimize space and time requirements for storage of materials and equipment on site.
- B. Use of Existing Building: Maintain existing buildings shown to remain on demolition plans in a weathertight condition throughout construction period. Repair damage caused by construction operations. Protect buildings during construction period.

1.2 OCCUPANCY REQUIREMENTS

- A. Full Owner Occupancy: Owner will occupy site and existing buildings outside of the limits of construction during entire construction period. Cooperate with Owner during construction operations to minimize conflicts and facilitate Owner usage. Perform the Work so as not to interfere with Owner's operations.

PART 2 – PRODUCTS (Not Used)

PART 3 – EXECUTION (Not Used)

END OF SECTION

SECTION 012100 – ALLOWANCES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes administrative and procedural requirements governing allowances.
 - 1. Certain materials and equipment are specified in the Contract Documents by allowances. In some cases, these allowances include installation. Allowances have been established in lieu of additional requirements and to defer selection of actual materials and equipment to a later date when additional information is available for evaluation. If necessary, additional requirements will be issued by Change Order.
- B. Types of allowances include the following:
 - 1. Lump sum allowances.

1.2 SUBMITTALS

- A. Submit proposals for performing Work included in allowances, in the form specified for Change Orders.
- B. Submit invoices or delivery slips to show actual quantities of materials delivered to the site for use in fulfillment of each allowance.

PART 2 – PRODUCTS (Not Used)

PART 3 – EXECUTION

3.1 EXAMINATION

- A. Examine products covered by an allowance promptly on delivery for damage or defects. Return damaged or defective products to manufacturer for replacement.

3.2 PREPARATION

- A. Coordinate materials and their installation for each allowance with related materials and installations to ensure that each allowance item is completely integrated and interfaced with related work.

3.3 SCHEDULE OF ALLOWANCES

- A. Allowance No. 1: Include a lump sum of \$5,000 per school for removal and replacement of unsuitable soils in the new D-zone areas with structural fill as required and specified in the "Earth Moving" Section of Division 31.

END OF SECTION

SECTION 012300 – ALTERNATES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes administrative and procedural requirements for alternates.

1.2 DEFINITIONS

- A. Alternate: An amount proposed by bidders and stated on the Bid Form for certain work defined in the Bidding Requirements that may be added to or deducted from the Base Bid amount if Owner decides to accept a corresponding change either in the amount of construction to be completed or in the products, materials, equipment, systems, or installation methods described in the Contract Documents.
 - 1. The cost or credit for each alternate is the net addition to or deduction from the Contract Sum to incorporate alternate into the Work. No other adjustments are made to the Contract Sum.

1.3 PROCEDURES

- A. Coordination: Modify or adjust affected adjacent work as necessary to completely integrate work of the alternate into Project.
 - 1. Include as part of each alternate, miscellaneous devices, accessory objects, and similar items incidental to or required for a complete installation whether or not indicated as part of alternate.
- B. Notification: Immediately following award of the Contract, notify each party involved, in writing, of the status of each alternate. Indicate if alternates have been accepted, rejected, or deferred for later consideration. Include a complete description of negotiated modifications to alternates.
- C. Execute accepted alternates under the same conditions as other work of the Contract.
- D. Schedule: A Schedule of Alternates is included at the end of this Section. Specification Sections referenced in schedule contain requirements for materials necessary to achieve the work described under each alternate.

PART 2 – PRODUCTS (Not Used)

PART 3 – EXECUTION

3.1 SCHEDULE OF ALTERNATES

- A. Alternate No. 1: Add potable yard hydrant adjacent to visitor side maintenance building at Green Sea Floyds High School as shown on Sheet C-320 and labeled “Add Alternate”. Include approximately 200 feet of ¾-inch PEX water line and valve and connection to nearest potable water line as indicated.

END OF SECTION

SECTION 013000 – PROJECT MANAGEMENT AND COORDINATION

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes administrative provisions for coordinating construction operations on Project including, but not limited to, the following:
 - 1. Coordination.
 - 2. Submittals.
 - 3. Administrative and supervisory personnel.
 - 4. Project meetings.
 - 5. General installation provisions.
 - 6. Cleaning and protection.

1.2 COORDINATION

- A. Coordination: Coordinate construction activities included under various Sections of these Specifications to assure efficient and orderly installation of each part of the Work. Coordinate construction operations included under different Sections of these Specifications that are dependent upon each other for proper installation, connection, and operation.
 - 1. Where installation of one part of the Work is dependent on installation of other components, either before or after its own installation, cooperate with scheduled construction activities in the sequence required to obtain the best results.
 - 2. Where availability of space is limited, coordinate installation of different components to assure maximum accessibility for required maintenance, service and repair.
 - 3. Make adequate provisions to accommodate items scheduled for later installation.
 - 4. Coordinate construction activities with public and private utilities.
 - a. Notify South Carolina 811 a minimum of 48 hours prior to excavation or blasting.
 - b. Notify the Owner and Engineer of any utility locations encountered which conflict with the work. Coordinate with the Owner and Utility Company in the protection, removal, relocation or replacement of conflicting utility locations.
- B. Where necessary, prepare memoranda for distribution to each party involved outlining special procedures required for coordination. Include such items as required notices, reports, and attendance at meetings.
 - 1. Prepare similar memoranda for the Owner and separate Contractors where coordination of their Work is required.
- C. Administrative Procedures: Coordinate scheduling and timing of required administrative procedures with other construction activities and activities of other contractors to avoid conflicts and to ensure orderly progress of the Work. Such administrative activities include, but are not limited to, the following:
 - 1. Preparation of Contractor's Construction Schedule.
 - 2. Preparation of the Schedule of Values.
 - 3. Delivery and processing of submittals.
 - 4. Progress meetings.
 - 5. Pre-installation conferences.
 - 6. Project closeout activities.

- D. Conservation: Coordinate construction activities to ensure that operations are carried out with consideration given to conservation of energy, water, and materials.
 - 1. Salvage materials and equipment involved in performance of, but not actually incorporated into, the Work. Refer to other Sections for disposition of salvaged materials that are designated as Owner's property.

1.3 SUBMITTALS

- A. Coordination Drawings: Prepare and submit coordination Drawings where close and careful coordination is required for installation of products and materials fabricated off-site by separate entities, and where limited space availability necessitates maximum utilization of space for efficient installation of different components.
 - 1. Show the interrelationship of components shown on separate Shop Drawings.
 - 2. Indicate required installation sequences.
 - 3. Comply with requirements contained in Section "Submittals Procedures."
- B. Staff Names: Within 15 days of starting construction operations, submit a list of principal staff assignments, including superintendent and other personnel in attendance at Project site. Identify individuals and their duties and responsibilities; list addresses and telephone numbers, including mobile and office telephone numbers. Provide names, addresses, and telephone numbers of individuals assigned as standbys in the absence of individuals assigned to Project.

1.4 PROJECT MEETINGS

- A. General: Schedule and conduct meetings and conferences at Project site, unless otherwise indicated.
 - 1. Attendees: Inform participants and others involved, and individuals whose presence is required, of date and time of each meeting. Notify Owner and Engineer of scheduled meeting dates and times.
 - 2. Agenda: Prepare the meeting agenda. Distribute the agenda to all invited attendees.
 - 3. Minutes: Record significant discussions and agreements achieved. Distribute the meeting minutes to everyone concerned, including Owner and Engineer, within 3 days of the meeting.
- B. Preconstruction Conference: Schedule a preconstruction conference and organizational meeting at the Project site or other convenient site prior to commencement of construction activities. Conduct the meeting to review responsibilities and personnel assignments.
 - 1. Attendees: Authorized representatives of Owner, the Engineer, and their consultants; the Contractor and its superintendent; major subcontractors; manufacturers; suppliers and other concerned parties shall each be represented at the conference. All participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
 - 2. Agenda: Discuss items of significance that could affect progress, including the following:
 - a. Tentative construction schedule.
 - b. Phasing.
 - c. Critical work sequencing.
 - d. Designation of responsible personnel.
 - e. Procedures for processing field decisions and Change Orders.
 - f. Procedures for processing Applications for Payment.
 - g. Distribution of the Contract Documents.
 - h. Submittal procedures.
 - i. Preparation of Record Documents.
 - j. Use of the premises.

- k. Responsibility for temporary facilities and controls.
 - l. Parking availability.
 - m. Work and storage areas.
 - n. Equipment deliveries and priorities.
 - o. Safety procedures.
 - p. First aid.
 - q. Security.
 - r. Progress cleaning.
 - s. Working hours.
 - t. Housekeeping.
 - u. Subcontractors.
 - v. Preliminary Schedule of Shop Drawings and Samples.
 - w. Contractor's Schedule of Values.
- C. Progress Meetings: Conduct progress meetings at the Project Site at regularly scheduled intervals. Coordinate dates of meetings with preparation of payment requests.
- 1. Attendees: In addition to representatives of the Owner and Engineer, each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
 - 2. Agenda: Review and correct or approve minutes of previous progress meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to the current status of Project.
 - a. Contractor's Construction Schedule: Review progress since the last meeting. Determine whether each activity is on time, ahead of schedule, or behind schedule, in relation to Contractor's Construction Schedule. Determine how construction behind schedule will be expedited; secure commitments from parties involved to do so. Discuss whether schedule revisions are required to ensure that current and subsequent activities will be completed within the Contract Time.
 - b. Review present and future needs of each entity present, including the following:
 - 1) Interface requirements.
 - 2) Time.
 - 3) Sequence of operations.
 - 4) Status of submittals.
 - 5) Deliveries.
 - 6) Access.
 - 7) Site utilization.
 - 8) Temporary facilities and controls.
 - 9) Work hours.
 - 10) Hazards and risks.
 - 11) Progress cleaning.
 - 12) Quality and work standards.
 - 13) Change Orders.
 - 14) Documentation of information for payment requests.
 - 3. Reporting: No later than 3 days after each progress meeting date, distribute copies of minutes of the meeting to each party present and to parties who should have been present. Include a brief summary, in narrative form, of progress since the previous meeting and report.

- a. Schedule Updating: Revise Contractor's Construction Schedule after each progress meeting where revisions to the schedule have been made or recognized. Issue the revised schedule concurrently with the report of each meeting.

PART 2 – PRODUCTS (Not Applicable)

PART 3 – EXECUTION

3.1 GENERAL INSTALLATION PROVISIONS

- A. Inspection of Conditions: Require the Installer of each major component to inspect both the substrate and conditions under which Work is to be performed. Do not proceed until unsatisfactory conditions have been corrected in an acceptable manner.
- B. Manufacturer's Instructions: Comply with manufacturer's installation instructions and recommendations, to the extent that those instructions and recommendations are more explicit or stringent than requirements contained in Contract Documents.
- C. Inspect materials or equipment immediately upon delivery and again prior to installation. Reject damaged and defective items.
- D. Provide attachment and connection devices and methods necessary for securing Work. Secure Work true to line and level. Allow for expansion and building movement.
- E. Visual Effects: Provide uniform joint widths in exposed Work. Arrange joints in exposed Work to obtain the best visual effect. Refer questionable choices to the Engineer for final decision.
- F. Recheck measurements and dimensions, before starting each installation.
- G. Install each component during weather conditions and Project status that will ensure the best possible results. Isolate each part of the completed construction from incompatible material as necessary to prevent deterioration.
- H. Coordinate temporary enclosures with required inspections and tests, to minimize the necessity of uncovering completed construction for that purpose.
- I. Mounting Heights: Where mounting heights are not indicated, install individual components at standard mounting heights recognized within the industry for the particular application indicated. Refer questionable mounting height decisions to the Engineer for final decision.

3.2 CLEANING AND PROTECTION

- A. During handling and installation, clean and protect construction in progress and adjoining materials in place. Apply protective covering where required to ensure protection from damage or deterioration at Substantial Completion.
- B. Clean and maintain completed construction as frequently as necessary through the remainder of the construction period. Adjust and lubricate operable components to ensure operability without damaging effects.
- C. Limiting Exposures: Supervise construction activities to ensure that no part of the construction completed or in progress, is subject to harmful, dangerous, damaging, or otherwise deleterious

exposure during the construction period. Where applicable, such exposures include, but are not limited to, the following:

1. Excessive static or dynamic loading.
2. Excessive internal or external pressures.
3. Excessively high or low temperatures.
4. Thermal shock.
5. Excessively high or low humidity.
6. Air contamination or pollution.
7. Water or ice.
8. Solvents.
9. Chemicals.
10. Light.
11. Radiation.
12. Puncture.
13. Abrasion.
14. Heavy traffic.
15. Soiling, staining and corrosion.
16. Bacteria.
17. Rodent and insect infestation.
18. Combustion.
19. Electrical current.
20. High speed operation.
21. Improper lubrication.
22. Unusual wear or other misuse.
23. Contact between incompatible materials.
24. Destructive testing.
25. Misalignment.
26. Excessive weathering.
27. Unprotected storage.
28. Improper shipping or handling.
29. Theft.
30. Vandalism.

END OF SECTION

SECTION 013300 – SUBMITTAL PROCEDURES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes administrative and procedural requirements for submitting Shop Drawings, Product Data, Samples, and other miscellaneous submittals.

1.2 DEFINITIONS

- A. Action Submittals: Written and graphic information that requires Engineer's responsive action.
- B. Informational Submittals: Written information that does not require Engineer's approval. Submittals may be rejected for not complying with requirements.
- C. File Transfer Protocol (FTP): Communications protocol that enables transfer of files to and from another computer over a network and that serves as the basis for standard Internet protocols. An FTP site is a portion of a network located outside of network firewalls within which internal and external users are able to access files.
- D. Portable Document Format (PDF): An open standard file format licensed by Adobe Systems used for representing documents in a device-independent and display resolution-independent fixed-layout document format.

1.3 SUBMITTAL ADMINISTRATIVE REQUIREMENTS:

- A. Engineer's Digital Data Files: Electronic digital data files of the Contract Drawings will be provided by Engineer for Contractor's use in preparing submittals.
 - 1. Engineer will furnish Contractor one set of digital data drawing files of the Contract Drawings for use in preparing Shop Drawings and Project record drawings.
 - a. Engineer makes no representations as to the accuracy or completeness of digital data drawing files as they relate to the Contract Drawings.
 - b. Digital Drawing Software Program: The Contract Drawings are available in AutoCAD Release 2018.
 - c. Contractor shall execute data licensing agreement.
- B. Coordination: Coordinate preparation and processing of submittals with performance of construction activities.
 - 1. Coordinate each submittal with fabrication, purchasing, testing, delivery, other submittals, and related activities that require sequential activity.
 - 2. Submit all submittal items required for each Specification Section concurrently unless partial submittals for portions of the Work are indicated on approved submittal schedule.
 - 3. Submit action submittals and informational submittals required by the same Specification Section as separate packages under separate transmittals.
 - 4. Coordinate transmittal of different types of submittals for related parts of the Work so processing will not be delayed because of need to review submittals concurrently for coordination.
 - a. Engineer reserves the right to withhold action on a submittal requiring coordination with other submittals until related submittals are received.

- C. Processing Time: Allow time for submittal review, including time for resubmittals, as follows. Time for review shall commence on Engineer's receipt of submittal. No extension of the Contract Time will be authorized because of failure to transmit submittals enough in advance of the Work to permit processing, including resubmittals.
1. Initial Review: Allow 15 days for initial review of each submittal. Allow additional time if coordination with subsequent submittals is required. Engineer will advise Contractor when a submittal being processed must be delayed for coordination.
 2. Intermediate Review: If intermediate submittal is necessary, process it in same manner as initial submittal.
 3. Resubmittal Review: Allow 15 days for review of each resubmittal.
 4. Concurrent Consultant Review: Where the Contract Documents indicate that submittals may be transmitted simultaneously to Engineer and to Engineer's consultants, allow 15 days for review of each submittal. Submittal will be returned to Engineer before being returned to Contractor.
- D. Electronic Submittals: Identify and incorporate information in each electronic submittal file as follows:
1. Assemble complete submittal package into a single indexed file incorporating submittal requirements of a single Specification Section and transmittal form with links enabling navigation to each item.
 2. Name file with submittal number or other unique identifier, including revision identifier.
 - a. File name shall use project identifier and Specification Section number followed by a decimal point and then a sequential number (e.g., AHS-061000.01). Resubmittals shall include an alphabetic suffix after another decimal point (e.g., AHS-061000.01.A).
 3. Provide means for insertion to permanently record Contractor's review and approval markings and action taken by Engineer.
 4. Transmittal Form for Electronic Submittals: Use electronic form acceptable to Owner, containing the following information:
 - a. Project name.
 - b. Date.
 - c. Name and address of Engineer.
 - d. Name of Construction Manager.
 - e. Name of Contractor.
 - f. Name of firm or entity that prepared submittal.
 - g. Names of subcontractor, manufacturer, and supplier.
 - h. Category and type of submittal.
 - i. Submittal purpose and description.
 - j. Specification Section number and title.
 - k. Specification paragraph number or drawing designation and generic name for each of multiple items.
 - l. Drawing number and detail references, as appropriate.
 - m. Location(s) where product is to be installed, as appropriate.
 - n. Related physical samples submitted directly.
 - o. Indication of full or partial submittal.
 - p. Transmittal number, numbered consecutively.
 - q. Submittal and transmittal distribution record.
 - r. Other necessary identification.
 - s. Remarks.

5. Metadata: Include the following information as keywords in the electronic submittal file metadata:
 - a. Project name.
 - b. Number and title of appropriate Specification Section.
 - c. Manufacturer name.
 - d. Product name.
- E. Options: Identify options requiring selection by Engineer.
- F. Deviations and Additional Information: On an attached separate sheet, prepared on Contractor's letterhead, record relevant information, requests for data, revisions other than those requested by Engineer on previous submittals, and deviations from requirements in the Contract Documents, including minor variations and limitations. Include same identification information as related submittal.
- G. Resubmittals: Make resubmittals in same form and number of copies as initial submittal.
 1. Note date and content of previous submittal.
 2. Note date and content of revision in label or title block and clearly indicate extent of revision.
 3. Resubmit submittals until they are marked with approval notation from action stamp.
- H. Distribution: Furnish copies of final submittals to manufacturers, subcontractors, suppliers, fabricators, installers, authorities having jurisdiction, and others as necessary for performance of construction activities. Show distribution on transmittal forms.
- I. Use for Construction: Retain complete copies of submittals on Project site. Use only final action submittals that are marked with approval notation from Engineer's action stamp.

PART 2 – PRODUCTS

2.1 SUBMITTAL PROCEDURES

- A. General Submittal Procedure Requirements: Prepare and submit submittals required by individual Specification Sections. Types of submittals are indicated in individual Specification Sections.
 1. Submit electronic submittals via email as PDF electronic files.
 - a. Engineer will return annotated file. Annotate and retain one copy of file as an electronic Project record document file.
 2. Certificates and Certifications Submittals: Provide a statement that includes signature of entity responsible for preparing certification. Certificates and certifications shall be signed by an officer or other individual authorized to sign documents on behalf of that entity.
- B. Product Data: Collect information into a single submittal for each element of construction and type of product or equipment.
 1. If information must be specially prepared for submittal because standard published data are not suitable for use, submit as Shop Drawings, not as Product Data.
 2. Mark each copy of each submittal to show which products and options are applicable.
 3. Include the following information, as applicable:
 - a. Manufacturer's catalog cuts.
 - b. Manufacturer's product specifications.
 - c. Standard color charts.
 - d. Statement of compliance with specified referenced standards.

- e. Testing by recognized testing agency.
 - f. Application of testing agency labels and seals.
 - g. Notation of coordination requirements.
 - h. Availability and delivery time information.
 - 4. For equipment, include the following in addition to the above, as applicable:
 - a. Wiring diagrams showing factory-installed wiring.
 - b. Printed performance curves.
 - c. Operational range diagrams.
 - d. Clearances required to other construction, if not indicated on accompanying Shop Drawings.
 - 5. Submit Product Data before or concurrent with Samples.
 - 6. Submit Product Data in the following format:
 - a. PDF electronic file.
- C. Shop Drawings: Prepare Project-specific information, drawn accurately to scale. Do not base Shop Drawings on reproductions of the Contract Documents or standard printed data, unless submittal based on Engineer's digital data drawing files is otherwise permitted.
- 1. Preparation: Fully illustrate requirements in the Contract Documents. Include the following information, as applicable:
 - a. Identification of products.
 - b. Schedules.
 - c. Compliance with specified standards.
 - d. Notation of coordination requirements.
 - e. Notation of dimensions established by field measurement.
 - f. Relationship and attachment to adjoining construction clearly indicated.
 - g. Seal and signature of professional engineer if specified.
 - 2. Sheet Size: Except for templates, patterns, and similar full-size drawings, submit Shop Drawings on sheets at least 8-1/2 by 11 inches but no larger than 30 by 42 inches.
 - 3. Submit Shop Drawings in the following format:
 - a. PDF electronic file.
- D. Samples: Submit Samples for review of kind, color, pattern, and texture for a check of these characteristics with other elements and for a comparison of these characteristics between submittal and actual component as delivered and installed.
- 1. Transmit Samples that contain multiple, related components such as accessories together in one submittal package.
 - 2. Identification: Attach label on unexposed side of Samples that includes the following:
 - a. Generic description of Sample.
 - b. Product name and name of manufacturer.
 - c. Sample source.
 - d. Number and title of applicable Specification Section.
 - e. Specification paragraph number and generic name of each item.
 - 3. For projects where electronic submittals are required, provide corresponding electronic submittal of Sample transmittal, digital image file illustrating Sample characteristics, and identification information for record.
 - 4. Disposition: Maintain sets of approved Samples at Project site, available for quality-control comparisons throughout the course of construction activity. Sample sets may be used to determine final acceptance of construction associated with each set.

- a. Samples that may be incorporated into the Work are indicated in individual Specification Sections. Such Samples must be in an undamaged condition at time of use.
 - b. Samples not incorporated into the Work, or otherwise designated as Owner's property, are the property of Contractor.
- 5. Samples for Initial Selection: Submit manufacturer's color charts consisting of units or sections of units showing the full range of colors, textures, and patterns available.
 - a. Number of Samples: Submit 1 full set of available choices where color, pattern, texture, or similar characteristics are required to be selected from manufacturer's product line. Engineer will return submittal with options selected.
- 6. Samples for Verification: Submit full-size units or Samples of size indicated, prepared from same material to be used for the Work, cured and finished in manner specified, and physically identical with material or product proposed for use, and that show full range of color and texture variations expected. Samples include, but are not limited to, the following: partial sections of manufactured or fabricated components; small cuts or containers of materials; complete units of repetitively used materials; swatches showing color, texture, and pattern; color range sets; and components used for independent testing and inspection.
 - a. Number of Samples: Submit 3 sets of Samples. Engineer will retain 2 Sample sets; remainder will be returned.
 - 1) Submit a single Sample where assembly details, workmanship, fabrication techniques, connections, operation, and other similar characteristics are to be demonstrated.
 - 2) If variation in color, pattern, texture, or other characteristic is inherent in material or product represented by a Sample, submit at least 3 sets of paired units that show approximate limits of variations.
- E. Product Schedule: As required in individual Specification Sections, prepare a written summary indicating types of products required for the Work and their intended location. Include the following information in tabular form:
 - 1. Type of product. Include unique identifier for each product indicated in the Contract Documents or assigned by Contractor if none is indicated.
 - 2. Manufacturer and product name, and model number if applicable.
 - 3. Number and name of room or space.
 - 4. Location within room or space.
- F. Coordination Drawing Submittals: Comply with requirements specified in Division 01 Section "Project Management and Coordination."
- G. Closeout Submittals and Maintenance Material Submittals: Comply with requirements specified in Division 01 Section "Closeout Procedures."
- H. Qualification Data: Prepare written information that demonstrates capabilities and experience of firm or person. Include lists of completed projects with project names and addresses, contact information of Engineers and owners, and other information specified.
- I. Installer Certificates: Submit written statements on manufacturer's letterhead certifying that Installer complies with requirements in the Contract Documents and, where required, is authorized by manufacturer for this specific Project.
- J. Manufacturer Certificates: Submit written statements on manufacturer's letterhead certifying that manufacturer complies with requirements in the Contract Documents. Include evidence of manufacturing experience where required.

- K. Product Certificates: Submit written statements on manufacturer's letterhead certifying that product complies with requirements in the Contract Documents.
- L. Material Certificates: Submit written statements on manufacturer's letterhead certifying that material complies with requirements in the Contract Documents.
- M. Material Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting test results of material for compliance with requirements in the Contract Documents.
- N. Product Test Reports: Submit written reports indicating that current product produced by manufacturer complies with requirements in the Contract Documents. Base reports on evaluation of tests performed by manufacturer and witnessed by a qualified testing agency, or on comprehensive tests performed by a qualified testing agency.
- O. Preconstruction Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of tests performed before installation of product, for compliance with performance requirements in the Contract Documents.
- P. Compatibility Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of compatibility tests performed before installation of product. Include written recommendations for primers and substrate preparation needed for adhesion.
- Q. Field Test Reports: Submit written reports indicating and interpreting results of field tests performed either during installation of product or after product is installed in its final location, for compliance with requirements in the Contract Documents.

2.2 CONTRACTOR'S PROJECT HEALTH & SAFETY PLAN

- A. No later than the Pre-construction meeting, the Contractor shall submit to the Engineer a written Project Health & Safety Plan, which states the Contractor's company policy relative to safety. The plan must also address specific health and safety concerns, which are expected to be encountered on the project. As a minimum this plan shall include:
 - 1. Listing of project and company safety officers.
 - 2. Specific company safety policies.
 - 3. Employee Safety Training Program.
 - 4. Administrative procedures to handle employee health & safety concerns.
 - 5. Procedures for insuring worker compliance with health and safety requirements.
- B. The Contractor shall be responsible to ensure that each Subcontractor employed on the project complies with the requirements of this section either by submitting a copy of the subcontractor's Project Health & Safety Plan or by submitting a letter from the Subcontractor stating that they will comply with the provisions of the Contractor's Project Health & Safety Plan.
- C. Submission of the required Project Health & Safety Plan by the Contractor is primarily for information or record purposes and shall not be construed to imply approval by the Engineer or to relieve the Contractor from the responsibility to adequately protect the health & safety of all workers involved in the project.

PART 3 – EXECUTION

3.1 CONTRACTOR'S REVIEW

- A. Review each submittal and check for compliance with the Contract Documents. Note corrections and field dimensions. Mark with approval stamp before submitting to Engineer.
- B. Approval Stamp: Stamp each submittal with a uniform, approval stamp. Include Project name and location, submittal number, Specification Section title and number, name of reviewer, date of Contractor's approval, and statement certifying that submittal has been reviewed, checked, and approved for compliance with the Contract Documents.

3.2 ENGINEER'S ACTION

- A. General: Engineer will not review submittals that do not bear Contractor's approval stamp and will return them without action.
- B. Action Submittals: Engineer will review each submittal, make marks to indicate corrections or modifications required, and return it. Engineer will stamp each submittal with an action stamp and will mark stamp appropriately to indicate action taken, as follows:
 - 1. Final Unrestricted Release: Where submittals are marked "No Exceptions Taken," that part of the Work covered by the submittal may proceed provided it complies with requirements of the Contract Documents; final acceptance will depend upon that compliance.
 - 2. Final-But-Restricted Release: When submittals are marked "Make Corrections Noted," that part of the Work covered by the submittal may proceed provided it complies with notations or corrections on the submittal and requirements of the Contract Documents; final acceptance will depend on that compliance.
 - 3. Returned for Resubmittal: When submittal is marked "Revise and Resubmit," "Rejected," or "Submit Specified Item," do not proceed with that part of the Work covered by the submittal, including purchasing, fabrication, delivery, or other activity. Revise or prepare a new submittal in accordance with the notations; resubmit without delay. Repeat if necessary to obtain a different action mark.
 - a. Do not permit submittals marked "Revise and Resubmit," "Rejected," or "Submit Specified Item" to be used at the Project site, or elsewhere where Work is in progress.
 - 4. Other Action: Where a submittal is primarily for information or record purposes, special processing or other activity, the submittal will be returned, marked "Action Not Required."
- C. Informational Submittals: Engineer will review each submittal and will not return it or will reject and return it if it does not comply with requirements. Engineer will forward each submittal to appropriate party.
- D. Submittals not required by the Contract Documents will not be reviewed and may be discarded.

END OF SECTION

SECTION 017700 – CLOSEOUT PROCEDURES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes administrative and procedural requirements for contract closeout, including, but not limited to, the following:
 - 1. Inspection procedures.
 - 2. Project Record Documents.
 - 3. Operation and maintenance manuals.
 - 4. Warranties.
 - 5. Instruction of Owner's personnel.
 - 6. Final cleaning.

1.2 SUBSTANTIAL COMPLETION

- A. Preliminary Procedures: Before requesting inspection for determining date of Substantial Completion, complete the following. List items below that are incomplete in request.
 - 1. Prepare a list of items to be completed and corrected (punch list), the value of items on the list, and reasons why the Work is not complete.
 - 2. Advise Owner of pending insurance changeover requirements.
 - 3. Submit specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
 - 4. Prepare and submit Project Record Documents, operation and maintenance manuals, Final Completion construction photographs, damage or settlement surveys, property surveys, and similar final record information.
 - 5. Deliver tools, spare parts, extra materials, and similar items to location designated by Owner. Label with manufacturer's name and model number where applicable.
 - 6. Terminate and remove temporary facilities from Project site, along with construction tools and similar elements.
 - 7. Complete final cleaning requirements, including touchup painting.
 - 8. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.
- B. Inspection: Submit a written request for inspection for Substantial Completion. On receipt of request, Engineer will either proceed with inspection or notify Contractor of unfulfilled requirements. Engineer will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Engineer, that must be completed or corrected before certificate will be issued.
 - 1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
 - 2. Results of completed inspection will form the basis of requirements for Final Completion.

1.3 FINAL COMPLETION

- A. Preliminary Procedures: Before requesting final inspection for determining date of Final Completion, complete the following:
 - 1. Submit a final Application for Payment according to Division 1 Section "Payment Procedures."

2. Submit certified copy of Engineer's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Engineer. The certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
 3. Submit evidence of final, continuing insurance coverage complying with insurance requirements.
 4. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems.
- B. Inspection: Submit a written request for final inspection for acceptance. On receipt of request, Engineer will either proceed with inspection or notify Contractor of unfulfilled requirements. Engineer will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.
1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.

1.4 PROJECT RECORD DOCUMENTS

- A. General: Do not use Project Record Documents for construction purposes. Protect Project Record Documents from deterioration and loss. Provide access to Project Record Documents for Engineer's reference during normal working hours.
- B. Record Drawings: Maintain and submit one set of blue- or black-line white prints of Contract Drawings and Shop Drawings.
1. Mark Record Prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to prepare the marked-up Record Prints.
 - a. Give particular attention to information on concealed elements that cannot be readily identified and recorded later.
 - b. Accurately record information in an understandable drawing technique.
 - c. Record data as soon as possible after obtaining it. Record and check the markup before enclosing concealed installations.
 - d. Mark Contract Drawings or Shop Drawings, whichever is most capable of showing actual physical conditions, completely and accurately. Where Shop Drawings are marked, show cross-reference on Contract Drawings.
 2. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at the same location.
 3. Mark important additional information that was either shown schematically or omitted from original Drawings.
 4. Note Construction Change Directive numbers, Change Order numbers, alternate numbers, and similar identification where applicable.
 5. Identify and date each Record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location. Organize into manageable sets; bind each set with durable paper cover sheets. Include identification on cover sheets.
- C. Record Specifications: Submit one copy of Project's Specifications, including addenda and contract modifications. Mark copy to indicate the actual product installation where installation varies from that indicated in Specifications, addenda, and contract modifications.
1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 2. Mark copy with the proprietary name and model number of products, materials, and equipment furnished, including substitutions and product options selected.

3. Note related Change Orders, Record Drawings, and Product Data, where applicable.

1.5 OPERATION AND MAINTENANCE MANUALS

- A. Assemble a complete set of operation and maintenance data indicating the operation and maintenance of each system, subsystem, and piece of equipment not part of a system. Include operation and maintenance data required in individual Specification Sections and as follows:
 1. Operation Data:
 - a. Emergency instructions and procedures.
 - b. System, subsystem, and equipment descriptions, including operating standards.
 - c. Operating procedures, including startup, shutdown, seasonal, and weekend operations.
 - d. Description of controls and sequence of operations.
 - e. Piping diagrams.
 2. Maintenance Data:
 - a. Manufacturer's information, including list of spare parts.
 - b. Name, address, and telephone number of Installer or supplier.
 - c. Maintenance procedures.
 - d. Maintenance and service schedules for preventive and routine maintenance.
 - e. Maintenance record forms.
 - f. Sources of spare parts and maintenance materials.
 - g. Copies of maintenance service agreements.
 - h. Copies of warranties and bonds.
- B. Organize operation and maintenance manuals into suitable sets of manageable size. Bind and index data in heavy-duty, 3-ring, vinyl-covered, loose-leaf binders, in thickness necessary to accommodate contents, with pocket inside the covers to receive folded oversized sheets. Identify each binder on front and spine with the printed title "OPERATION AND MAINTENANCE MANUAL," Project name, and subject matter of contents.

1.6 WARRANTIES

- A. Submittal Time: Submit written warranties on request of Engineer for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated.
- B. Organize warranty documents into an orderly sequence based on the table of contents of the Project Manual.
 1. Bind warranties and bonds in heavy-duty, 3-ring, vinyl-covered, loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2-by-11-inch paper.
 2. Provide heavy paper dividers with plastic-covered tabs for each separate warranty. Mark tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product and the name, address, and telephone number of Installer.
 3. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project name, and name of Contractor.
- C. Provide additional copies of each warranty to include in operation and maintenance manuals.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Cleaning Agents: Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

PART 3 – EXECUTION

3.1 DEMONSTRATION AND TRAINING

- A. Instruction: Instruct Owner's personnel to adjust, operate, and maintain systems, subsystems, and equipment not part of a system.
 - 1. Provide instructors experienced in operation and maintenance procedures.
 - 2. Provide instruction at mutually agreed-on times. For equipment that requires seasonal operation, provide similar instruction at the start of each season.
 - 3. Schedule training with Owner, through Engineer, with at least 7 days advance notice.
 - 4. Coordinate instructors, including providing notification of dates, times, length of instruction, and course content.
- B. Program Structure: Develop an instruction program that includes individual training modules for each system and equipment not part of a system, as required by individual Specification Sections. For each training module, develop a learning objective and teaching outline. Include instruction for the following:
 - 1. System design and operational philosophy.
 - 2. Review of documentation.
 - 3. Operations.
 - 4. Adjustments.
 - 5. Troubleshooting.
 - 6. Maintenance.
 - 7. Repair.

3.2 FINAL CLEANING

- A. General: Provide final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
 - 1. Complete the following cleaning operations before requesting inspection for certification of Final Completion for entire Project:
 - a. Clean Project site, yard, and grounds, in areas disturbed by construction activities, including landscape development areas, of rubbish, waste material, litter, and other foreign substances.
 - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
 - c. Rake grounds that are neither planted nor paved to a smooth, even-textured surface.
 - d. Remove tools, construction equipment, machinery, and surplus material from Project site.

- e. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore reflective surfaces to their original condition.
 - f. Remove labels that are not permanent.
 - g. Touch up and otherwise repair and restore marred, exposed finishes and surfaces. Replace finishes and surfaces that cannot be satisfactorily repaired or restored or that already show evidence of repair or restoration.
 - h. Leave Project clean and ready for occupancy.
- C. Comply with safety standards for cleaning. Do not burn waste materials. Do not bury debris or excess materials on Owner's property. Do not discharge volatile, harmful, or dangerous materials into drainage systems. Remove waste materials from Project site and dispose of lawfully.

END OF SECTION

SECTION 116833 – OUTDOOR SPORTS EQUIPMENT

PART 1 – GENERAL

1.1 WORK INCLUDED

- A. Provide equipment and materials, and do work necessary and construct or provide the following as indicated on the Drawings and as specified. Work shall include but shall not be limited to:
 - 1. Football Equipment:
 - a. Goal Post System

1.2 SUBMITTALS

- A. Shop Drawings:
 - 1. Show application to project.
- B. Provide sealed structural drawings by the qualified professional engineer for goalpost footings.
- C. Product Data: Submit manufacturer's product data and samples as noted for the following:
 - 1. Goal Post System

1.3 QUALITY ASSURANCE

- A. Installer of outdoor sports equipment the playing field shall be the same Contractor. All installed equipment shall be under the supervision of Owner's groundskeeper.
- B. Welding: Qualify procedures and personnel according to AWS D1.1, "Structural Welding Code-Steel," and AWS D1.3, "Structural Welding Code – Sheet Steel."

1.4 WARRANTY

- A. General Warranty: Special warranties specified in this Section shall not deprive the Owner of other rights the Owner may have under other provisions of the Contract Documents and shall be in addition to, and run concurrent with, other warranties made by the Contractor under requirements of the Contract Documents.
- B. Special Warranties:
 - 1. Equipment: Written warranties, executed by the manufacturer of each piece of equipment specified agreeing to repair or replace equipment or components that fail in materials or workmanship with specified warranty period.

PART 2 – PRODUCTS

2.1 FOOTBALL EQUIPMENT

- A. Football Goal Post System:
 - 1. Goal Posts and Appurtenances for the specific sport level by the following or approved equal:

- a. Upright Height:
 - 1) 20 Feet
 - b. Crossbar Width:
 - 1) 23 feet 4 inches.
 - c. Adjustable width.
 - d. Gooseneck Depth:
 - 1) 8 feet
 - e. Material:
 - 1) Aluminum
2. Products and Suppliers:
- a. Sportsfield Specialties, Inc. (www.sportsfieldspecialties.com):
 - 1) Goal System, Model No. GP820HS
 - 2) Foundation Box and Cover, Model No. GPAFNG.
 - 3) Goal Post Pads, Model No. GPPR, 18 ounce.
 - a) Padding shall be manufacturer's standard color with custom lettering and or graphics.
 - b. Triman Tele-Goal (800) 822-6886.
 - c. Gilman Gear [Select appropriate goalpost]:
 - 1) LNG23 (23 feet 4 inches wide), 8-foot offset, Gilman Gear.
 - d. UCS Sports and Recreation Equipment:
 - 1) 8-foot offset.
 - 2) (800) 526-4856.
 - e. Or approved equal.
3. Paint:
- a. Powder Coated Saturn Yellow.

PART 3 – EXECUTION

3.1 INSTALLATION

- A. General: Install in accordance with manufacturers recommendations and approved shop drawings.
- B. Football Equipment:
 - 1. Football Goal Post System:
 - a. Install new equipment as per manufacturer's instructions for location, height of crossbar and level.
 - b. Contractor to submit drawing of footing sealed by a licensed engineer and approved prior to installation of footing or sleeve.

END OF SECTION

SECTION 116833.43 – TRACK AND FIELD EQUIPMENT

PART 1 – GENERAL

1.1 SUMMARY

- A. This section covers all labor and materials required to install the following:
 - 1. In-ground track and field equipment.
 - 2. Field event materials.
 - a. Sand.
 - b. Rock Dust.
- B. The Contractor is responsible for the purchase and installation of all sports equipment. The Track & Field Synthetic Surfacing Contractor is responsible for installation of synthetic surface in, around and on top of the specified sports equipment.

1.2 CODES AND STANDARDS

- A. Codes and standards follow the current guidelines set forth by the National Federation of State High School Associations (NFSHSA).

1.3 SUBMITTALS

- A. The following information shall be submitted prior to installation of specified work.
 - 1. Standard printed specifications and diagrams or drawings depicting installation directions and dimensions for all in-ground sports equipment.
 - 2. Installation process and requirements for subbase (stone and asphalt) and any conditions that may limit the installation or affect quality of installation.
 - 3. Material safety data sheets on all products, as necessary.
 - 4. Contractor to supply Owner with a 1-gallon sample of field event material product(s) for visual inspection and testing.

1.4 QUALITY ASSURANCE

- A. The Contractor shall only accept bids from those vendors or manufacturers that have been pre-approved or identified as approved equivalent.
- B. The Contractor shall only accept bids from those vendors or manufacturers that have been pre-approved, identified as approved equivalent or that meet the requirements as an equivalent product.

PART 2 – PRODUCTS

2.1 IN-GROUND TRACK & FIELD EQUIPMENT

- A. The Contractor is responsible to provide and install all permanent, in-ground track & field event equipment as specified by these specifications and shown on the project drawings. The products must meet NFSHSA regulations.
- B. The physical make-up of these products vary across the country; therefore the Contractor shall use his best efforts to supply the Owner with a product that best meets the performance specifications listed below.

- C. The in-ground track & field equipment is available from the following:
 - 1. Sportsfield Specialties: Contact: Brian Jaeger (Southeast) Tel.: (607) 267-3621.
 - 2. UCS Spirit: Contact: Mike Chappell; Telephone: (800) 526-4856.
 - 3. Gill Athletics: Contact: Mike Cunningham; Telephone: (800) 637-3090.
- D. In-ground Equipment (Based on Sportsfield Specialties Model # or Approved Equivalent)
 - 1. Aynor HS:
 - a. One (1) cast aluminum pole vault box without the cover. Model # PVBCAW.
 - b. Two (2) mesh covers for sand pits. Model # SPCVRMCSTM.
 - c. One (1) discus cage with ground sleeves. Model # DCHSEA+DCHSBNS.
 - d. One (1) web style shot put circle. Model # TFSP.
 - e. One (1) web style discus circle. Model # TFD.
 - f. One (1) toe board for depressed circle. Model # SPTBCARHS.
 - 2. Green Sea Floyds HS:
 - a. One (1) cast aluminum pole vault box without the cover. Model # PVBCAW.
 - b. Two (2) mesh covers for sand pits. Model # SPCVRMCSTM.
 - c. One (1) discus cage with ground sleeves. Model # DCHSEA+DCHSBNS.
 - d. One (1) web style shot put circle. Model # TFSP.
 - e. One (1) web style discus circle. Model # TFD.
 - f. One (1) toe board for depressed circle. Model # SPTBCARHS.
 - 3. North Myrtle Beach HS:
 - a. One (1) cast aluminum pole vault box without the cover. Model # PVBCAW.
 - b. Two (2) mesh covers for sand pits. Model # SPCVRMCSTM.
 - c. One (1) discus cage with ground sleeves. Model # DCHSEA+DCHSBNS.
 - d. One (1) web style shot put circle. Model # TFSP.
 - e. One (1) web style discus circle. Model # TFD.
 - f. One (1) toe board for depressed circle. Model # SPTBCARHS.

2.2 FIELD EVENT MATERIALS

- A. Sand:
 - 1. The sand shall be washed and sized as follows:
 - a. 2008 IAAF Track & Field Facilities Manual (2.3.1.5):
 - 1) For the safety of the athletes, the sand must (to avoid hardening as a result of moisture) consist of washed river sand or pure quartz sand, without organic components, maximum 2mm granules, of which not more than 5% in weight is less than 0.2mm.
 - 2. Sand shall be free of trash, organic matter, clay, silt, and rocks.
 - a. Top 6" of Sand color to be white.
 - 3. Sand shall have the following technical data:
 - a. Water permeability or filtration rate with a minimum of 20 inches/hour.
 - b. Bulk density of 1.55 grams per cubic centimeter.
 - c. Penetrometer Reading of 1.8 to 2.2 kg/cm².
 - d. Sand shape of high sphericity and rounded.
- B. Rock Dust:
 - 1. The shot-put landing area shall consist of a material that is firmly compacted, yet porous to allow vertical drainage. The Contractor shall provide a one-gallon sample of the proposed

material for approval by the Owner prior to installation. The material shall be compacted to at least 90 percent of Standard AASHTO Density with discing, sprinkling, and rolling as necessary. All material aggregate larger than 1/4-inch in diameter that comes to the surface during discing shall be removed prior to compacting operations.

2. Rock dust shall meet the below sieve analysis

Screen No.	% Passing
3/8	100
4	100
8	86
16	65
30	45
50	35
100	25
200	15

PART 3 – EXECUTION

3.1 INSTALLATION OF SPORTS EQUIPMENT

- A. The installation of the track and field equipment stated herein shall follow the directions of the manufacturer and/or vendor. Shop drawings must be submitted and approved prior to installation of equipment.
- B. Sand:
 1. The sand should be one of the last items installed on the facility to maintain the physical properties.
 2. Do not install the sand until drain pipe is installed and connected to drainage system.

3.2 ADJUSTING AND CLEANING

- A. Upon completion of installation, test operation to demonstrate satisfactory operation acceptable to Owner.
- B. Clean or replace unsuitable materials.

END OF SECTION

SECTION 260001 – ELECTRICAL

PART 1 – GENERAL

1.1 SCOPE OF WORK

- A. Provide all labor, material, tools, equipment, transportation, and services necessary for and incidental to completion of all electrical work as indicated on the Drawings and/or as specified herein.

1.2 DRAWING USE AND INTERPRETATION

- A. The Drawings are diagrammatic and indicate the general arrangement of systems and equipment unless indicated otherwise by dimensions or details. Exact equipment locations and raceway routing, etc. shall be governed by actual field conditions and/or instructions of the Engineer and/or Owner's Representative.

1.3 COMPLETE SYSTEMS

- A. General: Furnish and install all materials as required for complete systems, including all parts obviously or reasonably incidental to a complete installation, whether specifically indicated or not. All systems shall be completely assembled, tested, adjusted and demonstrated to be ready for operation prior to Owner's acceptance.
- B. Wiring: The wiring specified and/or shown on the Drawings is for complete and workable systems. Any deviations from the wiring shown due to a particular manufacturer's or subcontractor's requirements shall be made at no cost to either the Contract or the Owner.

1.4 CODES AND REGULATIONS

- A. General: Comply with the latest recognized edition of the National Electrical Code (NEC) and all governing federal, state, and local laws, ordinances, codes, rules, and regulations. Where the Contract Documents exceed these requirements, the Contract Documents shall govern. In no case shall work be installed contrary to or below minimum legal standards.
- B. Utilities: Comply with all applicable rules, restrictions, and requirements of the utility companies serving the project site/facilities.
- C. Non-Compliance: Should any work be performed which is found not to comply with any of the above codes and regulations, provide all work and pay all costs necessary to correct the deficiencies.

1.5 REFERENCE STANDARDS

- A. All latest published standards of the following associations/organizations shall be followed and applied where applicable as minimum requirements:
 - 1. (ADA), Americans with Disabilities Act.
 - 2. (ANSI), American National Standards Institute.
 - 3. (ASTM), American Society for Testing and Materials.
 - 4. (CBM), Certified Ballast Manufacturer.
 - 5. (EPACT), National Energy Policy Act.
 - 6. (ETL), Electrical Testing Laboratory.
 - 7. (ICEA), Insulated Cable Engineers Association.

8. (IEEE), Institute of Electrical and Electronic Engineers.
9. (IESNA), Illuminating Engineering Society of North America.
10. (NBFU), National Board of Fire Underwriters.
11. (NEMA), National Electrical Manufacturers Association.
12. (NESC), National Electrical Safety Code.
13. (NFPA), National Fire Protection Association.
14. (UL), Underwriter's Laboratories.

1.6 PERMITS

- A. General: Obtain and pay for any and all permits required by all applicable agencies, prior to commencing work.

1.7 SUBMITTALS

- A. General: Prepare and submit for approval, per the procedures set forth in Division 1, all submittals required by Division 1, this section, and by all other Contract Documents.
- B. Types: Required submittals may include: Schedule of Values; List of Subcontractors; Product Data; Shop Drawings; Samples; Test Reports; Certifications; Warranties; Maintenance Manuals; Record Drawings; and various administrative submittals.
- C. Number of Copies: As indicated in Division 1, Division 26, or elsewhere in the Contract Documents. For quantities indicated in the Contract Documents or specification sections other than Division 26 sections, increase number of copies by one to allow for the Engineer's record copy. Minimum number of copies per submittal: three.
- D. Product Data: Submit for all basic electrical equipment, devices, and materials to be used on the project. Product data to consist of manufacturer's standard catalog cuts, descriptive literature and/or diagrams, in 8-1/2-inch-by-11-inch format, and in sufficient detail so as to clearly indicate compliance with all specified requirements and standards. Mark each copy to clearly indicate proposed product, options, finishes, etc.
- E. Shop Drawings: Submit for all custom equipment and systems (e.g., panelboards) to be used on the project. Shop Drawings to be newly prepared, specifically for this project, and shall include all information listed in the Shop Drawings submittal requirements in the respective specification section. Include all pertinent information such as equipment/system identification, manufacturer, dimensions, nameplate data, sizes, capacities, types, materials, performance data, features, accessories, wiring diagrams, etc., in sufficient detail so as to clearly indicate compliance with all specified requirements and standards. For control systems, provide computer generated control ladder diagrams specifically developed for this project (standard diagrams not acceptable).
- F. Maintenance Manuals: Include operating and maintenance data in accordance with Division 1. Include all Product Data/Shop Drawing submittals as well as descriptions of function, normal operating characteristics and limitations, and manufacturer's printed operating maintenance, trouble shooting, repair, adjustment, and emergency instructions, and complete replacement parts listing.
- G. Record Documents: Prepare and submit in accordance with Division 1. In addition to Division 1 requirements, indicate actual installed locations for all equipment and devices, routing of major interior raceways, locations of all concealed and underground equipment and raceways, and all approved modifications to the Contract Documents, and deviations necessitated by field conditions and change orders.

1.8 QUALITY ASSURANCE

- A. Manufacturers' Qualifications: Not less than three years of experience in the actual production of the specified products.
- B. Installers' Qualifications: Firm with not less than five years of experience in the installation of electrical systems and equipment similar in scope and complexity to those required for this Project, and having successfully completed at least ten comparable scale projects.
- C. Incidental Work: Excavation, backfill, painting, patching, welding, carpentry, mechanical work, concrete pads and the like related to or required for Division 26 work shall be performed by craftsman skilled in the appropriate trade, but shall be provided for under Division 26.

1.9 INSPECTIONS

- A. General: During and upon completion of the work, arrange and pay all associated costs for inspections of all electrical work installed under this contract, in accordance with the Conditions of the Contract.
- B. Inspections Required: As per the laws and regulations of the local and/or state agencies having jurisdiction at the project site.
- C. Inspection Agency: Approved by the local and/or state agencies having jurisdiction at the project site.
- D. Certificates: Submit all required inspection certificates.
- E. Coordination: Coordinate inspections with the local utility.

1.10 DELIVERY STORAGE AND HANDLING

- A. Comply with Division 1 requirements.
- B. Packing and Shipping: Deliver products in original, unopened packaging, properly identified with manufacturer's identification, and compliance labels.
- C. Storage and Protection: Comply with all manufacturer's written recommendations. Store all products in a manner, which shall protect them from damage, weather, and entry of debris.
- D. Damaged Products: Do not install damaged products. Arrange for prompt replacement.

PART 2 – PRODUCTS

2.1 GENERAL

- A. Where Specified: Materials and equipment shall be as specified herein and/or as indicated on the Drawings.
- B. General Requirements: All materials and equipment shall be in accordance with the Contract Documents, and to the extent possible, standard products of the various manufacturers, except where special construction or performance features are called for. All materials and equipment to be new, clean, undamaged, and free of defects and corrosion.

- C. Acceptable Products: The product of a specified or approved manufacturer will be acceptable only when that product complies with or is modified as necessary to comply with all requirements of the Contract Documents.
- D. Common Items: Where more than one of any specific item is required, all shall be of the same type and manufacturer.
- E. UL Listing: All electrical materials and equipment shall be Underwriters' Laboratories (UL) listed and labeled where UL standards and listings exist for such materials or equipment.

2.2 PRODUCT OPTIONS AND SUBSTITUTIONS

- A. Refer to the Conditions of the Contract and Division 1.

2.3 SOIL MATERIALS

- A. Subbase Material: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, crushed slag, or natural or crushed sand.
- B. Drainage Fill: Washed, evenly graded mixture of crushed stone, or crushed or uncrushed gravel, with 100 percent passing a 1-1/2-inch sieve and not more than 5 percent passing a No. 4 sieve.
- C. Backfill and Fill Materials: Materials complying with ASTM D2487 soil classification groups GW, GP, GM, SM, SW, and SP, free of clay, rock, or gravel larger than 2 inches in any dimension, debris, waste, frozen materials, vegetable, and other deleterious matter.

2.4 RACEWAY SYSTEMS

- A. Raceway Sizing: As required by the NEC (minimum) with oversized raceways as indicated and where required for ease of pulling cable.
 - 1. Minimum conduit size: 3/4 inch, unless indicated otherwise.
- B. Raceway Types: Rigid galvanized steel conduit, electrical metallic tubing (EMT), flexible steel conduit, liquid-tight flexible steel conduit and Schedule 40 heavywall and Schedule 80 extra-heavywall rigid non-metallic (PVC) conduit conforming to applicable ANSI, NEMA and UL standards.
- C. Fittings: All raceway fittings (except for rigid non-metallic conduit) to be steel or malleable iron and UL-listed for the intended application. EMT fittings to be compression type.
- D. Outlet Boxes (Concealed in Walls): Non-gangable, galvanized steel with square cornered tile (or masonry) type extension rings or cover.
 - 1. Minimum size: two-gang masonry box or 4-inch square box with single-gang adapter (plaster) ring. Depth of adapter ring to suit application.
 - 2. Minimum depth: 1-1/2 inches.
 - 3. Minimum capacity: 21 cubic inches.
- E. Outlet Boxes (Surface Mounted): Cadmium plated cast or malleable iron.
- F. Pull and Junction Boxes, and Wireways: Use as indicated and required. Junction and pull boxes for general indoor use (dry locations) to be of galvanized code gauge steel construction, minimum 4-inch square by 1-1/2 inches deep with screw-on covers. Wireways to be UL listed, sheet steel

construction with screw-on covers. For exterior and damp or wet indoor locations, use boxes and wireways approved for such use.

- G. Handholes: Light-weight and high-strength, constructed of fiberglass reinforced polymer concrete, gray color, suitable for use at temperatures down to -50 DegF, and resistant to sunlight, weathering, chemicals and freeze-thaw cycles, with bolt-on cover (with standard logo indicating type of service), and designed for in-grade use in areas with light vehicular traffic (5,000-pound load over a 10-inch by 10-inch area).
 - 1. Acceptable Manufacturers:
 - a. Quazite "Composolite."
 - b. Styles "PC" or "PG."
- H. Pipe Sleeves: Rigid steel conduit or iron pipe.
- I. Conduit Seals: For Cast-in-Place Concrete Applications:
 - 1. Acceptable Manufacturers:
 - a. O-Z/Gedney Type "FSK."
 - b. Thunderline Corp. "Link Seal" with "Link Seal Wall Sleeve."
- J. For Core Drilled and Pre-Cast Opening Applications:
 - 1. Acceptable Manufacturers:
 - a. O-Z/Gedney Type "CSML."
 - b. Thunderline Corp. "Link Seal."
- K. Pull Wires: No. 14 AWG zinc-coated steel monofilament plastic line with 200-pound tensile strength.

2.5 600 VOLT CLASS WIRE

- A. General: All wire and cable shall be constructed in accordance with all applicable ICEA, NEMA and IEEE published standards, and shall be UL-listed and labeled. Single-conductor, 98 percent conductivity, annealed, uncoated copper conductors with 600-volt rated type "THHN/THWN" insulation.
- B. Wire shall be annealed bare copper per ANSI/ASTM B3, UL 83, and Federal Specification JC-30A with 600 volt insulation, be stranded (except for #10 AWG and smaller may be solid), and be minimum size #12 AWG (except for control wiring and signal circuits).
- C. Insulation: Provide THHN/THWN insulation for all conductors except XHHW insulation may be used for conductors #4 and larger.
- D. Ampacity of conductors shall be rated for 75 DegC regardless of temperature of conductor insulation when combining circuits in one conduit. Derate conductors and increase size per NEC when installing multiple circuits in a raceway, utilizing 75 DegC ampacity table.
- E. Connectors: Nylon shell insulated metallic screw-on connectors for #14-10 AWG and bolted pressure or compression type lugs and connectors with insulating covers for #8 AWG and larger.

2.6 WIRING DEVICES

- A. GFI Receptacles: Ground fault circuit interrupter, feed-through, duplex type, 125 volt, 20 amp, NEMA 5-20R, with solid-state ground-fault sensing and 5 mA trip level.

1. Acceptable Manufacturers:
 - a. Leviton.
 - b. Arrow-Hart.
 - c. Hubbell.
 - d. Pass and Seymour.
- B. Device Color: Brown, unless directed otherwise.
- C. Coverplates (Exterior Locations): Weatherproof cast aluminum. Receptacles installed in damp or wet locations shall have an enclosure and cover that are weatherproof with the attachment plug inserted or removed per NEC 406.9.

2.7 EQUIPMENT CONNECTIONS

- A. Materials as specified in this section, and as required.

2.8 ELECTRICAL IDENTIFICATION

- A. Nameplates: Three-layer laminated plastic with minimum 3/16-inch high white engraved characters on black background, and punched for mechanical fastening. Fasteners: self-tapping stainless-steel screws or number 10-32 stainless steel machine screws with nuts and flat and lock washers. Each nameplate on all panelboards and switchgear shall indicate the following:
 1. Panel Name.
 2. Voltage, Phase, Number of Wires.
 3. Source.
- B. Underground Warning Tape: 6-inch wide polyethylene tape, permanently bright colored with continuous-printed legend indicating general type of underground line below and "CAUTION." Colors as follows:
 1. Red – Electric.
 2. Orange – Communications.
- C. Marking Pens: Permanent, waterproof, quick drying black ink.
 1. Acceptable Manufacturers:
 - a. Sanford Fine Point "Sharpie."
 - b. Or equal.
- D. Wire Tags: Vinyl or vinyl-cloth self-adhesive wraparound type indicating appropriate circuit number, etc.

2.9 GROUNDING

- A. General: Ground rods, conductors, clamps and connectors, etc., as required.
- B. Ground Rods: Minimum 5/8-inch diameter by 10-foot long copper clad steel.
- C. Welded Connectors: Exothermic process.

2.10 CIRCUIT BREAKERS

- A. Breakers to be added to Existing Panelboards: Same manufacturer, type, and interrupting rating as for the existing breakers in same panelboard.

PART 3 – EXECUTION

3.1 GENERAL

- A. The installation of all electrical work shall be in accordance with the intent of the Contract Documents as determined by the Engineer.
- B. Installation Requirements: All materials and equipment shall be installed as recommended by the respective manufacturers, by mechanics experienced and skilled in their particular trade, in a neat and workmanlike manner, in accordance with the standards of the trade, and so as not to void any warranty or UL listing.
- C. Administration and Supervision: All electrical work shall be performed under the Contractor's direct supervision using sufficient and qualified personnel as necessary to complete the work in accordance with the progress schedule. The Contractor shall assign one or more competent supervisors who shall have authority to accept and execute orders and instructions, and who shall cooperate with the other Contractors and subcontractors, the Engineer, and Owner in all matters to resolve conflicts and avoid delays.

3.2 EXAMINATION

- A. Conditions Verification: Examine the areas and conditions under which the work is to be performed, and identify any conditions detrimental to the proper and timely completion of the work. Do not proceed until unsatisfactory conditions have been corrected.

3.3 COORDINATION

- A. General: Sequence, coordinate and integrate the installation of all electrical materials and equipment for efficient flow of work, in conjunction with the other trades. Review to the Drawings for work of the other trades, and report and resolve any discovered discrepancies, prior to commencing work.
- B. Cooperation: Cooperate with the other Contractors and individual disciplines for placement, anchorage, and accomplishment of the work. Resolve interferences between work of other disciplines or Contractors, prior to commencing installation.
- C. Chases, Slots, and Openings: Arrange for chases, slots, and openings during the progress of construction as required to allow for installation of the electrical work.
- D. Supports and Sleeves: Coordinate the installation of required supporting devices and sleeves to be set in poured-in-place concrete and other structural components as they are constructed.
- E. Obstacles and Interferences: When installing equipment and raceways, provide offsets, fittings, accessories, and changes in elevation or location as necessary to avoid obstacles and interferences, per actual field conditions.
- F. Space Requirements: Electrical equipment sizes indicated on the Drawings are generally based on specified manufacturer. Verify that the proposed equipment will fit in the space indicated on the drawings. Maintain clearances required by NEC.

3.4 DIMENSIONS

- A. Building Dimensions: For exact locations of building elements, refer to dimensioned drawings. However, field measurements take precedence over dimensioned drawings.
- B. Site Dimensions: Field measurements take precedence over scaled electrical site plans.
- C. Limiting Dimensions: Equipment outlines shown on detail drawings of 1/4" = 1'-0" scale or larger and dimensions indicated on the Drawings are limiting dimensions. Do not install equipment exceeding dimensions indicated by outlines on Drawings or equipment or arrangements that reduce indicated clearances.
- D. Establish the exact location of electrical equipment based on the actual field verified dimensions of equipment furnished.

3.5 EQUIPMENT PROTECTION

- A. Protect all electrical equipment, and materials and work from the weather elements, paint, mortar, construction debris and damage until project is substantially complete. Repair, replace, and clean all electrical work so affected.

3.6 ELECTRICAL INSTALLATION - GENERAL

- A. Unfinished and Finished Areas: For the purposes of these electrical specifications, "unfinished" areas shall include mechanical, electrical and telephone equipment rooms. All other areas shall be considered "finished" spaces unless indicated or approved otherwise.
- B. In Unfinished Areas: Raceways, equipment, and devices may be installed concealed or exposed unless indicated otherwise.
- C. In Finished Areas: Conceal all raceway and flush mount all electrical boxes, equipment, and devices unless indicated or approved otherwise. The space above suspended ceilings or behind furred spaces is considered outside finished areas and electrical materials installed within these areas are considered concealed.
- D. Minimum Mounting Height: Install exposed raceway and all other electrical equipment (e.g., lighting fixtures) with not less than 7 feet and 6 inches clear to finished floor unless indicated or approved otherwise, and excluding raceway and equipment mounted on walls.
- E. Dimensions and Clearances: Field measure all dimensions and clearances affecting the installation of electrical work in relation to established datum, building openings and clearances, and work of other trades as construction progresses.
- F. Rough-In Locations: Verify final locations for rough-ins with field measurements and requirements of actual equipment being installed.
- G. Install equipment, conduit, cable tray, hangers, and supports to withstand seismic forces for the seismic zone of the installation.

3.7 LAYOUT

- A. Serviceability: Install electrical equipment and raceways, etc., to readily facilitate servicing, maintenance, and repair or replacement of components and so as to minimize interference with other equipment and installations.

- B. Clearances: Prior to commencing work, verify that all electrical equipment will adequately fit and conform to the indicated and code required clearances in the spaces indicated on the Drawings. If rearrangement is required, submit plan and elevation drawings or sketches indicating proposed rearrangement for the Engineer's approval. Do not rearrange without express written permission of the Engineer.
- C. Right-Of-Way: When laying out electrical work, give priority in available space to steam and condensate lines, sanitary lines, drain lines, fire protection piping, and sheet metal duct work. Provide offsets as required to avoid conflicts. Resolve all conflicts before commencing installation.

3.8 HOLES, SLEEVES, AND OPENINGS

- A. General: Provide all holes, sleeves, and openings required for the completion of Division 26 work and restore all surfaces damaged to match surrounding surfaces. Maintain integrity of all fire and smoke rated barriers using approved firestopping systems. When cutting holes or openings, or installing sleeves, do not cut, damage, or disturb structural elements or reinforcing steel unless approved in writing by the Project Structural Engineer.
- B. Conduit Penetrations: Size core drilled holes so that an annular space of not less than 1/4 inch and not more than 1 inch is left around the conduit. When openings are cut in lieu of core drilled, provide sleeve in rough opening. Size sleeves to provide an annular space of not less than 1/4 inch and not more than 1 inch around the conduit. Patch around sleeve to match surrounding surfaces.

3.9 CUTTING AND PATCHING

- A. General: Provide all cutting, drilling, chasing, fitting, and patching necessary for accomplishing the work of Division 26, which includes any and all work necessary to: uncover work to provide for the installation of ill-timed work; remove and replace defective work and work not conforming to the requirements of the Contract Documents; and install equipment and materials in existing structures, in addition to that required during the normal course of construction.
- B. Comply with the cutting and patching requirements of Division 1.
- C. Building Structure: Do not endanger the integrity of the building structure by cutting, drilling, or otherwise modifying any structural member without specific approval. Do not proceed with any structural modifications without written permission of the Project Structural Engineer.
- D. Repairs: Repair any and all damage to work of other trades caused by cutting and patching operations using skilled mechanics of the trades involved.

3.10 UNDERGROUND ELECTRICAL WORK

- A. General: Perform all excavating, trenching, backfilling, etc., as indicated or required for the installation of all underground electrical work. Coordinate work with other trades and verify existing underground services and conditions.
- B. Conduit Burial Depth: 30 inches below finished grade or 6 inches below bottom of frost line, whichever is deeper, unless indicated otherwise. All excavation and burial depths indicated are below finished grade.
- C. Excavating: Do not excavate below required depth except as necessary for removal of unstable soil or when rock is encountered. When rock is encountered, excavate 6 inches below the required depth and backfill with a minimum 6-inch layer of crushed stone or gravel between rock bearing surface and the electrical installation. Stockpile satisfactory excavated materials where directed until

required for backfilling. Remove and legally dispose of excess excavated materials and materials not suitable for backfill use. Shore and brace as required for stability of excavation. Remove shoring and bracing when no longer required. Where sheeting is allowed to remain, cut top of sheeting off at an elevation of 30 inches below finished grade.

- D. Protection: Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards created by excavations.
- E. Existing Utilities: Remove existing electrical and other utility lines so indicated. Where existing utilities, which are to remain, exist within areas of excavation, locate such utilities and support and protect during excavation operations.
- F. Trenching: Cut all trenches neatly and uniformly and so as to provide ample working room and at least six inches clearance on both sides of raceways, etc., unless otherwise noted. Take necessary precautions when working near existing underground utilities, and coordinate with the installation of concurrent utilities by other trades. Unless indicated otherwise, pitch all electrical conduit runs downward away from buildings, manholes, and pad mounted equipment. Excavate trenches to depth indicated or required. Limit length of open trench to that in which installations can be made and trenches backfilled within the same day.
- G. Sand Envelope: Install a minimum envelope of 3 inches (top, bottom, and sides: 3 inches each) of fine grain sand around all electrical cables and conduits installed below grade unless indicated otherwise.
- H. Preparation for Backfilling: Backfill excavations as promptly as work permits but not until completion of inspection, testing, approvals, and recording of underground utility locations. Prior to backfilling, remove all concrete form work, shoring, bracing, trash, and debris.
- I. Backfilling: Use only approved materials free from boulders, sharp objects, and other unsuitable materials. Match the final elevations and materials of areas affected by electrical excavating, trenching, and backfilling. Replace conduit and cables damaged by improper backfilling. Replace surface materials to match existing surface materials if no other utility or site work is being done in area. Place specified soil materials in 4- to 8-inch layers to required subgrade elevations for area classifications as follows:
 - 1. Under Sidewalks: Use combination of subbase materials and excavated or borrowed materials.
 - 2. Under Building Slabs: Use drainage fill materials.
 - 3. Under Piping and Equipment: Use subbase materials where required over rock bearing surfaces and for correction of unauthorized excavation.
 - 4. For Raceways Less than 30 inches below Surface of Paved Areas or Roadways: Provide 4-inch thick concrete base slab support. After raceway installation, provide 4-inch thick concrete encasement (sides and top) prior to backfilling and placement of roadway subbase. Refer to Contract Documents for Conduit Encased in Concrete Details.
- J. Backfill Placement: Place backfill and fill materials in layers of not more than 8 inches in loose depth for material compacted by heavy equipment and not more than 4 inches in loose depth for material compacted by hand-operated tampers. Before compaction, moisten or aerate each layer as necessary to provide optimum moisture content. Compact each layer to required percentage of maximum dry density or relative dry density for each area classification specified below. Do not place backfill or fill material on surfaces that are muddy, frozen, or contain frost or ice. Place backfill and fill materials evenly adjacent to structures, piping, and equipment to required elevations. Prevent displacement of raceways and equipment by carrying material uniformly around them to approximately same elevation in each lift.

- K. Compaction: Control soil compaction during construction, providing minimum percentage of density specified for each area classification indicated below.
- L. Percentage of Maximum Density Requirements: Compact soil to not less than the following percentages of maximum density for soils, which exhibit a well-defined, moisture-density relationship (cohesive soils), determined in accordance with ASTM D1557 and not less than the following percentages of relative density, determined in accordance with ASTM D2049, for soils, which will not exhibit a well-defined moisture-density relationship (cohesionless soils).
 - 1. Areas under Structures, Building Slabs and Steps, Pavements: Compact top 12 inches of subgrade and each layer of backfill or fill material to 90 percent maximum density for cohesive materials and 95 percent relative density for cohesionless materials.
 - 2. Areas Under Walkways: Compact top 6 inches of subgrade and each layer of backfill or fill material to 90 percent maximum density for cohesive materials and 95 percent relative density for cohesionless materials.
 - 3. Other Areas: Compact top 6 inches of subgrade and each layer of backfill or fill material to 85 percent maximum density for cohesive materials and 90 percent relative density for cohesionless materials.
- M. Moisture Control: Where subgrade or layer of soil material must be moisture conditioned before compaction, uniformly apply water. Apply water in minimum quantity necessary to achieve required moisture content and to prevent water appearing on surface during, or subsequent to, compaction operations.
- N. Subsidence: Where subsidence occurs at electrical installation excavations during the period 12 months after Substantial Completion, remove surface treatment (i.e., pavement, lawn, or other finish), add backfill material, compact to specified conditions, and replace surface treatment. Restore appearance, quality, and condition of surface or finish to match adjacent areas.

3.11 RACEWAY SYSTEMS

- A. Raceway Types: Unless indicated otherwise, use raceway types as follows:
 - 1. Indoors, Exposed: Use rigid galvanized steel conduit below 10 feet above finished floor. EMT may be used above 10 feet.
 - 2. Outdoors, Below Grade: (Minimum 1 inch size). Schedule 40 rigid non-metallic conduit. Stub up using rigid galvanized steel elbows.
 - 3. Outdoors, Exposed: Rigid galvanized steel conduit.
 - 4. Flexible Steel Conduit: Use (in dry locations only) for connections to transformers, vibrating equipment, and equipment requiring minor adjustments in positions for final connections to recessed lighting fixtures and between outlet boxes in metal stud partitions.
 - 5. Liquid-Tight Flexible Steel Conduit: Use where flexible steel conduit connections are required in damp, wet, or oily locations, and for final connections to all motors and similar equipment.
- B. Raceway Routing: As required by job conditions unless specific routes or dimensioned positions are indicated on the Drawings. Install tight to slabs, beams, and joists wherever possible. Route exposed conduit, and conduit installed above ceilings, parallel or perpendicular to walls ceilings and structural members. Install to maintain minimum headroom and to present a neat appearance. Run parallel raceways together with bends made from same center line. Verify exact locations of all raceways, pull boxes, and junction boxes. Resolve any conflicts before installation.
- C. Raceway Installation: Cut conduit ends square using saw or pipecutter and ream each cut end smooth. Carefully make all conduit bends and offsets so that the inside diameter of pipe is not

reduced. Make bends so that legs are in the same plane. Make offsets so that legs are in the same plane and parallel. Protect stub-ups from damage, and carefully rebend when necessary.

- D. Fittings: Make up all raceway fittings tight so that final installation of raceway, fittings and enclosures constitutes a firm mechanical assembly and a continuous electrical conductor. Where required, provide bonding jumpers to assure electrical continuity.
- E. Protection: Protect all raceways, enclosures, and equipment during construction to prevent entry of concrete, debris and other foreign matter. Free clogged conduits of all obstructions, or replace, prior to pulling wire. Do not pull wire within buildings until buildings are completely enclosed.
- F. Boxes: Install all outlet, pull, and junction boxes rigidly, plumb, and level. Support and secure boxes independently from conduits terminating at box. Install all boxes so as to be accessible and so that covers may be easily removed.
- G. Handholes: Provide as indicated, installed plumb and level. Where not indicated, install every 200 feet at a minimum.
- H. Conduit Seals: Install conduit seal for each conduit penetrating an exterior building wall below grade (unless penetration is below lowest building floor slab) and elsewhere as indicated, and so as to achieve a sealed watertight installation.
- I. Pull Strings: Provide pull strings in all spare conduits.

3.12 CONDUCTORS - 600 VOLT AND BELOW

- A. Minimum Conductor Size: All branch circuit wiring shall be minimum #12 AWG. All control circuit wiring shall be minimum #14 AWG unless indicated otherwise. Provide larger sizes as indicated or required.
- B. Branch Circuit Conductor Sizes: Provide branch circuit conductor sizes as indicated on the panelboard schedules, plans, or elsewhere. Neutral conductor size to match phase conductors unless indicated otherwise. Provide branch circuit switch legs and travelers as required for the switching indicated.
- C. Equipment Grounding Conductor Required: For each branch circuit and feeder run, provide an equipment grounding conductor for continuous length of run, sized per NEC 250-122 (minimum), larger if so indicated.
- D. Feeders: Provide feeder conductor sizes and quantities as indicated.
- E. In Raceway: Install all wiring in conduit or other specified raceway unless indicated otherwise.
- F. Terminations: Furnish and install terminations including lugs (if necessary) to make all electrical connections indicated or required. Make connections and terminations for all stranded AWG conductors using crimp, clamp, or box-type connectors and terminators. Enclose all strands of stranded conductors in connectors, and lugs.

- G. Color: Conductors #10 and smaller shall be factory color-coded by integral pigmentation with a separate color for each phase and neutral. #8 and larger shall have stripes, bands, hash marks, or color pressure-sensitive plastic tape. Color code all branch circuit and feeder conductors as follows:

1. 208/120 Volts:

PHASE	COLOR
A	Black
B	Red
C	Blue
Neutral	White

2. Equipment Grounding Conductors: Green

- H. Phase Arrangement: Arrange phases in all electrical equipment as follows:

1. A, B, C: Front to Rear.
2. A, B, C: Top to Bottom.
3. A, B, C: Left to Right when facing established front of equipment.

3.13 EQUIPMENT CONNECTIONS

- A. Connect complete, all equipment requiring electrical connections, furnished as part of this Contract or by others unless indicated otherwise.
- B. Equipment Variations: Note that equipment sizes and capacities as shown on the Contract Documents are for bidding purposes and as such may not be the exact unit actually furnished. Contractor shall anticipate minor variations in equipment and shall include in his Bid all costs required to properly connect the equipment actually furnished.
- C. Verification: Obtain and review shop drawings, product data, and manufacturer's instructions for equipment furnished by others. Examine actual equipment to verify proper connection locations and requirements.
- D. Coordination: Sequence electrical rough-in and final connections to coordinate with installation and start-up schedule and work by other trades.
- E. Rough-In: Provide all required conduit, boxes, fittings, wire, connectors, miscellaneous accessories, etc., as necessary to rough in and make final connections to all equipment requiring electrical connections. In general, motors and equipment shall be wired in conduit to a junction box (or safety switch) near the unit, and from there to the unit in flexible metal or liquid-tight flexible steel conduit.
- F. Connections: Provide properly sized overload and short circuit protection for all equipment connected, whether furnished under this Contract or by others. Verify proper connections with manufacturer's published diagrams and comply with same. Verify that equipment is ready for electrical connections, wiring, and energization prior to performing same.

3.14 HANGERS AND SUPPORTS

- A. General: Rigidly support and secure all electrical materials, raceway, and equipment to building structure using hangers, supports, and fasteners, suitable for the use, materials and loads encountered. Provide all necessary hardware.

- B. Wall Mounting: Support wall mounted equipment by masonry, concrete block, metal framing, or sub-framing.
- C. Exterior Walls: Mount all electrical equipment located on the interior of exterior building walls at least 1 inch away from wall surface using suitable spacers.
- D. Independent Support: Do not support electrical materials or equipment from other equipment, piping, ductwork, or supports for same.
- E. Raceway Supports: Rigidly support all raceway with maximum spacings per NEC and so as to prevent distortion of alignment during pulling operation. Use approved hangers, clamps, and straps for individual runs. Do not use perforated straps or tie wires. Where multiple parallel raceways are run together, use trapeze type hanger arrangement made from U-channel and accessories, suspended by threaded rods, and allow at least 25 percent spare capacity for future installation of additional raceways. Rigidly anchor vertical conduits serving floor-mounted or "island" type equipment mounted away from walls with metal bracket or rigid steel conduit extension secured to floor.
- F. Miscellaneous Supports: Provide any additional structural support steel brackets, angles, fasteners, and hardware as required to adequately support all electrical materials and equipment.

3.15 ELECTRICAL IDENTIFICATION

- A. General: Locate nameplate, marking, or other identification means on outside of equipment or box front covers when above ceilings and when in mechanical or electrical equipment rooms or other unfinished areas, and on inside of front cover when in finished rooms/areas. Use Contract Document designations for identification unless indicated otherwise.
- B. Nameplates: Provide nameplate engraved with equipment designation for each safety switch, panelboard, transformer, motor starter, and all other electrical cabinets, etc.
- C. Underground Warning Tape: During trench backfilling for each underground electrical, telephone, signal, and communications line, provide a continuous underground warning tape located directly above line at 6 to 8 inches below finished grade.
- D. Marking Pen Labeling: Mark each junction and pull box indicating source designation and circuit number(s) for the enclosed conductors.
- E. Wire Tags: For power circuits, apply wire tag indicating appropriate circuit or feeder number to each conductor present in distribution panel and panelboard gutters, and to each conductor in pull and junction boxes where more than one feeder or multi-wire branch circuit is present. Where only a single feeder or multi-wire branch circuit is present, box cover labeling and conductor color coding is sufficient. For control, communications, and signal circuits, apply wire tag indicating circuit or termination number at all terminations and at all intermediate locations and boxes where more than one circuit is present.
- F. Panelboard Circuit Directories: At completion of project, accurately complete each panelboard circuit directory card, identifying load served or "spare" or "space" for each circuit pole. When modifying, adding or deleting circuits at an existing panelboard, update the existing (or provide new) circuit directory card to accurately reflect final conditions.

3.16 GROUNDING

- A. General: Provide all system and equipment grounding as indicated and required by the NEC.

- B. Equipment Grounding: Provide a green equipment grounding conductor, sized per NEC 250-122 (larger if so indicated), with each feeder and branch circuit run.
- C. Provide exothermic welded connections where indicated.

3.17 CHECKOUT, TESTING, AND ADJUSTING

- A. General: Provide testing equipment, materials, instruments, and personnel to perform all test procedures and adjustments required by the Contract Documents and/or deemed necessary by the Engineer to establish proper performance and installation of electrical systems and equipment. All test instruments to be accurately calibrated and in good working order.
- B. Scheduling: Schedule tests at least three days in advance, and so as to allow Engineer and Owner representative(s) to witness the test, unless directed otherwise. Do not schedule tests until the system installation is complete and fully operational unless indicated or directed otherwise.
- C. Manufacturer's Authorized Representatives: For all new and modified systems and equipment, arrange and pay for the services of the manufacturer's authorized representative(s) to be present at time of equipment or system start-up, to supervise the start-up, and to conduct and/or certify all required testing and adjusting.
- D. Test Reports: Submit test reports neatly typewritten on 8-1/2-inch-by-11-inch sheets indicating system or equipment being tested, methodology of testing, date, and time of test, witnesses of test, and test results. Submit test reports in three (3) copies to the Engineer for review within five (5) days after test is performed, and include a copy with the appropriate operation and maintenance data.
- E. Correction/Replacement: After testing, correct any deficiencies, and replace materials and equipment shown to be defective or unable to perform at design or rated capacity. Retest without additional cost to the Owner or Contract. Submit finalization report indicating corrective measures taken and satisfactory results of retest.

3.18 SYSTEMS DEMONSTRATION

- A. Instruct the Owner's representative(s) in the start-up, operation, and maintenance of all electrical systems and equipment in accordance with Division 1 and as requested by the Owner's Representative.

3.19 CLEANING AND TOUCH-UP PAINTING

- A. Perform cleaning required by Division 1.
- B. General: Periodically remove from the project site, all waste, rubbish, and construction debris accumulated from construction operations, and maintain order. The premises shall be left clean and free of any debris and unused construction materials prior to final acceptance.
- C. Electrical Equipment: Remove all dust, dirt, debris, mortar, wire scraps, rust, and other foreign materials from the interior and exterior of all electrical equipment and enclosures, and wipe down. Clean accessible current carrying elements and insulators prior to energizing.

- D. Touch-Up Painting: Restore and refinish to original condition, all surfaces of electrical equipment scratched, marred, and/or dented during shipping, handling, or installation. Remove all rust, and prime and paint as recommended by the manufacturer.

END OF SECTION

SECTION 310519.13 – GEOTEXTILES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the installation of separation/stabilization fabric as shown on the Drawings and as specified herein.

1.2 QUALITY ASSURANCE

- A. The latest edition of the following standards, as referenced herein, shall be applicable.
 - 1. American Society for Testing and Materials (ASTM).

1.3 SUBMITTALS

- A. Product Data:
 - 1. Submit Manufacturer's material specifications, product literature and installation instructions.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Delivery:
 - 1. Deliver sufficient materials to the site to prevent interruption of the work.
 - 2. All materials shall be inspected by Contractor upon delivery. Contractor shall notify Engineer of any damage. Products received at the site torn, with holes, deteriorated, or otherwise damaged will not be approved and shall be returned and replaced at no expense to the Owner.
- B. Storage:
 - 1. All material shall be stored in strict accordance with the manufacturer's recommendations and as approved by the Engineer.
 - 2. Do not store products directly on ground. Ship and store geotextile with suitable wrapping for protection against moisture and ultraviolet exposure. Store geotextile in way that protects it from elements, if stored outdoors, elevate, and protect geotextile with waterproof cover.
- C. Handling:
 - 1. All material shall be handled in strict accordance with the manufacturer's recommendations and as approved by the Engineer.

PART 2 – PRODUCTS

2.1 NONWOVEN GEOTEXTILE

- A. Separation/Filtration Fabric: To be used in drainage ditches, haybale installation, culvert outfall installations, rip-rap outfall installations, and cover material separation
- B. Pervious sheet of polyester, polypropylene, or polyethylene fabricated into stable network of fibers that retain their relative position with respect to each other. Nonwoven geotextile shall be composed of continuous or discontinuous (staple) fibers held together through needle-punching, spun-bonding, thermal-bonding, or resin-bonding.

- C. Geotextile Edges; selvaged or otherwise finished to prevent outer material from pulling away from geotextile.
- D. Unseamed Sheet Width: Minimum 12 feet.
- E. Physical Properties: Conform to the requirements noted below:

PROPERTY	DESIGN VALUE	TEST METHOD
Tensile Strength	160 pounds	ASTM D4632
Elongation	50 percent	ASTM D4632
Trapezoidal Tear	60 pounds	ASTM D4533
CBR Puncture Strength	400 pounds	ASTM D6241
A.O.S.	70 (US Sieve)	ASTM D4751
Permittivity	1.4 sec ⁻¹	ASTM D4491

PART 3 – EXECUTION

3.1 GENERAL

- A. The Contractor shall be responsible for the installation, and seaming of geotextile fabric in accordance with the specifications and the manufacturer's recommendations, as approved by the Engineer.

3.2 SUBGRADE PREPARATION

- A. Surfaces to be covered with geotextile fabric shall be smooth and free of rocks, sticks, roots, sharp objects, and all debris that may damage the fabric. The surface to be covered shall be firm and unyielding, with no sudden changes or breaks in grade. There shall be no standing water or excessive moisture on the surface when the fabric is placed.
- B. The compacted subgrade shall be maintained in a smooth, uniform, and compacted condition during installation of the fabric.

3.3 GEOTEXTILE INSTALLATION

- A. The fabric shall be cleaned of all debris or other materials that may negatively affect the fabric's performance.
- B. Mechanical equipment shall not be permitted to operate directly on the fabric unless authorized to do so by the manufacturer and approved by the Engineer.
- C. Geotextile Placement:
 1. Fabric shall be placed as recommended by the manufacturer and approved by the Engineer on surfaces which have been prepared to conform with these Specifications and found acceptable for fabric installation.
 2. The fabric shall be placed as smooth and wrinkle-free as possible.
 3. When installing geotextile in trenches, swales, ditches, etc., overlap geotextile in the direction of flow.
 4. All areas of fabric damaged during installation as determined by the Engineer shall be repaired or replaced by the Contractor as specified at no additional cost to the Owner. Should the fabric be damaged during any step of the installation, the damaged section shall be repaired by

covering it with a piece of fabric which extends at least 24 inches in all directions beyond the damaged area. The fabric shall be secured by sewing or bonding as approved by the Engineer.

5. At time of installation, fabric will be rejected if it has defects, ribs, holes, flaws, deterioration, or damage incurred during manufacture, transportation, handling, or storage. Damaged materials shall be removed and replaced at no additional cost to the Owner.
6. Fabric shall be placed with long dimension down slope.
7. Fabric shall be protected at all times during construction from contamination by surface run-off and any fabric so contaminated shall be removed and replaced with uncontaminated fabric.

D. Seams and Overlaps of Geotextile:

1. All overlaps shall be a minimum of 18 inches (450 mm).

3.4 COVER MATERIALS OVER GEOTEXTILES

- A. Granular materials shall be placed on geotextiles as shown on the Drawings. During backdumping and spreading, a minimum depth of 6 inches of granular material shall be maintained at all times between the fabric and wheels of trucks or spreading equipment. All equipment used in spreading or traveling on the cover layer for any reason shall exert low ground pressures and shall be approved by the manufacturer and Engineer. Dozer blades, etc., shall not make direct contact with the fabric; however, if tears occur in the fabric during the spreading operation, the granular material shall be cleared from the fabric and the damaged area repaired as previously described.
- B. The granular material shall be spread in the direction of fabric overlap. Large fabric wrinkles which may develop during the spreading operations shall be folded and flattened in the direction of the spreading. Occasionally, large folds may reduce the fabric overlap width. Special care shall be given to maintain proper overlap and fabric continuity.
- C. All equipment spreading cover material or traveling on the cover layer shall avoid making sharp turns, quick stops, or quick starts.
- D. Fabric shall be covered as soon as possible after placement to minimize exposure to sunlight. Fabric shall not be exposed for more than 5 days.

3.5 DISPOSAL OF SCRAP MATERIALS

- A. On completion of installation, the Contractor shall legally dispose of all trash and scrap material off-site or in a location approved by the Owner and Engineer, remove equipment used in connection with the work herein, and shall leave the premises in a neat acceptable manner.

END OF SECTION

SECTION 311000 – SITE CLEARING

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Protecting existing trees, shrubs, groundcovers, plants, and grass to remain.
 - 2. Removing existing trees, shrubs, groundcovers, plants, and grass.
 - 3. Clearing and grubbing.
 - 4. Stripping and stockpiling topsoil.
 - 5. Removing above- and below-grade site improvements.
 - 6. Disconnecting, capping or sealing, and abandoning site utilities in place removing site utilities.

1.2 DEFINITIONS

- A. Topsoil: Natural or cultivated surface-soil layer containing organic matter and sand, silt, and clay particles; friable, pervious, and black or a darker shade of brown, gray, or red than underlying subsoil; reasonably free of subsoil, clay lumps, gravel, and other objects more than 2 inches (50 mm) in diameter; and free of subsoil and weeds, roots, toxic materials, or other non-soil materials.
- B. Tree Protection Zone: Area surrounding individual trees or groups of trees to be protected during construction, and defined by the drip line of individual trees or the perimeter drip line of groups of trees, unless otherwise indicated.
- C. Grubbing: Removal of vegetation and other organic matter including stumps, buried logs, and roots.

1.3 MATERIAL OWNERSHIP

- A. Except for excess stripped topsoil or other materials indicated to remain Owner's property, cleared materials shall become Contractor's property and shall be removed from Project site.

1.4 SUBMITTALS

- A. Photographs or videotape, sufficiently detailed, of existing conditions of trees and plantings, adjoining construction, and site improvements that might be misconstrued as damage caused by site clearing.
- B. Record drawings, according to Section "Project Record Documents," identifying and accurately locating capped utilities and other subsurface structural, electrical, and mechanical conditions.
- C. Certification: Submit written certification by qualified arborist that trees indicated to remain have been protected during the course of construction in accordance with recognized standards and that where damage did occur, trees were promptly and properly treated. Indicate which damaged trees (if any) are incapable of retaining full growth potential and are recommended to be replaced.

1.5 QUALITY ASSURANCE

- A. Stake limits of clearing, grubbing, and stripping, prior to commencing of work.
- B. Arborist Qualifications: Engage a qualified arborist who has successfully completed tree protection and trimming, to perform the following work:

1. Remove branches from trees that are to remain, if required.
2. Recommend procedures to compensate for loss of roots and perform initial pruning of branches and stimulation of root growth where removed to accommodate new construction.
3. Recommend procedures for excavation and grading work juxtaposed to established plants.
4. Perform tree repair work for damage incurred by new construction.

1.6 PROJECT CONDITIONS

- A. Traffic: Minimize interference with adjoining roads, streets, walks, and other adjacent occupied or used facilities during site-clearing operations.
 1. Do not close or obstruct streets, walks, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction.
 2. Provide alternate routes around closed or obstructed traffic ways if required by authorities having jurisdiction. Detour routes shall be identified by adequate signs in accordance with the MUTCD.
- B. Protect areas outside limits of disturbance from encroachment by construction personnel or equipment, regardless of property Ownership. Access shall be by specific, written permission or easement only
- C. Improvements on Adjoining Property: Authority for performing site clearing indicated on property adjoining Owner's property will be obtained by Owner before award of Contract.
 1. Do not proceed with work on adjoining property until directed by Owner's Representative.
- D. Salvageable Improvements: Carefully remove items indicated to be salvaged and deliver to storage location defined on the plans or specified here in.
- E. Utility Locator Service: Properly notify utility locator service for area where Project is located before site clearing in accordance with local protocol.
- F. Do not commence site clearing operations until temporary erosion and sedimentation control measures are in place.
- G. Contractor shall verify existing grades prior to performing work under this section. If existing grades are at variance with the drawings, notify the Owner and receive instructions prior to proceeding. No additional compensation will be considered resulting from grade variances once site clearing has commenced.

PART 2 – PRODUCTS (NOT USED)

PART 3 – EXECUTION

3.1 PREPARATION

- A. Protect and maintain benchmarks and survey control points from disturbance during construction.
- B. Locate and clearly flag, fence and protect trees and vegetation to remain or to be relocated.
- C. Remove branches from trees that are to remain, if required to clear new construction and only if specifically approved by Owner's Representative.
 1. Where directed by Engineer, extend pruning operation to restore natural shape of entire tree.

2. Cut branches and roots, if required, with sharp pruning instruments; do not break or chop.
- D. Protect existing site improvements to remain from damage during construction.
 1. Restore damaged improvements to their original condition, as acceptable to Owner.

3.2 TREE PROTECTION

- A. Erect and maintain temporary fencing around tree drip line before starting site clearing. Remove fence when construction is complete.
 1. Do not store construction materials, debris, or excavated material within fenced area.
 2. Do not permit vehicles, equipment, or foot traffic within fenced area.
 3. Maintain fenced area free of weeds and trash.
- B. Do not machine excavate within tree drip line.
- C. Where excavation for new construction is required within tree drip line, hand clear and excavate to minimize damage to root systems. Use narrow-tine spading forks, comb soil to expose roots, and cleanly cut roots as close to excavation as possible.
- D. Do not allow exposed roots to dry out before permanent backfill is placed; provide temporary earth cover or pack with peat moss and wrap with burlap. Water and maintain in moist condition and temporarily support and protect from damage until permanently relocated and covered with earth.
 1. Temporarily support and protect roots from damage until they are permanently redirected and covered with soil.
 2. Coat cut faces of roots more than 1-1/2 inches (38 mm) in diameter with an emulsified asphalt or other approved coating formulated for use on damaged plant tissues.
 3. Backfill with soil as soon as possible.
 4. Where trenching for utilities is required within drip line, tunnel under or around roots by hand digging. Do not cut main lateral roots or tap roots; cut only smaller roots that interfere with installation of new work. Cut roots with sharp pruning instruments; do not break or chop.
- E. Repair or replace trees and vegetation indicated to remain that are damaged by construction operations, in a manner approved by Engineer and acceptable to the Owner.
 1. Employ an arborist, licensed in jurisdiction where Project is located, to submit details of proposed repairs and to repair damage to trees and shrubs.
 2. Replace trees that cannot be repaired and restored to full-growth status, as determined by Engineer and acceptable.

3.3 UTILITIES

- A. Owner will arrange for disconnecting and sealing indicated utilities that serve existing structures before site clearing, when requested by Contractor.
 1. Verify that utilities have been disconnected and capped before proceeding with site clearing.
- B. Locate, identify, disconnect, and seal or cap off utilities indicated to be removed.
 1. Arrange with utility companies to shut off indicated utilities.
 2. Owner will arrange to shut off indicated utilities when requested by Contractor.

- C. Existing Utilities: Do not interrupt utilities serving facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary utility services according to requirements indicated:
 - 1. Notify Engineer and owner not less than two days in advance of proposed utility interruptions.
 - 2. Do not proceed with utility interruptions without Engineer written permission.
- D. Excavate for and remove underground utilities indicated to be removed.

3.4 CLEARING AND GRUBBING

- A. Completely remove obstructions, trees, shrubs, stumps, roots, grass, and other vegetation to permit installation of new construction.
 - 1. Do not remove trees, shrubs, and other vegetation indicated to remain or to be relocated.
 - 2. Cut minor roots and branches of trees indicated to remain in a clean and careful manner where such roots and branches obstruct installation of new construction.
 - 3. Use only hand methods for grubbing within tree protection zone.
 - 4. Chip removed tree branches and [stockpile in areas approved by [Engineer][Construction Manager][Owner's Representative] [dispose of off-site].
- B. Fill depressions caused by clearing and grubbing operations in accordance with Section "Earth Moving" unless further excavation or earthwork is indicated.
 - 1. Place fill material in horizontal layers not exceeding a loose depth of 8 inches (200 mm) and compact each layer to a density equal to adjacent original ground.

3.5 TOPSOIL STRIPPING

- A. Remove sod and grass before stripping topsoil.
- B. Where trees are designated to remain, stop topsoil stripping and adequate distance from the trees to prevent damage to the main root system.
- C. Strip topsoil to whatever depths are encountered in a manner to prevent intermingling with underlying subsoil or other waste materials.
 - 1. Remove subsoil and non-soil materials from topsoil, including trash, debris, weeds, roots, and other waste materials.
- D. Stockpile topsoil materials away from edge of excavations without intermixing with subsoil. Grade and shape stockpiles to drain surface water. Cover to prevent windblown dust.
 - 1. Limit height of topsoil stockpiles to 72 inches (1800 mm).
 - 2. Do not stockpile topsoil within tree protection zones.
 - 3. Dispose of excess topsoil as specified for waste material disposal.

3.6 SITE IMPROVEMENTS

- A. Remove existing above- and below-grade improvements as indicated and as necessary to facilitate new construction.
- B. Remove slabs, paving, curbs, gutters, and aggregate base as indicated.
 - 1. Unless existing full-depth joints coincide with line of demolition, neatly saw-cut length of existing pavement to remain before removing existing pavement. Saw-cut faces vertically.
 - 2. Paint cut ends of steel reinforcement in concrete to remain to prevent corrosion.

3.7 DISPOSAL

- A. Burning of debris onsite is not permitted.
- B. Remove surplus soil material, unsuitable topsoil, obstructions, demolished materials, and waste materials including trash and debris, and legally dispose of them off Owner's property.
 - 1. Separate recyclable materials produced during site clearing from other nonrecyclable materials. Store or stockpile without intermixing with other materials and transport them to recycling facilities.
 - 2. Debris may be buried in designated onsite disposal areas to minimum depth of 3 feet below final grade. Only the following materials are suitable for on-site disposal:
- C. Dispose of all diseased Elmwood within 4 days after cutting by burning or by other methods approved by the Department of Environmental Conservation.

END OF SECTION

SECTION 312000 – EARTH MOVING

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the preparation of the site, protection, excavation, embankment, drainage, dewatering, for site grading, as shown on the Drawings, and as herein specified.
- B. The Contractor shall accept the site in the condition in which it exists at the time of the award of the Contract.
- C. The Engineer shall determine the suitability of materials that are to be used in the work and should any materials encountered be unsatisfactory for the purpose intended, they shall be removed from the site at the Contractor's expense.

1.2 QUALITY ASSURANCE

- A. Reference Standards:
 - 1. The latest edition of the following standards, as referenced herein, shall be applicable.
 - a. Applicable State DOT Standard Specifications.
 - b. "Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO)."
- B. The Contractor shall comply with the requirements for soil erosion and sedimentation control, and other requirements of governmental authorities having jurisdiction, including the State of North Carolina.
- C. The Contractor shall provide and pay for all costs in connection with an approved independent testing facility to determine conformance of soils and aggregate with the specifications in accordance with Section "Quality Requirements."

1.3 SUBMITTALS

- A. Samples:
 - 1. The Contractor shall furnish earth materials to the testing laboratory for analysis and report, as directed by the Engineer, or as outlined in the specifications.
- B. Test Results:
 - 1. The testing laboratory shall submit written reports of all tests, investigations, and recommendations to the Contractor and the Engineer.

1.4 PROJECT REQUIREMENTS

- A. Notify the Engineer of any unexpected subsurface condition.
- B. Protection of Existing Utilities:
 - 1. Locate existing underground utilities in areas of work. If utilities are to remain in place, provide adequate support and protection during earthwork operations, comply with OSHA requirements.
 - 2. Coordinate interruption and/or termination of utilities with the utility companies and the Owner.

3. Provide a minimum of 48 hours' notice to the Owner and receive written notice to proceed before interrupting any utility.
 4. Demolish and completely remove from the site any existing underground utilities designated to be removed as shown on the Drawings or as specified in Section "Site Clearing."
 5. Repair any damaged utilities as acceptable to the Engineer, at no additional cost to the Owner.
- C. Protection of Persons and Property:
1. Barricade open excavations occurring as part of this work, and post with warning lights.
 2. Operate warning lights as recommended by authorities having jurisdiction.
 3. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards created by earthwork operations.
 4. Perform excavation within drip-line of large trees to remain by hand and protect the root system from damage or dryout to the greatest extent possible. Maintain moist conditions for root system and cover exposed roots with burlap. Paint root cuts of 1-inch diameter and larger with emulsified asphalt tree paint.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Select Granular Material: Sound, durable, sand, gravel, stone or blends with these materials, free from organic, frozen, or other deleterious materials, conforming to the requirements of SCDOT and meeting the following gradation requirements:

SIEVE	PERCENT PASSING
2"	100
1/4"	30 - 65
No. 40	5 - 40
No. 200	0 - 10

- B. Structural Fill: Sound, durable, sand, gravel, stone, or blends of these materials, free from organic, frozen or other deleterious materials.
1. Structural fill shall be used for backfilling footing excavations, undercuts, below slabs, and backfilling basement walls. Material suitable for Structural Fill should consist of sound, durable, non-plastic, widely graded sand and gravel, free of stumps, roots, other organics and any frozen or deleterious materials.
 2. Structural Fill shall be placed in loose lifts not exceeding 8.0 inches in thickness in open areas when using a 10-ton roller or in 6 inch lifts in confined areas such as trench excavations when using a narrow trench roller. Structural fill should be compacted to at least 95 percent of the material's maximum dry density as determined by the modified Proctor test (ASTM D 1557). Actual lift thickness shall be based on the type of compaction equipment used during construction.

SIEVE	PERCENT PASSING
4"	100
No. 40	0 - 70
No. 200	0 - 10

1. Fines passing No. 200 shall be non-plastic.
2. Particle size analysis shall show no gap grading.

PART 3 – EXECUTION

3.1 PRECONSTRUCTION MATERIAL QUALIFICATION TESTING

- A. A 100-pound minimum representative sample shall be obtained from each potential borrow source. If different material gradations are known to exist in the pit, samples shall be obtained for each material. Each sample shall be mixed thoroughly and reduced to test specimen size, in accordance with AASHTO T87. The test shall be performed in the order shown. Failure to pass any test is grounds for disqualification and shall lead to cessation of the test program for that material.
 - 1. Particle Size Analysis:
 - a. Method: ASTM D422.
 - b. Number of Tests: One (1) per potential source.
 - c. Acceptance Criteria: Gradation within specified limits.
 - 2. Maximum Density Determination:
 - a. Method: ASTM D1557, Modified Proctor.
 - b. Number of Tests: One (1) per potential source.
 - 3. Re-establish gradation and maximum density of fill material if source is changed during construction.

3.2 PREPARATION

- A. Establish required lines, levels, contours, and datum.
- B. Maintain benchmarks and other elevation control points. Re-establish, if disturbed or destroyed, at no additional cost to the Owner.
- C. Establish location and extent of utilities before commencement of grading operations.

3.3 EXCAVATION

- A. Excavation shall consist, in general, of the excavation of whatever substance is encountered to the lines, grades, and sections shown on the Drawings including excavation as necessary for grading and other similar features.
- B. All suitable materials removed in excavation shall be used in the construction of embankments, subgrade, shoulders, slopes, and at such other places as directed. The Engineer shall be the sole judge of what constitutes suitable material.
- C. During construction, the grading operations shall be executed in such a manner that the excavation will be well drained at all times. All grading shall be finished on neat, regular lines conforming to the sections and contours shown on the Plans.
- D. Removal of materials beyond the indicated subgrade elevations, without authorization by the Engineer, shall be classified as unauthorized excavation and shall be performed at no additional cost to the Owner.
- E. Excavation shall be performed in proper sequence with all other associated operations.
- F. Maintain the slopes of excavation in a safe condition until completion of the grading operation.

- G. All excavation work shall be inspected and approved by the Engineer before proceeding with construction.
- H. Any excess excavation shall be removed from the site to disposal areas at the Contractor's expense.

3.4 FILL

- A. All site fill shall be "selected fill" unless otherwise shown on the Drawings or directed by the Engineer. "Select granular fill" shall be placed in lieu of selected fill where directed by the Engineer.
- B. Before depositing fills, the surface of the ground shall be cleared of all refuse, brush, and large stones. Conform to Section "Site Clearing."
- C. Prior to placing fill over undistributed material, scarify to a minimum depth of 6 inches.
- D. Where fills are made on hillsides or slopes, the slope of the original ground upon which the fill is to be placed shall be plowed or scarified deeply or where the slope ratio of the original ground is steeper than 2 horizontal to 1 vertical, the bank shall be stepped or benched.
- E. The original ground shall be proof rolled until the underlying soil is thoroughly compacted to the satisfaction of the Engineer before any filling is begun. A steel-wheel tandem roller weighing 8 to 10 tons or equipment capable of obtaining the same effort shall be used to obtain a thoroughly compacted subgrade. Remove or recompact any soft or loose soils as determined by the Engineer prior to filling.
- F. A thoroughly and satisfactorily subgrade is defined as having a minimum dry density of 95 percent of the maximum density of the material used. The subgrade material shall be compacted at a moisture content suitable for obtaining the required density.
- G. Place backfill and fill materials in layers not more than 12 inches in loose depth unless shown otherwise on the Drawings. Lift height shall be governed by the ability of the compaction equipment to obtain the required compaction with 12 inches as a maximum lift height. Before compaction, moisten or aerate each layer as necessary to facilitate compaction to the required density. Do not place backfill or fill material on surfaces that are muddy, frozen, or contain frost, ice, ponded water, or extraneous debris.
- H. When work is suspended during periods of freezing weather, measures shall be taken to prevent fill already in place from freezing. Upon resumption of work after any inclement weather, prepare the exposed surface by proof rolling to identify any zones of soft/loose soils. Soft/loose materials or frozen soils shall be removed and replaced by compacted granular fill.
- I. Moisture Control:
 - 1. Where fill or backfill must be moisture conditioned before compaction, uniformly apply water to the surface and to each layer of fill or backfill. Prevent ponding or other free water on surface subsequent to, or during, compaction operations.
 - 2. Remove and replace, or scarify and air dry, soil that is too wet to permit compaction to specified density. Soil that has been removed because it is too wet to permit compaction may be stockpiled or spread and allowed to dry. Assist drying by discing, harrowing, or pulverizing until moisture content is reduced to a value which will permit compaction to the percentage of maximum density specified.

- J. All fill shall be thoroughly and satisfactorily compacted to 95 percent of the maximum density of material used.

3.5 GRADING

- A. The present and finished grade lines are shown on the Drawings. Grade over the entire area, as shown on the drawings, shall be to the finished subgrade levels. Upon completion of this work, all debris shall be cleaned out and removed from the premises.
- B. All cutting, filling, backfilling and grading necessary shall be done to bring the area to the following grade or subgrade levels:
 - 1. For roadway surface areas to the finished subgrade levels specified on the contract drawings.
 - 2. For areas to be topsoiled and seeded to within 6 inches of the finished grade.
 - 3. For other surface treatments as detailed on the Drawings.
- C. Sufficient grading must be done during the progress of the work so that the entire site shall be well drained and free from water pockets.
- D. Finish grading, including dressing swales, cleaning up excess footing excavation, dressing terraces, disposing of excess material and all other work necessary to prepare the site for topsoil and seeding shall be done after construction of structures and roadway surface areas is substantially complete.

3.6 COMPACTION EQUIPMENT

Compaction equipment used for the Work is subject to approval by the Engineer. Any equipment not originally manufactured for compaction purposes and equipment which is not in proper working order will not be approved. Furnish manufacturer's specifications covering data not obvious from a visual inspection of the equipment and necessary to determine its classification and performance characteristics.

3.7 DRAINAGE AND DEWATERING

- A. Prevent surface, subsurface or ground water from flowing into excavation and from flooding project area, as well as surrounding areas.
- B. Do not allow water to accumulate in excavations. Remove water to prevent soil changes detrimental to the stability of subgrades.
- C. Provide and maintain the pumps, well points, sumps, suction and discharge lines, and other dewatering components necessary to convey water away from excavations.
- D. Provide and maintain temporary drainage ditches and other diversions outside excavation limits to convey rain water and water removed from excavations by dewatering, to collection or run-off areas.
- E. Dewatering operations shall be as directed by the Engineer and performed in accordance with Section "Dewatering."

3.8 FIELD QUALITY CONTROL

- A. Notify the Engineer at least one (1) working day in advance of all phases of filling and backfilling operations.

- B. Compaction testing shall be performed to ascertain the compacted density of the fill and backfill materials in accordance with the following methods:
 - 1. In-place relative density:
 - a. Method: AASHTO T310, Nuclear Method.
 - b. Number of Tests: One (1) per 8-inch vertical lift.
 - 1) Paved and Building Slab Areas: At subgrade and at each compacted fill and backfill layer, at least one (1) test for every 2,000 square feet or less of paved area of building slab, but in no case fewer than three (3) tests.
- C. The Engineer may direct additional tests to establish gradation, maximum density, and in-place density as required by working conditions, at the Contractor's expense.
- D. Acceptance Criteria: The sole criterion for acceptability of in-place fill shall be in situ dry density. Minimum dry density for all fill or backfill shall be 95 percent of the maximum dry density. If a test fails to qualify, the fill shall be further compacted and retested. Subsequent test failures shall be followed by removal and replacement of the material.

3.9 CLEAN UP

- A. Provide and maintain protections or newly filled areas against damage. Upon completion or when directed, correct all damaged and deficient work by building up low spots and remove temporary protections, fencing, shoring and bracing.
- B. Remove all surplus excavated material not required for filling and backfilling and legally dispose of same away from premises.
- C. Leave the premises and work in clean, satisfactory condition, ready to receive subsequent operations.

END OF SECTION

SECTION 312319 – DEWATERING

PART 1 – GENERAL

1.1 SUMMARY

- A. This section includes provisions for a dewatering system to continuously lower and control groundwater levels and hydrostatic pressures in order to maintain near-dry conditions for construction of the work as shown on the plans and specified herein.

1.2 SUBMITTALS

- A. Submit the following:
 - 1. Description: of proposed dewatering system.
 - 2. Layout: of dewatering system, including location of sumps, deep wells, well points, header pipes, pumps, discharge lines, and observation wells.
 - 3. Details: of dewatering system, including installation methods for deep wells, well points and observation wells, depths of wells, material descriptions, pipe sizes, intake screen sizes, and pump capacities.
 - 4. Estimate: of time required to lower groundwater levels after start of pumping

1.3 JOB CONDITIONS

- A. Site soil boring data and samples, soil laboratory testing, and any soil reports shall be made available to prospective bidders for study and review. Bidders must make their own interpretation of subsurface conditions that may affect methods or the cost of construction of the Work.

PART 2 – PRODUCTS

2.1 DEWATERING SYSTEM

- A. Provide a dewatering system of adequate size and capacity to lower and maintain the groundwater at the specified level. The system shall include standby pumps and power source for continuous operation.
 - 1. Dewatering system shall consist of wellpoints, deep wells, cut-off walls, riser pipes, swing joints, header lines, valves, pumps, discharge lines, and all other necessary fittings, accessories and equipment for a complete operating system. Provide hole punches, sand backfill, and clay plugs as required by soil conditions.
- B. Observation Wellpoints: Provide groundwater reading wells or piezometers to monitor the groundwater level, as indicated on the approved Shop Drawings or as directed by the Engineer.
- C. Sand: Clean concrete sand conforming to ASTM C33.

PART 3 – EXECUTION

3.1 PREPARATION

- A. Install the observation well points at locations indicated on approved Shop Drawings or where directed by the Engineer. Install observation wellpoints in accordance with manufacturer's printed

instructions and in accordance with approved Shop Drawings. Provide sand backfill around wellpoint. Test each observation wellpoint to verify that the installation is performing properly.

- B. Protect observation well standpipes from damage by construction operations and maintain accessibility to them. Maintain reading wells until groundwater is allowed to return to its normal level.

3.2 INSTALLATION

- A. Install the dewatering system in accordance with approved Shop Drawings and as required by site conditions. Locate elements of the system to allow a continuous dewatering operation without interfering with the installation of any permanent project Work.

3.3 OPERATION

- A. Keep the system in continuous operation from the time excavation is started in the dewatering area (or before if required by site conditions to lower the groundwater to the elevations specified) until the time backfilling is completed at least 2 feet above the normal groundwater level.
 - 1. Do not discontinue dewatering operations without specific approval from the Engineer.
 - 2. Rates of groundwater withdrawal during dewatering operations, shall at all times be below the rate at which soil particles are removed from the existing soils.
- B. In the event excavation proceeds subsequent to dewatering as specified above, and the groundwater level is found to be within two feet of the excavation, the dewatering Contractor shall immediately continue to dewater as specified herein, including, but not limited to, additional dewatering and monitoring facilities, at no additional cost to the Owner. The excavation shall not be allowed to proceed below groundwater.

3.4 FIELD CONTROL

- A. Maintain a careful check to detect any settlement in existing adjacent Work. Notify the Engineer of any signs of settlement. Establish settlement point benchmarks and take periodic readings as directed. The Contractor shall take all such precautions and do any and all Work necessary to protect the stability and integrity of adjacent lands. Pavements, buildings, and utilities from settlement or other movement that may be caused by his dewatering operations. The Contractor shall be solely responsible for any damage or injury to adjacent lands, pavements, buildings, or utilities caused by his dewatering or other operations or his failure to use corrective or preventive procedures or methods.
- B. Take and record measurements of the groundwater in each reading and pumping well periodically and when directed by the Engineer.

3.5 DISCHARGE

- A. Dispose of all water removed from the excavation in such a manner as not to endanger public health, property, or any portion of the Work under construction or completed.
- B. Dispose of water in such a manner as to cause no inconvenience to others on or adjacent to the site.
- C. Convey water from the excavation in a closed conduit. Do not use trench excavations as temporary drainage ditches.

- D. Disposal of water shall be approved by the Engineer and shall not cause erosion or sedimentation to occur in existing drainage systems. All sedimentation or blocking of existing systems shall be thoroughly cleaned and returned to original condition by the Contractor at his own expense.
- E. Provide approved sediment traps when water is conveyed into water courses.

3.6 REMOVAL

- A. When system is no longer required, gradually decrease the pumping rate until the water table resumes its natural position so that the velocity of the returning groundwater will be low enough as not to carry fines with it.
- B. When the dewatering system is no longer required and when directed by the Engineer, dismantle and remove the system and all appurtenances from the site.

END OF SECTION

SECTION 312333 – TRENCHING AND BACKFILLING

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the excavation of trenching, backfilling, compacting, dewatering, excavation support and disposal, as shown on the Contract Drawings, and as herein specified.
- B. The Engineer will determine the suitability of materials that are to be used in the work and should any materials encountered be unsatisfactory for the purpose intended, they shall be removed from the site at the Contractor's expense.

1.2 QUALITY ASSURANCE

- A. Reference Standards:
 - 1. The latest edition of the following standards, as referenced herein, shall be applicable.
 - a. "Standard Specifications for Highway Construction, SCDOT."
 - b. "Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO)."
 - c. American Society for Testing and Materials (ASTM).
 - d. National Electric Code (NEC).
- B. The Contractor shall comply with the requirements for soil erosion and sedimentation control and other requirements of governmental authorities having jurisdiction, including the State.
- C. The Contractor shall provide and pay for all costs in connection with an approved independent testing facility to determine conformance of soils and aggregate with the specifications in accordance with Section "Quality Requirements."

1.3 SUBMITTALS

- A. Samples:
 - 1. The Contractor shall furnish representative earth materials to the testing laboratory for analysis and report, as directed by the Engineer, or as outlined in the specifications.
- B. Test Results:
 - 1. The testing laboratory shall submit written reports of all tests, investigations, findings, and recommendations to the Contractor and the Engineer.

1.4 PROJECT REQUIREMENTS

- A. Notify the Engineer of any unexpected subsurface condition.
- B. Protect excavations by shoring, bracing, sheet piling, or by other methods, as required to ensure the stability of the excavation. Comply with OSHA requirements.
- C. Underpin or otherwise support structures adjacent to the excavation, which may be damaged by the excavation. This includes service lines.

- D. Protection of Existing Utilities:
1. Locate existing underground utilities in areas of work. If utilities are to remain in place, provide adequate means of support and protection during earthwork operations. Comply with OSHA requirements.
 2. Coordinate interruption and/or termination of utilities with the utility companies and the Owner.
 3. Provide a minimum of 48 hours' notice to the Owner and receive written notice to proceed before interrupting any utility.
- E. Demolish and completely remove from the site any existing underground utilities designated to be removed, as shown on the Drawings or as specified.
- F. Repair any damaged utilities as acceptable to the Owner, Engineer, and utility company at no additional cost to the Owner.
- G. Contractor shall comply with maintenance and protection requirements as approved by the authority having jurisdiction.
- H. Protection of Persons and Property:
1. Barricade open excavations occurring as part of this work and post with warning lights, if required.
 2. Operate warning lights as recommended by authorities having jurisdiction.
 3. Protect structures, utilities, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards created by earthwork operations.
 4. Perform excavation within drip-line of trees to remain by hand and protect the root system from damage or dryout to the greatest extent possible. Maintain moist conditions for root system and cover exposed roots with burlap. Paint cut roots of 1-inch diameter and larger with emulsified asphalt tree paint.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Pipe Zone Bedding: Select mixture of graded crushed stone, free from organic, frozen or other deleterious materials, conforming to the requirements of SCDOT and meeting the following gradation requirements:

SIEVE	PERCENT PASSING
1-1/2"	100
1"	90 – 100
1/2"	0 – 15

- B. Pipe Zone Backfill: Sound, durable sand, gravel, stone or blends of these materials, free from organic, frozen or other deleterious materials, conforming to the requirements of SCDOT and meeting the following gradation requirements:

SIEVE	PERCENT PASSING
2"	100
1/4"	30 – 65
No. 40	5 – 40
No. 200	0 – 10

- C. Suitable Material: Sound, durable sand, gravel, stone or blends of these materials, free from organic, frozen or other deleterious materials, conforming to the requirements of SCDOT and meeting the following gradation requirements:

SIEVE	PERCENT PASSING
4"	100
No. 40	0 – 70
No. 200	0 – 15

1. Run-of-trench material, meeting the above criteria, shall be considered suitable material and shall be used for trench backfill only after tested in accordance with Section "Quality Requirements" and approved by the Engineer. The Contractor shall pay for all additional testing required to determine the conformance of run-of-trench material, if at any time during the Work this material appears to be in non-conformance in the opinion of the Engineer.

PART 3 – EXECUTION

3.1 PRECONSTRUCTION MATERIAL QUALIFICATION TESTING

A. General:

1. Sufficient size samples shall be obtained from the potential borrow source to allow completion of tests listed in paragraph B below. Samples may be obtained from test borings, test pits, or from borrow pit faces provided that surficial dry or wet soil is removed to expose undisturbed earth. Tests listed below shall be performed on each sample obtained. A minimum of 3 representative samples from each potential borrow source shall be furnished to the testing laboratory for prequalification testing. Test data shall be provided to the Engineer a minimum of 2 weeks prior to construction for approval of borrow source. Three test reports completed within three months prior to construction may be submitted for commercial earth borrow sources or suppliers of stone products (crushed stone or graded stone products) in lieu of prequalification tests as approved by the Engineer.

B. Material Tests:

1. Particle Size Analysis:
 - a. Method: ASTM D422.
 - b. Number of Tests: One (1) per sample; three (3) per potential source.
 - c. Acceptance Criteria: Gradation within specified limits.
2. Maximum Density Determination:
 - a. Method: ASTM D1557 - Modified Proctor.
 - b. Number of Tests: One (1) per sample; three (3) per potential source.
3. Re-establish gradation and maximum density of fill material if source is changed during construction.

3.2 PREPARATION

- A. Establish required lines, levels, contours, and datum.
- B. Maintain benchmarks and other elevation control points; re-establish if disturbed or destroyed at no additional cost to the Owner.
- C. Establish location and extent of existing utilities prior to commencement of excavation.

3.3 EXCAVATION

- A. All excavation shall be made to such depth as required and of the width shown on the Drawings to provide suitable room for building the structures and laying the pipe(s) they are to contain and for sheeting, shoring, pumping and draining as necessary, and for removing peat, silt, or any other materials which the Engineer may deem unsuitable. Hand trench excavation may be required to protect existing utilities and structures.
- B. Trench excavation for pipes shall be made by open cut to accommodate the pipe or structure at the depths indicated on the Drawings. Excavation shall be made to such a depth and to the width indicated on the Drawings so as to allow a minimum of 8 inches of pipe zone bedding to be placed beneath the bottom of all structures and barrels, bells or couplings of all pipes installed unless otherwise specified on the Drawings.
- C. The bottom of the trench shall be accurately graded to provide a uniform layer of bedding material as required for each section of pipe. Trim and shape trench bottoms and leave free of irregularities, lumps, and projections.
- D. Stockpile excavated subsoil for reuse where directed or approved.
- E. Over excavation/undercut: If, in the opinion of the Engineer, existing material below the trench grade is unsuitable for properly placing bedding material and laying pipe, the Contractor shall excavate and remove the unsuitable material and replace the same with an approved pipe zone bedding material properly compacted.
- F. Stability of Excavation: Slope sides of excavations shall comply with local codes and ordinances having jurisdiction. Shore and brace where sloping is not possible because of space restrictions or stability of material excavated. Maintain sides and slopes of excavation in safe condition until completion of backfilling.
- G. Removal of materials beyond the indicated subgrade elevations, without authorization by the Engineer, shall be classified as unauthorized excavation and shall be performed at no additional cost to the Owner.

3.4 DEWATERING

- A. The Contractor shall remove all water from the excavation promptly and continuously throughout the progress of the work and shall keep the excavation dry at all times until the work is completed and excavation is backfilled or have sufficient weight to resist uplift pressures. Groundwater levels shall be depressed to a minimum of 2 feet below excavation subgrade. No pipe or structure is to be laid in water and water shall not be allowed to rise on or flow over any pipe or structure until such time as approved by the Engineer.
- B. Provide a suitable point of discharge from dewatering operations shall be conveyed in a non-erosive manner satisfactory to the Engineer.
- C. Precautions shall be taken to protect uncompleted work from flooding during storms or from other causes. All pipe lines or structures not stable against uplift during construction or prior to completion shall be thoroughly braced or otherwise protected.

3.5 BEDDING AND BACKFILLING

- A. All pipe trenches backfill (pipe zone bedding, pipe zone backfill and trench backfill) shall be compacted by tamping or rolling to achieve a minimum dry density of 90 percent of the modified

Proctor maximum dry density of the material used (ASTM D1557). Backfill in pipe trenches to be covered with pavement shall be compacted to a minimum of 95 percent of modified Proctor maximum dry density. Backfill materials shall be placed with water content within plus or minus 4 percent of optimum moisture content per the modified Proctor method (ASTM D1557). Any water used for compaction shall be provided by the Contractor at his own expense. The Contractor is responsible for the repair of any trench settlement at no expense to the owner.

- B. Bedding and backfilling shall be accomplished in three stages unless otherwise specified on the Contract Drawings. The first stage shall involve placement of "pipe zone bedding" as a layer(s) of selected material required to support, or to stabilize unsound or unsatisfactory foundation conditions. The second stage shall involve placement of "pipe zone backfill" from the top of the bedding material up to 1 foot above the pipe. The third stage involves the placement of "trench backfill" in the remainder of the trench up to the surface of the ground or the bottom of any special surface treatment subgrade elevation.
- C. The bedding material shall be placed in the trench after the trench has been excavated a minimum of 8 inches below the bell of the pipe to permit the placing of not less than 8 inches of bedding material unless otherwise specified on the Drawings. Where, in the opinion of the Engineer, more than 8 inches of bedding material shall be required, the excavation shall be performed and bedding placed to the depth ordered by the Engineer.
- D. Provide uniform bearing and support for each section of pipe at every point along the entire length except where necessary to excavate for bell holes, pipe joints, or other required connections. Dig bell holes and depressions for joints after trench bottom has been graded. Dig no deeper, longer, or wider than needed to make the joint connection properly.
- E. The bedding material shall be placed to the full width of trench. The bedding material shall be placed in loose lifts not exceeding 6 inches to the elevation shown on the Drawings or directed by the Engineer. The bedding material shall be tamped and compacted to form a firm and even bearing surface.
- F. Pipe zone backfill shall be placed to the elevation shown on the Drawings in loose lifts not-to-exceed 6 inches in thickness, before compaction. The backfill shall be placed on both sides of the pipe at the same time and to approximately the same elevation. Any pipe that is damaged or moved out of alignment, regardless of cause, shall be replaced or realigned at the Contractor's expense. Each layer shall be thoroughly compacted by hand-tamping or mechanical means being careful not to damage the pipe. When the pipe zone backfill reaches 1 foot over the top of the pipe, the entire surface shall be compacted by mechanical means.
- G. The remainder, if any, of the trench above the pipe zone backfill shall be backfilled with suitable material in loose lifts not exceeding 6 inches in thickness before compaction. Each layer shall be thoroughly compacted by mechanical means.

3.6 BACKFILLING AROUND STRUCTURES

- A. The Contractor shall not place backfill against any structure without obtaining the approval of the Engineer. No dumping shall be allowed where materials would flow against or around such structures. Backfill material shall be deposited in horizontal layers not exceeding 6 inches in loose thickness or as shown on the Drawings and thoroughly compacted by hand or by mechanical means to the satisfaction of the Engineer.

3.7 SUSPENSION OF WORK

- A. Whenever the work is suspended, excavations shall be protected and the roadways, if any, left unobstructed. Within or adjacent to private property, material shall be stored at such locations as will not unduly interfere with traffic of any nature and in no case shall materials be stored in locations which will cause damage to existing improvements.

3.8 DISPOSAL OF MATERIAL

- A. Excess and unsuitable materials shall be disposed of by the Contractor on the site in an area approved by the Engineer or legally disposed of off- site at the Contractor's expense.

3.9 FIELD QUALITY CONTROL

- A. Notify the Engineer at least 3 working days in advance of all phases of filling and backfilling operations.
- B. In-place density testing shall be performed to ascertain the compacted density of the fill and backfill materials in accordance with the following methods:
 - 1. In-place relative density:
 - a. Method: AASHTO T310, Nuclear Method.
- C. Perform initial density testing to verify that contractors proposed compaction effort will obtain the minimum required densities.
- D. In-place density tests on trench backfills shall be provided for every 500 cubic yards of fill or in vertical lifts not exceeding 2 feet and at least once daily.
- E. One particle size analysis (ASTM D422) and one modified Proctor compaction test (ASTM D1557) shall be completed for every 5,000 cubic yards of material placed.
- F. The Engineer may direct additional tests to establish gradation, maximum density, and in-place density as required by working conditions, at the Contractor's expense.
- G. Acceptance Criteria: The criteria for acceptability of in-place fill shall be in-situ dry density and moisture content. If a test fails to qualify, the fill shall be further compacted and re-tested. Subsequent test failures shall be followed by removal and replacement of the material.

END OF SECTION

SECTION 320116.71 – COLD MILLING ASPHALT PAVEMENT

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the milling, shaping and removal of portions of existing surfaces by a cold milling process, and subsequent cleaning, utilizing equipment and procedures meeting the requirements in this specification.
- B. Cold-milling shall be performed to the elevations and cross-slopes required to the installation of the new pavement section shown on the Drawings.

1.2 QUALITY ASSURANCE

- A. Reference Standards:
 - 1. The latest edition of the following standards, as referenced herein, shall be applicable.
 - a. "Standard Specifications for Highway Construction, SCDOT."
 - b. "Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO)."

1.3 SUBMITTALS

- A. The Contractor shall survey the post-milled elevations along the proposed edge of pavement, and record the elevations corresponding to proposed elevations shown on the Drawings. This information shall be submitted to the Engineer for verification prior to proceeding with subsequent work.

1.4 PROJECT REQUIREMENTS

- A. Coordinate the milling of existing asphalt concrete pavement with the completion of other items of this Contract.

PART 2 – PRODUCTS

2.1 EQUIPMENT

- A. Milling machines shall be power operated, self-propelled machines capable of removing the desired thickness of existing surfaces. The machines shall have sufficient power, traction and stability to accurately maintain depth of cut and slope. They shall be capable of producing a finished profile and cross slope to within 1/4 inch of that required and shall produce a uniform surface texture free from gouges and ridges greater than 3/8 inch in depth.
- B. The machines shall be equipped with a means to control dust and other particulate matter created by the cutting action.
- C. The machines shall have an integral loading system or sufficient equipment shall be provided to accomplish complete removal of milled material at a rate equivalent to the milling rate.
- D. Vacuum trucks, street sweepers or power brooms shall be used to clean the milled surfaces. The Engineer may disallow the use of power brooms in urban, residential or other sensitive areas if he deems the dust raised by the broom to be objectionable.

PART 3 – EXECUTION

3.1 GENERAL

- A. Milling shall be performed at the locations and in accordance with the details indicated on the plans.
- B. Where indicated on the plans, profile and cross slope shall be controlled by a taut reference string line. The reference elevations shall be established by the Contractor and subject to the approval of the Engineer. The reference elevations shall be based upon proposed bottom of curb elevations, as indicated on the Drawings.
- C. The milled surface shall be sloped to provide the required cross slope, and sufficient to allow the installation of the proposed asphalt concrete pavement overlay. Where the required cross slope cannot be achieved by the milling process due to refusal at the curbline, the pavement slope shall be provided by installation of an asphalt shim course, at no additional cost.
- D. Any potential difficulties in obtaining the specified elevations at the curbline are to be brought immediately to the attention of the Engineer.
- E. All equipment and methods shall conform to SCDOT Standard Specifications, unless otherwise specified.

3.2 REMOVAL OF EXISTING PAVEMENT

- A. All milled material, including that removed by other means, shall be immediately removed from the milled surfaces and adjacent surfaces. Surfaces shall be cleaned of all fines and dust prior to opening to traffic. The Contractor shall conduct his operations in such a manner that dust is controlled and is not objectionable. Milled and adjacent surfaces shall be cleaned again, as directed by the Engineer, prior to the placement of tack coats, or pavement courses if traffic has been allowed on the milled surface and/or if more than 48 hours have elapsed since the initial cleaning.
- B. Milled longitudinal or transverse vertical faces exceeding 1-1/4 inches in height that would be exposed to traffic during non-work hours shall be sloped or tapered in a manner approved by the Engineer so as not to create a traffic hazard. Milling operations shall be conducted to preclude the possibility of pavement runoff collecting along milled joints and creating a traffic hazard.
- C. Areas not accessible to the milling machine, such as around and/or adjacent to inlets, manholes, curbs and transverse joints on structures, may be removed by a small milling machine, handwork or other methods approved by the Engineer.
- D. The Contractor shall maintain drainage at catch basins, according to the details shown on the plans, or in a manner approved by the Engineer.
- E. When working adjacent to traffic, the Contractor shall immediately remove material that is spilled on the traveled way.

3.3 DISPOSAL OF MATERIAL

- A. Material removed during the milling process, including foreign debris within or on the pavement, shall become the property of the Contractor and shall be disposed of at a site obtained by the Contractor.

3.4 CLEANING OF MILLED SURFACES

- A. Sweeping of milled surfaces or other approved methods of cleaning shall be carried out directly behind the milling process. All milled material shall be removed to the satisfaction of the Engineer.
- B. Immediately prior to commencing asphalt paving operations, the milled surfaces shall again be thoroughly cleaned in accordance with these specifications.

3.5 FIELD QUALITY CONTROLS

- A. Damage to milled surfaces resulting from traffic or other causes such as, but not limited to, raveling, fuel spillage or any contaminants which would inhibit bond, shall be repaired or remilled by the Contractor in a manner approved by the Engineer.

END OF SECTION

SECTION 321116 – SUBBASE COURSES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes provisions for prepared subbase courses for under walks and pavements.
- B. Proof rolling of subgrade for walks and pavements is included in this Section.
- C. Replacement of unsuitable subgrade materials is included in another Section.
- D. Final grading of pavement subbase is specified in this Section.

1.2 REFERENCES

- A. SCDOT Standards.
- B. Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO).
- C. American Society for Testing and Materials (ASTM).

1.3 SUBMITTALS

- A. Source Quality Control Test Reports: Submit test reports directly to Engineer from the testing agency with copy to Contractor.
- B. Field Testing Reports: Submit results of field testing directly to Engineer with copy to Contractor. Reference testing location to plan, and cross-reference to all retesting required to accept installed subbase material.
 - 1. Note action taken next to all sub-standard test results.

1.4 QUALITY ASSURANCE

- A. Testing Laboratory Qualifications: To qualify for acceptance, the soil testing laboratory must demonstrate to Engineer's satisfaction, based on evaluation of laboratory-submitted criteria conforming to ASTM E 699, that it has the experience and capability to conduct the required testing without delaying the progress of the Work.
- B. Field Testing and Inspection Service: Contractor shall retain the services of the same independent soil testing laboratory used for source qualification testing to provide soil testing during pavement subbase installation.

PART 2 – PRODUCTS

2.1 SOURCE QUALIFICATION TESTING

- A. Contractor shall employ and pay for a qualified independent soil testing laboratory to perform soil testing services for source qualification.
 - 1. Obtain a 100-pound minimum representative sample from each potential aggregate source. Obtain samples for each different material gradation known to exist in the pit. Mix each

sample thoroughly in accordance with AASHTO T87, and submit to the testing laboratory for reduction to specimen size. The laboratory shall perform the following tests in the order shown. Each material shall pass all tests in order to qualify.

- a. Particle Size Analysis:
 - 1) Method: ASTM D422.
 - 2) Number of Tests: 2 per potential source.
 - 3) Acceptance Criteria: Gradation within specified limits.
 - b. Plasticity Index Determination:
 - 1) Method: ASTM D424.
 - 2) Number of Tests: 1 particle size analysis on material passing no 40 mesh.
 - 3) Acceptance Criteria: Plasticity Index within specified limits.
 - c. Maximum Density Determination:
 - 1) Method: ASTM D1557 Modified Proctor.
 - 2) Number of Tests: 2 per potential source.
 - d. Magnesium Sulfate Soundness Loss Test:
 - 1) Method: State DOT Standard Test Method.
 - 2) Number of Tests: 2 per potential source.
 - 3) Acceptance Criteria: 4 cycle loss within specified limits.
2. Re-establish subbase material properties if source is changed during construction.

2.2 MATERIALS

- A. Processed Gravel Subbase Course: Materials shall consist of sound, durable blast furnace slag, stone, sand, gravel or blends of these materials.
- B. Crushed Rock Subbase Course: Materials shall consist solely of approved blast furnace slag or stone which is the product of crushing ledge rock.
- C. All compacted pavement subbase aggregate materials shall be well graded from course to fine and free from organic or other deleterious materials, conforming to the requirements of SCDOT Standards, and meeting the following gradation requirements:

SIEVE	PERCENT PASSING
1 1/2"	100
3/4"	55-90
No. 4	25-50
No. 50	5-20
No. 200	3-10

- D. All AASHTO #57 materials shall be free from organic or other deleterious materials, conforming to the requirements of SCDOT Standards, and meeting the following gradation requirements:

SIEVE	PERCENT PASSING
1 1/2"	100
1"	95-100
1/2"	25-60
No. 4	0-10
No. 8	0-5

1. Magnesium Sulfate soundness loss after 4 cycles shall be less than 20 percent.
2. Plasticity Index of material passing No. 40 sieve shall not exceed 5.0.
3. Not more than 30 percent, by weight, of the particles retained on a 1/2 inch sieve shall consist of flat or elongated particles. A flat or elongated particle is defined as one which has its greatest dimension more than 3 times its least dimension.
4. All material shall meet the specified gradation prior to placement. All processing shall be completed at the source.

2.3 PREPARATION

- A. Establish required lines, levels, contours, and datum.
- B. Maintain benchmarks and other elevation control points. Re-establish, if disturbed or destroyed, at no additional cost to Owner.
- C. Proof-roll existing subgrade to the satisfaction of the Engineer. Should the subbase course become unstable at any time prior to the placement of the overlying course(s), correct the unstable condition to the satisfaction of the Engineer. Replace unstable or weak subgrade materials with suitable material as provided in the Specifications.
- D. Place stabilization fabric in locations as directed on the plans and in accordance with Section "Geotextiles" after subgrade has been proof-rolled and accepted by the Engineer.

2.4 INSTALLATION

- A. Place subbase material in uniform horizontal layers, with a maximum compacted thickness of 12 inches.
- B. Place subbase in a manner to avoid segregation. Uncontrolled spreading shall not be permitted.

2.5 COMPACTION

- A. Where subbase courses must be moisture-conditioned before compaction, uniformly apply water to the surface. Prevent free water from appearing on the surface during or subsequent to compaction operations.
- B. Compact all portions of each layer to a density not less than 95 percent of the maximum density.
- C. Final tolerances for the top surface of the subbase course requires that the surface does not extend more than 1/4 inch above nor more than 1/4 inch below the specified grade at any location.

2.6 TRAFFIC ON SUBBASE

- A. The movement of vehicular traffic over the final surface of the subbase may be permitted at locations designated by, and under such restrictions as ordered by the Engineer, provided such movements take place prior to the final finishing of this course to the specified tolerance. The movement of construction equipment on this course may be permitted, at locations designated by and under such restrictions as ordered by the Engineer at locations where permission is granted for such movement, the temporary surface of the course upon which the construction traffic is running, shall be placed and maintained for at least 2 inches above the final surface of this course. Just prior to paving, and after all construction traffic not required for the removal has ceased, remove the 2 inch protective layer, prepare the exposed surface of the course, and compact to the specified tolerance.
- B. Should the subbase become mixed with the subgrade or any other material, through any cause whatsoever, remove such mixture and replace it with the specified subbase material.

2.7 FIELD QUALITY CONTROL

- A. Notify the Engineer at least 1 working day in advance of all phases of subbase installation.
- B. Comply with the requirements of this Section for in-place relative density testing.
 - 1. In-place relative density:
 - a. Method: AASHTO T238, Nuclear Method.
 - b. Number of Tests: 1 per specified interval.
 - c. Acceptance Criteria: Plus/minus 2 percent of specified percent compactions.
 - 2. Compaction tests shall be provided for every 1000 square yard of subbase placement. A minimum of 3 for each lift is required.
 - 3. The Engineer may direct additional tests to establish gradation, maximum density, and in-place density as required by working conditions.
 - 4. Acceptance Criteria: The sole criterion for acceptability of in-place subbase shall be in situ dry density. Minimum dry density for all subbase shall be 95 percent of the maximum dry density. If a test fails to qualify, the fill shall be further compacted and re-tested. Subsequent test failures shall be followed by removal and replacement of the material.

END OF SECTION

SECTION 321216.36 – ATHLETIC TRACK ASPHALT PAVING

PART 1 – GENERAL

1.1 SUMMARY

- A. This section includes provisions for hot-mixed asphalt concrete paving over prepared subbase.
- B. This section includes provisions for replacing pavement removed during the course of the Work or damaged resulting from Contractor's operations.

1.2 REFERENCES

- A. Applicable State or Provincial Department of Transportation Standard Specifications.
- B. "Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO)."
- C. "American Society for Testing and Materials (ASTM)."

1.3 SUBMITTALS

- A. Material Certificates signed by material producer and Contractor, certifying that each material item complies with or exceeds specified requirements.
 - 1. Job mix formula shall include the theoretical maximum specific gravity (Gmm) in order for the third-party testing agency to accurately calculate the in-place compaction as a % of maximum.
- B. Field Test Reports: Submit results of field testing directly to the Engineer.
- C. Track & Field Paving Experience:
 - 1. On-site Project Manager/Superintendent Qualifications:
 - a. The track and field contractor shall be a current certified track builder as part of the American Sports Builders Association (ASBA).
 - b. Provide a list of completed facilities, minimum of 5 running tracks, in the past 5 years.
 - c. The project manager/superintendent will be on-site during all track & field paving operations. Substitution of project manager/superintendent shall not be permitted.
 - 2. Track Paving Contractor Qualifications:
 - a. Track Paving Contractor shall provide a list of completed facilities, minimum of 5 running tracks, in the past 5 years.
- D. Asphalt truck delivery tickets: Contractor to collect and submit all tickets within 48 hours of delivery.

1.4 SITE CONDITIONS

- A. Weather Limitations: Apply tack coats when ambient temperature is above 50 DegF (10 DegC) and when temperature has not been below 35 DegF (1 DegC) for 12 hours immediately prior to application. Do not apply when base is wet or contains an excess of moisture.
- B. Construct hot-mixed asphalt concrete surface course when atmospheric temperature is above 40 DegF (4 DegC) and when base is dry. Base course may be placed when air temperature is above 30 DegF (minus 1 DegC) and rising.

- C. Grade Control: Establish and maintain required lines and elevations.
- D. In no instance shall the materials and thicknesses of pavement and subbase courses replaced be less than that removed, unless approved by the Engineer.

1.5 SEQUENCING AND SCHEDULING

- A. Coordinate the placement of asphalt concrete pavement with the completion of underground work by other trades.
- B. The asphalt top course shall be allowed to cure for 28 days prior to application of resilient track surfacing.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. General: All hot mix asphalt shall be in accordance with applicable provisions of State or Provincial Department of Transportation Specifications, except as herein modified.
 - 1. No RAP (Reclaimed Asphalt Pavement) content will be permitted in the asphalt wearing/surface course.
 - 2. The RAP (Reclaimed Asphalt Pavement) content in the asphalt binder course shall be 20 percent or less.
- B. Asphalt Binder Course:
 - 1. SCDOT Intermediate Course Type B, PG64-22
- C. Asphalt Wearing/Surface Course:
 - 1. SCDOT Surface Course Type B, PG64-22
- D. Asphalt Tack Coat:
 - 1. The primer for application on asphalt surfaces (tack coat) shall be CRS-1.
 - a. Tack coat material shall be in accordance with State or Provincial Department of Transportation Specifications.

PART 3 – EXECUTION

3.1 SURFACE PREPARATION

- A. General: Remove loose material from compacted subbase surface immediately before commencing paving operations.
- B. Proof-roll prepared subbase surface with a ten-ton static, steel-wheel roller to check for unstable areas and areas requiring additional compaction, witnessed by the Engineer at least 48 hours prior to scheduled paving operations.
- C. Do not begin paving work until deficient subbase areas have been corrected and are ready to receive paving.

- D. Sawcut edges of existing pavement to achieve straight line transitions between old and new pavement. Make a second sawcut through the top course of existing pavement 18 inches from the first cut to provide a staggered joint.
- E. Tack Coat: Apply to contact surfaces of previously constructed asphalt or Portland cement concrete and surfaces abutting or projecting into asphalt concrete pavement. Distribute at rate of 0.03 to 0.07 gallons per square yard of surface.
- F. Allow to dry until at proper condition to receive paving.
- G. Exercise care in applying bituminous materials to avoid smearing of adjoining surfaces. Remove and clean damaged surfaces.
- H. Do not commence pavement replacement operations until all buried work beneath pavement repair has been completed to the satisfaction of the Engineer.
- I. Where trench dimensions preclude the use of proof rolling equipment, demonstrate the stability of the subgrade and subbase through other means, as acceptable to the Engineer.

3.2 PLACING AND COMPACTING MIX

- A. General: Place and compact asphalt pavement courses in accordance with applicable state or provincial department of transportation specifications unless otherwise specified. This, however, shall not relieve the Contractor of his responsibility to provide a well densified pavement. It shall be the Contractor's obligation to recognize difficulties in compacting the mix, and to make appropriate corrections.
- B. Compaction: Compact asphalt pavement courses with a static steel wheel roller only, unless otherwise approved by the Engineer, based upon work conditions.
- C. Place inaccessible and small areas by hand and compact with hot hand tampers or vibrating plate compactors.
- D. Chamfer edges of walks at 45-degree angle where walks do not abut curb.
- E. Joints: Make joints between old and new pavements, or between successive days' work, to ensure continuous bond between adjoining work. Construct joints to have same texture, density, and smoothness as other sections of asphalt concrete course. Clean contact surfaces and apply tack coat.
- F. Place tack coat between successive courses if more than 48 hours have elapsed after placing the preceding course. Apply tack coat at a rate of 0.03 to 0.07 gallons per square yard of surface.
- G. Remove and patch areas of any asphalt concrete course deemed unsatisfactory by the Engineer at the Contractor's expense. Remove hardened or set asphalt by saw cutting.
- H. Roll and compact the asphalt concrete course until the finished surface is free from depressions, waves or other defects that would prevent proper drainage. The finished surface shall be uniform in texture and appearance.
- I. Protection: After final rolling, do not permit vehicular traffic on pavement until it has cooled and hardened.
- J. Erect barricades to protect paving from traffic until mixture has cooled enough not to become marked.

3.3 FIELD QUALITY CONTROL

- A. General: Testing in-place asphalt concrete courses for compliance with requirements for thickness, surface smoothness and compaction will be done by Third Party (paid for by Contractor) testing laboratory. Repair or remove and replace unacceptable paving as directed by Engineer.
- B. Thickness: Testing agency to measure loose asphalt thickness during paving operations and compacted asphalt thickness after rolling. Above thickness measurements or in-place compacted thickness tested in accordance with ASTM D3549 will not be acceptable if exceeding following allowable variations:
 - 1. Binder and Surface Course: Plus or minus 1/4 inch.
 - 2. Cumulative Thickness Tolerances: Plus or minus 1/4 inch for nominal cumulative thicknesses less than or equal to 4 inches. Plus or minus 1/2 inch for nominal cumulative thicknesses greater than 4 inches.
- C. Surface Smoothness: Test finished surface of each asphalt concrete course for smoothness, using 10-foot straightedge applied parallel with and at right angles to centerline of paved area. Surfaces will not be acceptable if exceeding the following tolerances for smoothness:
 - 1. Binder Course Surfaces: 1/4 inch.
 - 2. Wearing Course Surface: 3/16 inch.
 - 3. Crowned Surfaces: Test with crowned template centered and at right angle to crown. Maximum allowable variance from template is 1/4 inch.
- D. Compaction:
 - 1. The average sub-lot (daily or 400 tons, whichever is less) in-place density measurement for asphalt surface course mixture shall be at least 94% of the theoretical maximum density at optimum with no single value less than 92%. Acceptable average measurements shall be made by use of a correlated nuclear density gauge per ASTM D2950. Additional testing shall be performed on any given day once 400 tons of asphalt is placed on that day.
 - 2. In-place density tests shall be in accordance with state standards for frequency and methods where the work being performed is done with a minimum of testing meeting the above compaction requirements.
- E. Check surface areas at intervals as directed by Engineer.
- F. Scuff Resistance: If, in the opinion of the Engineer, the pavement does not demonstrate reasonable resistance to deformation by punching loads and scuffing under horizontally applied shearing loads, after the pavement has cooled and hardened, the Engineer may require laboratory testing of cored pavement samples to determine the properties of the pavement; including aggregate gradation, asphalt content, air void ratio, density and any others deemed appropriate. If laboratory testing indicates that any parameters substantially deviate from the design mix tolerances specified by applicable state or provincial department of transportation, replace the affected areas of pavement at no additional cost, and reimburse the Owner for all costs incurred in procurement and testing of cores.

3.4 TRACK & FIELD REQUIREMENTS

- A. Flood Testing:
 - 1. The completed asphalt surface that will receive track & field synthetic surfacing must be flood tested in the presence of the track & field synthetic surfacing contractor to determine if any depressions require remediation prior to the installation of the track & field synthetic surfacing.

- B. Track & Field Slope Requirements (NFSHSA (High School)):
1. Track Oval: Direction of running, maximum slope 1:1000 (0.1%); Cross/lateral slope (perpendicular to lane lines), outermost lane down to Lane 1, 2:100 (2.0%) maximum.
 2. High Jump: Maximum slope of the approach and take-off area shall not exceed 1:100 (1.0%) downward toward the center of the crossbar.
 3. Long/Triple Jump, Javelin, and Pole Vault Runways:
 - a. Direction of running/jumping, maximum slope 1:1000 (0.1%).
 - b. Cross / lateral slope (perpendicular to runway lines), 2:100 (2.0%) maximum.

END OF SECTION

SECTION 321630 – CONCRETE SIDEWALKS

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the installation of concrete sidewalk as shown on the Drawings, or as specified herein.
- B. The materials and methods specified herein are directly intended for placement of “new” concrete sidewalk. Where existing sidewalk is removed and replaced during construction, modifications to these specifications to match existing conditions shall be made as directed by the Engineer.

1.2 QUALITY ASSURANCE

- A. Reference Standards:
 - 1. The latest edition of the following standards, as referenced herein, shall be applicable.
 - a. SCDOT Standards.
 - b. American Society of Testing and Materials (ASTM).
 - c. American Concrete Institute (ACI).
- B. The Contractor shall provide and pay for all costs in connection with an approved independent testing facility to determine conformance of materials with the specifications, if at any time during the Work, materials appear unsuitable in the opinion of the Engineer.

1.3 SUBMITTALS

- A. Concrete:
 - 1. The Contractor shall furnish the name and location of the concrete supplier.
 - 2. Submit the design mix for each class of concrete prior to use in the Work.
- B. Product Data:
 - 1. Submit manufacturer’s catalog cuts, specifications, and installation instructions.
- C. Test Results:
 - 1. The testing laboratory shall submit written reports of all tests, investigations, and recommendations to the Contractor and the Engineer.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Concrete:
 - 1. All cast-in-place concrete shall be ready mixed concrete meeting the following criteria:
 - a. 28-day compressive strength-4000 psi
 - b. Air entrainment-4% to 8%
 - c. Slump-2" to 4"

- B. Premoulded Expansion Joint Filler:
 - 1. Concrete curbing shall be provided with a 1/2 inch premoulded expansion joint filler conforming to ASTM D1751.
 - 2. The premoulded expansion joint filler shall be “pre-cut” to match the concrete sidewalk cross-sectioned dimensions as detailed on the Drawings.
- C. Fabric Reinforcement:
 - 1. Flat sheets of 6 x 6 - W 2.9 x W 2.9, ASTM A1064, welded wire reinforcement.
- D. Sealants:
 - 1. Joint Sealers: ASTM C920.
- E. Forms:
 - 1. Sidewalk forms shall be of wood or steel, straight of sufficient strength to resist springing during depositing and consolidating concrete, and of a height equal to the full depth of the finished sidewalk.
 - 2. Wood forms shall be surfaced plank, 2-inch nominal thickness, straight and free from warp, twist, loose knots, splits or other defects. Wood forms shall have a nominal length of 10 feet, with a minimum of three stakes per form, at maximum spacing of 4 feet. Corners, deep sections, and radius bends shall have additional stakes and braces, as required. Radius bends may be formed with 3/4-inch boards, laminated to the required thickness.
 - 3. Steel forms shall be channel-formed sections with a flat top surface and with welded braces at each end and at not less than two intermediate points. Form ends shall be interlocked and self-aligning. Forms shall include flexible forms for radius forming, corner forms, form spreaders, and fillers. Forms shall have a nominal length of 10 feet, with a minimum of two welded stake pockets per form. Stake pins shall be solid steel rods with chamfered heads and pointed tips, designed for use with steel forms.

PART 3 – EXECUTION

3.1 INSPECTION

- A. The Contractor shall notify the Engineer 24 hours before placing concrete in order to give the Engineer an opportunity to inspect the formwork, reinforcing and related items prior to placement of the concrete.
- B. Delivery tickets shall show the amount of cement, brand, and amount of all admixtures, in addition to information required by ASTM C94, Section 14. Water added on the job shall be approved and the amount noted on the delivery ticket and initialed by the Contractor.

3.2 SUBBASE PREPARATION

- A. Concrete sidewalk shall be constructed on a compacted granular subbase as shown on the Drawings.
- B. The completed subbase shall be tested for grade and cross section with a template extending the full width of the sidewalk and supported between side forms.
- C. The subbase shall be maintained in a smooth, compacted condition in conformity with the required section and established grade, until the concrete is placed.
- D. The subbase shall be in a moist condition when concrete is placed.

- E. The subbase shall be prepared and protected so as to produce a subbase free from frost when the concrete is deposited.

3.3 FORMWORK

- A. Earth cuts may not be used as forms for vertical surfaces.
- B. All forms shall be built mortar tight and of materials sufficient in strength to hold concrete without bulging between supports. Forms shall be maintained to eliminate the formation of joints due to shrinkage of the forms. Concrete, misshapen by bulges or deformations caused by inadequate forms, shall be removed or corrected as ordered by the Engineer. All replacements or corrections shall be made at the Contractor's expense.
- C. All surfaces of wooden forms that will be in contact with exposed concrete shall be thoroughly treated with an approved lacquer in the procedure recommended by the manufacturer. Forms so treated shall be protected from being damaged or dirtied prior to placing of the concrete.
- D. Metal forms shall be treated with an approved form lacquer or may be treated with an approved form oil. The metal used for forms shall be of sufficient thickness to remain true to shape. All bolt and rivet heads shall be designed to hold the forms rigidly together and to allow removal, without injury to the concrete. Metal forms which do not have smooth surfaces, correct alignment and clean surfaces shall not be used.
- E. Side forms shall not be removed for less than 12 hours after finishing has been completed.

3.4 CONCRETE PLACEMENT AND FINISHING

- A. Preparation:
 - 1. Set forms true to line and grade and anchor rigidly in position.
 - 2. Transverse expansion joints shall be installed at sidewalk returns and opposite expansion joints in adjoining curbs. Longitudinal expansion joints shall be installed between concrete sidewalk and abutting concrete curb, continuously. Transverse expansion joints shall be installed equally at not more than 25 feet on center, unless otherwise directed by the Engineer, or as detailed on the Drawings.
 - 3. Transverse expansion joints shall be filled with 1/2-inch joint filler strips. Joint filler shall be placed with top edge 1/4 inch below the surface and shall be held in place with steel pins or other devices to prevent warping of the filler during floating and finishing. Protect the top edge of the joint filler during concrete placement with a temporary cap and remove after concrete has been placed.
 - 4. Expansion joints shall be formed about structures and features that project through or into the sidewalk pavement, using joint filler of the type, thickness, and width indicated. The filler shall be installed in such manner as to form a complete, uniform separation between the structure and sidewalk pavement.
- B. Placement of Fabric Reinforcement:
 - 1. Prior to placement, clean reinforcement thoroughly of mill and rust scale and of coatings which could destroy or reduce bond. Where there is a delay in depositing concrete after the positioning of reinforcement, reclean reinforcement, if necessary.
 - 2. Place reinforcement midway between top and bottom of the slab and secure against displacement.

3. Lap edges and ends of adjoining sheets of fabric reinforcement at least half the mesh width. Offset end laps in adjacent sheets to prevent continuous joints at ends. Interrupt reinforcement at expansion joints, stopping 2 inches from edges.
- C. Concrete Placement:
1. Concrete shall be placed in the forms in one layer of such thickness that when compacted and finished the sidewalk will be of the thickness indicated. After concrete has been placed in the forms, a strike-off guided by side forms shall be used to bring the surface to proper section to be compacted.
 2. The concrete shall be tamped and consolidated with a suitable wood or metal tamping bar, and the surface shall be finished to grade with a wood float. Finished surface of the walk shall not vary more than 3/16 inch from the testing edge of a 20-foot straightedge. Irregularities exceeding the above shall be satisfactorily corrected. The surface shall be divided into rectangular areas by means of contraction joints spaced at intervals shown on the drawings.
 3. Place concrete in accordance with ACI 301 unless otherwise specified herein.
 4. Cold Weather Concreting: Comply with ACI 306 for placement at temperatures of, or expected to be, below 40°F.
 5. Hot Weather Concreting: Comply with ACI 305 for placement at temperature of, or expected to be, above 90°F.
- D. Concrete Finishing:
1. After straight edging, when most of the water sheen has disappeared, and just before the concrete hardens, the surface shall be finished to a smooth and uniformly fine granular or sandy texture free of waves, irregularities, or tool marks. A scored surface shall be produced by brooming with a fiber-bristle brush in a direction transverse to that of the traffic, or as otherwise shown on the drawings.
 2. All slab edges, including those at formed joints, shall be finished carefully with an edger having a radius of 1/8 inch. Corner and edges which have crumbled and areas which lack sufficient mortar for proper finishing shall be cleaned and filled solidly with a properly proportioned mortar mixture and then finished.
 3. The completed surface shall be uniform in color and free of surface blemishes and tool marks.

3.5 CURING

- A. General: Protect freshly placed concrete from premature drying and excessive cold or hot temperatures.
- B. Comply with ACI 306.1 for cold-weather protection.
- C. Evaporation Retarder: Apply evaporation retarder to concrete surfaces if hot, dry, or windy conditions cause moisture loss approaching 0.2 lb/sq. ft. x h (1 kg/sq. m x h) before and during finishing operations. Apply according to manufacturer's written instructions after placing, screeding, and bull floating or darbying concrete but before float finishing.
- D. Begin curing after finishing concrete but not before free water has disappeared from concrete surface.
- E. Curing Methods: Cure concrete by moisture curing as follows:
1. Moisture Curing: Keep surfaces continuously moist for not less than seven days with the following materials:
 - a. Water.
 - b. Continuous water-fog spray.

- c. Absorptive cover, water saturated and kept continuously wet. Cover concrete surfaces and edges with 12-inch (300-mm) lap over adjacent absorptive covers.

3.6 SEALING JOINTS

- A. At the end of the curing period, expansion joints shall be carefully cleaned and filled with joint sealer. Concrete at the joint shall be surface dry, and the atmospheric and pavement temperatures shall be above 50°F, at the time of application of joint sealing materials.
- B. Joints shall be filled flush with the concrete surface in such manner as to minimize spilling on the walk surface. Spilled sealing material shall be removed immediately and the surface of the walk cleaned. Dummy groove joints shall not be sealed.

3.7 BACKFILLING AND RESTORATION

- A. After curing, debris shall be removed, and the area adjoining the concrete shall be backfilled, graded, and compacted to conform to the surrounding area in accordance with lines and grades indicated.
- B. All lawns, pavements, driveways, shrubs, or other improvements affected by sidewalk placement shall be restored to their original condition.

3.8 PROTECTION

- A. The Contractor shall protect the sidewalk and keep it in “first class” condition until the completion of the Contract. Any sidewalk which is damaged prior to final acceptance of the Work shall be removed and replaced at the Contractor’s expense.

3.9 FIELD QUALITY CONTROL

- A. Testing and Inspecting: The Owner will provide an inspecting agency to perform tests and inspections and to submit reports.
- B. Concrete Tests: Testing of composite samples of fresh concrete obtained according to ASTM C 172 shall be performed according to the following requirements:
 - 1. Testing Frequency: Obtain one composite sample for each day's pour of each concrete mixture exceeding 5 cu. yd., but less than 25 cu. yd., plus one set for each additional 50 cu. yd. or fraction thereof.
 - 2. Testing Frequency: Obtain at least one composite sample for each 100 cu. yd. or fraction thereof of each concrete mixture placed each day.
 - a. When frequency of testing will provide fewer than five compressive-strength tests for each concrete mixture, testing shall be conducted from at least five randomly selected batches or from each batch if fewer than five are used.
 - 3. Slump: ASTM C 143/C 143M; one test at point of placement for each composite sample, but not less than one test for each day's pour of each concrete mixture. Perform additional tests when concrete consistency appears to change.
 - 4. Air Content: ASTM C 231, pressure method, for normal-weight concrete; one test for each composite sample, but not less than one test for each day's pour of each concrete mixture.
 - 5. Concrete Temperature: ASTM C 1064/C 1064M; one test hourly when air temperature is 40 DegF and below and when 80 DegF and above, and one test for each composite sample.
 - 6. Compression Test Specimens: ASTM C 311/C 311M.
 - a. Cast and laboratory cure three sets of two standard cylinder specimens for each composite sample.

7. Compressive-Strength Tests: ASTM C39/C39M; test one set of two laboratory-cured specimens at 7 days and one set of two specimens at 28 days. The remaining two cylinders will be held in reserve. If the results of the 28-day tests indicate low strength concrete, the engineer will direct the contractor and laboratory to test the remaining two cylinders at a time directed by the Engineer.
8. Strength of each concrete mixture will be satisfactory if every average of any three consecutive compressive-strength tests equals or exceeds specified compressive strength and no compressive-strength test value falls below specified compressive strength by more than 500 psi.
9. Test results shall be reported in writing to Engineer, concrete manufacturer, and Owner within 48 hours of testing. Reports of compressive-strength tests shall contain Project identification name and number, date of concrete placement, name of concrete testing and inspecting agency, location of concrete batch in Work, design compressive strength at 28 days, concrete mixture proportions and materials, compressive breaking strength, and type of break for both 7- and 28-day tests.

END OF SECTION

SECTION 321815 – ATHLETIC CHANNEL DRAIN SYSTEM

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes install a precast, interlocking channel drainage system as specified and as shown on the working drawings.
- B. System Description: Modular trench drain system precast from a corrosion resistant polymer including interlocking modular components for on-site installation.

1.2 QUALITY ASSURANCE

- A. Warranty:
 - 1. Channel drain system is included under the Project Warranty.

1.3 SUBMITTALS

- A. Contractor will submit shop drawings showing a plan of the total drainage system listing all parts being provided with exact center-line dimensions suitable for installation. Copies of the manufacturer's recommended method of installation, assembly, and anchorage shall be submitted for review.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Physical and Mechanical Characteristics of Channel Units
 - 1. Top unit width - Approximately 6.1 inches.
 - 2. Internal width - Approximately 4.0 inches.
 - 3. Unit depth - Approximately 9.6 inches.
- B. Channel Profile shall include positive interlocking tongue and groove connections which can be sealed to provide watertight connections. Each precast polymer channel shall be an approximately 1-meter unit and be available in curved and straight sections.
- C. Catch Basins shall be precast polymer concrete, 39.37" in length and include a plastic grating.
- D. Channel Drainage System:
 - 1. Turf to track and turf to curb applications.
 - a. Sportsedge PRO-S Trench Drain.
 - b. ACO Sport System 4020.
 - 2. Track to track applications.
 - a. Sportsedge XT-6 Slot Drain.
 - b. ACO Sport System 2000.

- E. Grates:
 - 1. Grates are to be black plastic with an anti-slip finish.
 - 2. Grate locking devices are to be galvanized steel.

PART 3 – EXECUTION

3.1 SITE PREPARATION

- A. Excavate the area for channel placement wide enough to accommodate the channel size with a minimum of four-inch concrete encasement. Channels require a minimum of six inches concrete support, and top of channel must be evenly aligned to the surface of the surrounding surface on both sides, as well as underneath the channel.

3.2 INSTALLATION

- A. Install precast channel drain in accordance with the details on the plans and the manufacturer's instructions.
- B. Channel sections are installed from the outlet ends of the system, working from the catch basins. Insert channels from above to allow ends to interlock. Channel sections shall be placed on brick, rebar basket, channel chair, low slump concrete grout slurry, or suspended to obtain correct finished elevation. Cutting will be made, if required, by masonry or concrete saw. Cover top of channel with tape, plastic, or plywood strips to protect the channel surface from concrete during pouring.
- C. Finishing and Cleanup
 - 1. Following final set of concrete, remove protection covering top of channels.
 - 2. Install drain system in strict accordance with manufacturer's recommendations and shop drawings.

END OF SECTION

SECTION 321823.38 – SYNTHETIC RUNNING TRACK SURVEYING

PART 1 – GENERAL

1.1 SUMMARY

- A. This section covers all labor and materials required to provide survey of key construction elements and the final track and field facility. The Contractor is responsible for completing all survey work.

1.2 CODES AND STANDARDS

- A. The survey work must be completed by a licensed surveyor or engineer.
- B. Codes and standards follow the current guidelines set forth by the National Federation of State High School Associations (NFSHSA).

1.3 SUBMITTALS

- A. The following information must be submitted by the Contractor:
 - 1. After installation of new precast channel drain:
 - a. Survey the new precast channel drain location with elevations at:
 - 1) 10-meter intervals starting at the common finish line.
 - 2. New outside and infield border curbs:
 - a. Survey the outside border curbs location with elevations at:
 - 1) 10-meter intervals starting at the common finish line.
 - 2) All sprint chute corners.
 - 3) Elevations to show top of curb and top of notch if necessary.
 - b. Survey the infield border curbs location with elevations at:
 - 1) 10-meter intervals.
 - 2) Elevations to show top of curb and top of notch.
 - 3. After installation of all field events:
 - a. Survey all field events with elevations as follows:
 - 1) 4 corners of all long/triple jump sand pits.
 - 2) Center of all long/triple jump take-off boards.
 - 3) Top flange of all pole vault boxes (center front and center back).
 - 4) 4 corners of all throw circle pads.
 - 4. After installation of the asphalt/concrete base:
 - a. Survey track oval and field event areas as follows:
 - 1) Both edges of all runways at 10-foot intervals.
 - 2) High jump area on a 20-foot grid.
 - 3) All paved D-zone surfaces on a 20-foot grid.
 - 4) Oval lanes 1, 4 and 8 at 10-meter intervals starting at the common finish line.

PART 2 – PRODUCTS (NOT USED)

PART 3 – EXECUTION (NOT USED)

END OF SECTION

SECTION 321823.39 – SYNTHETIC RUNNING TRACK SURFACING

PART 1 – GENERAL

1.1 SUMMARY

- A. This section covers all labor and materials required to install a first-class track & field surface. The Track & Field Synthetic Surfacing Contractor is responsible for installing all track & field synthetic surfacing materials and line markings as designated in these specifications.

1.2 CODES AND STANDARDS

- A. Codes and standards follow the current guidelines set forth by the National Federation of State High School Associations (NFSHSA).

1.3 SUBMITTALS

- A. The following information must be submitted by the Track & Field Synthetic Surfacing Contractor prior to installation.
 - 1. Test results, from an IAAF certified laboratory, verifying manufacturer's Track & Field Synthetic Surfacing product meets the IAAF Performance Specifications for Synthetic Surfaces.
 - a. The same components from the test sample must be used in the installed surface. No substitutions will be allowed.
 - b. TRRL Pendulum test results for slip resistance must be greater than 47.
 - 2. Surfacing Contractor On-site Project Manager/Superintendent Qualifications:
 - a. The project manager/superintendent for the surfacing contractor will be on-site during all surfacing operations. Substitution of project manager/superintendent shall not be permitted.
 - b. A list of completed facilities, minimum of 5, which are certified to meet NFSHSA rules & regulations in the past 5 years utilizing the product specified in these specifications. The Track & Field Synthetic Surfacing Contractor's project manager/supervisor responsible for the completed facilities must supervise this project.
 - 3. Standard printed specifications of the track & field synthetic surfacing system that is being installed.
 - 4. Installation process and requirements for subbase (stone, asphalt, and concrete) and any conditions that may limit the track & field synthetic surface installation or affect quality of installation.
 - 5. Temperature/climatic conditions limiting quality of installation.
 - 6. Standard specification and application for recommended subbase primers, crack filler, patching and leveling material.
 - 7. Three product samples, a minimum of 6" x 6" in size, the same color, texture, thickness, etc. of the same type of surfacing to be installed for this project. This must be a representative sample of the product. This sample must be submitted and approved by the Owner prior to installation. At completion of the project this sample may be used as a comparison to judge the quality of the installed product.
 - 8. Material safety data sheets on all individual components of the product being installed.
 - 9. Provide a letter stating the Track & Field Synthetic Surfacing Contractor reviewed the asphalt specification and are accepting the specification as correct. Upon completion of the Asphalt paving and prior to installation of the track & field synthetic surface, the Track & Field Synthetic Surfacing Contractor will provide a letter accepting the installed asphalt and stating it is suitable to receive the track & field synthetic surface.

10. Letter from synthetic surfacing manufacturer approving the installer/applicator of the synthetic surface listed in these specifications.
 11. Written notice and acceptance that all in-ground field event equipment is installed as per the Contract Documents and the rules of the sport.
- B. The following information shall be submitted after completion of the specified work:
1. Provide a copy of the Track & Field Synthetic Surface vendor's standard Warranty noting any exceptions to the Warranty information included in this Specification Section.
 2. Provide a Care and Maintenance manual for the Owner's use in maintaining the synthetic surfacing.

1.4 QUALITY ASSURANCE

- A. Prior to installation, or during installation or at completion of installation of the synthetic surfacing, if the Owner has any question or doubt about the quality or formulation of the material, the Track & Field Synthetic Surfacing Contractor shall have the product tested. If the product meets these specifications, then the Owner shall pay for the cost of the testing; if the product does not meet these specifications, then the Track & Field Synthetic Surfacing Contractor shall pay for the testing. Any material failing to meet specifications will be replaced with new material at the Track & Field Synthetic Surfacing Contractor's expense.
- B. Slopes and Tolerances (NFSHSA):
1. The maximum lateral inclination permitted for the track across the full width of the track, preferably toward the inside lane, and across all runways, shall not exceed 2:100, 2.0 percent.
 2. The maximum overall downward inclination permitted in the running direction for the track, the running direction for all runways and the throwing direction for all landing sectors shall not exceed 1:1,000, 0.1 percent. Inclination shall be measured by comparing the start and end points of the races that use the straightaway portion of the oval, the last 20 meters of the javelin runway, the start and end points of other runways, not to exceed 40 meters, and the full graded length of each landing sector.
 3. In the high jump approach and takeoff area, the maximum overall downward inclination shall not exceed 1:100, 1.0 percent, in the running direction toward the center of the crossbar.
 4. The surface of a throwing circle shall be level.

1.5 SPECIAL PROJECT CONDITIONS

- A. The Track & Field Synthetic Surfacing Contractor will provide a project manager/superintendent on-site daily through the completion of the Track & Field Synthetic Surfacing Contractor's portion of the contract.
1. The on-site project manager/superintendent shall remain on site through the completion of the project. Substitution of project manager/superintendent shall not be permitted.
- B. The Track & Field Synthetic Surfacing Contractor will provide a technician that will serve as a consultant to the Owner and Contractor during the Asphalt Paving, first reviewing the asphalt specification, accepting the specification as correct, and then, providing daily review and guidance of the construction of the Asphalt Paving which will directly affect the tolerances and longevity of the eventual synthetic surfacing installation.
- C. Prior to installing any concrete, the Contractor must verify with the Track & Field Synthetic Surface manufacturer if any curing compounds or agents are allowed or acceptable.

1.6 SPECIFIC SCOPE OF WORK

- A. The Track & Field Synthetic Surfacing Contractor shall verify the entire track & field subbase and all events to determine that:
 - 1. The synthetic surface for the 400-meter track oval will accurately fit onto the Asphalt Paving base.
 - 2. That slopes and elevations meet required tolerances.
 - 3. No bird baths exceed the allowable limits as specified.
 - 4. The track & field areas will meet or exceed the rules of the sport.
- B. The Track & Field Synthetic Surfacing Contractor shall provide all labor, materials and equipment to perform the following work:
 - 1. The Track & Field Synthetic Surfacing Contractor is responsible for installing all track & field synthetic surfacing materials and line markings as designated in these specifications.
 - 2. Review Bidding documents and specifications, provide technical assistance, and approve Asphalt Paving base work as required in the specifications.
 - 3. Review and approve installation of all field event in-ground equipment before any track & field synthetic surfacing is installed as specified and shown on the Drawings.
 - 4. Brush and wash down all areas to be surfaced, as often as necessary during the installation of the track and field synthetic surface.
 - 5. Repair all birdbaths as required in these specifications.
 - 6. Install removable track & field synthetic surfacing (full pour polyurethane) plugs in all pole vault boxes, throw circles (cut plugs in half); apply synthetic surfacing to the junction box covers.
 - 7. Install special material (i.e., foam, board, etc.) in slot drain opening to prevent polyurethane from entering the opening. The drainage slot opening shall be neatly trimmed out (vertical cuts), after polyurethane installation, to allow proper drainage to occur. No polyurethane is allowed on the inside of the drainage slot opening. This shall apply only if the precast slot drain is installed.
 - 8. Repair all damaged areas, clean-up all glue, and remove excess polyurethane, primers and similar products. All trim cuts shall be neat and clean; on all curves the trim-out shall follow a radius line for accuracy and neatness.

1.7 WARRANTY/GUARANTEE

- A. General: Warranties / Guarantees specified in this Article shall not deprive the Owner of other rights the Owner may have under other provisions of the Contract Documents and are in addition to and run concurrent with other warranties/guarantees made by the Contractor under requirements of the Contract Documents.
- B. The following are inclusive of the term “Track & Field Synthetic Surface” for provisions of the guarantee:
 - 1. All slopes & tolerances as required in this specification.
 - 2. Synthetic track & field surface product as specified and represented by the Track & Field Synthetic Surface Manufacturer.
 - 3. All materials and products specified.
 - 4. All line markings installed in accordance with the Contract Documents.
- C. Track & Field Synthetic Surface Installer Guarantee: Provide in writing a “Full System Guarantee” agreement. The President/Principal(s) of both the Track & Field Synthetic Surface Installer and the Track & Field Synthetic Surface Manufacturer (if different) shall sign this document and it shall include the following:

1. All work executed under this section will be free from defects of material and workmanship for the specified period from date of Substantial Completion/Acceptance of the Owner.
 2. Any defects will be remedied on written notice at no additional cost to the Owner.
 3. The warranty shall not be prorated.
 4. All material shall be guaranteed to the extent that the surfacing:
 - a. Has been manufactured, applied and will perform in accordance with these and the manufacturer's specifications.
 - b. Will hold fast and/or adhere to the primer, asphalt, concrete, edging, filler, patches, or overlay materials.
 - c. Is Ultra-Violet resistant, will not bubble, blister, fade, crack, or wear excessively during the warranty period.
- D. The Track & Field Synthetic Surfacing Contractor shall, in the presence of the Owner, inspect the track and field synthetic surfacing each year until the end of the warranty period, or at any time requested by the Owner. Any defects in workmanship or materials (at no fault of the Owner) shall be repaired at the expense of the Track & Field Synthetic Surfacing Contractor to the satisfaction of the Owner.
- E. Contractor shall not be held liable for incidental or consequential damages. The Track & Field Synthetic Surface Warranties described shall be conditioned upon:
1. Owner shall maintain track as described in the Owner's Manual submitted by the Contractor to the Owner.
- F. The Warranty does not cover any defect, failure, damage caused by or connected with abuse, neglect, deliberate acts, acts of God, casualty or loads exceeding the Contractor's recommendations.
- G. Warranty period to be five (5) years minimum.

PART 2 – PRODUCTS

2.1 TRACK & FIELD SYNTHETIC SURFACE

- A. The track and field synthetic surface shall be as per the manufacturer's specifications, plus the following requirements and where discrepancies exist, they shall be brought to the attention of the Owner or Owner's representative prior to Bidding or Installation.
- B. Colors: Manufacturer's Standard Red. Confirm final color with owner.
- C. Basemat Structural Spray Track Surfacing: The following Products are approved for bidding:
1. Beynon Sports Surfaces:
 - a. Contact: John Beynon @ (410) 771-9473.
 - b. Product: Basemat Structural Spray (Porous): BSS 100.
 2. Advanced Polymer Technologies (APT):
 - a. Contact: (724) 452-1330.
 - b. Product: Basemat Structural Spray (Porous): Spurtan BS.
 3. Stockmeier Urethanes:
 - a. Contact: (704) 905-4156.
 - b. Product: Basemat Structural Spray (Porous): Stobitan SC.
 4. Conica:
 - a. Contact: (615) 499-3624
 - b. Product: Basemat Structural Spray (Porous): Conipur SP

- D. Synthetic Track Surfacing shall be IAAF approved thickness unless otherwise specified.
- E. Patching Material: All materials must be approved materials and compatible with the synthetic surface.

PART 3 – EXECUTION

3.1 INSPECTION AND ACCEPTANCE

- A. Examine all surfaces and contiguous elements to receive work of this section and correct, as part of the Work of this Contract, any defects affecting installation.
- B. Commencement of work will be construed as complete acceptability of surfaces and contiguous elements.

3.2 INSTALLATION REQUIREMENTS

- A. The following installation requirements must be met by the Track & Field Synthetic Surfacing Contractor:
 - 1. Installation by synthetic surface manufacturer approved project manager/superintendent applicators and technicians. Local laborers may be hired for non-technical work, only.
 - 2. Priming - The primer shall be spray-applied in accordance with the manufacturer's specifications. Only those areas which can be installed the same day should be primed. All concrete areas to be surfaced shall receive manufacturer's approved primer.

3.3 INSTALLATION OF TRACK & FIELD SYNTHETIC SURFACE

- A. Basemat Structural Spray (Porous):
 - 1. Thickness to match sample submitted to IAAF certified testing laboratory.
 - 2. Base Layer:
 - a. The SBR granules and polyurethane shall be mixed together on site to regulate the ratio/quantity of SBR, not to exceed 82% by weight in the base mat portion of the system. The single component polyurethane binder shall be mixed with the SBR rubber so that a minimum of 20%, by weight, exists in the final mixture. This mixture is then mechanically installed using the paver.
 - 3. Wearing layer:
 - a. The 0.5 to 1.5-millimeter EPDM granules shall be mixed with polyurethane, the single-component structural spray coating. The structural spray shall be made in two (2) uniform applications.

3.4 TIMING, LIMITATIONS, AND CONDITIONS AFFECTING INSTALLATION

- A. The track surfacing material shall be applied no sooner than 28 days after placement of the asphalt top course.
- B. Weather and Climate: If in the opinion of the synthetic track surfacing manufacturer or the Owner, weather and climatic conditions are having or will have an adverse effect on installation; work shall be delayed until the adverse condition has passed.
- C. Adjacent and Concurrent Construction: Installation shall not take place until the completion of the adjacent or concurrent construction operations which generate dust, airborne abrasives, or any other by-product that, in the opinion of the Owner or synthetic track surfacing manufacturer, would be harmful to the track material. Under specific direction of the Owner, the Track & Field Synthetic

Surfacing Contractor may be allowed to cover the track material with an approved covering if such harmful construction operations must occur after the track material has been installed.

END OF SECTION

SECTION 321823.40 – SYNTHETIC RUNNING TRACK LINE MARKINGS

PART 1 – GENERAL

1.1 SUMMARY

- A. This section covers all labor and materials required to install the track & field line markings.
- B. The Synthetic Surface Contractor is responsible for the purchase and installation of all paints and line markings.

1.2 CODES AND STANDARDS

- A. Codes and standards follow the current guidelines set forth by the National Federation of State High School Associations (NFSHSA).

1.3 SUBMITTALS

- A. The following information shall be submitted prior to installation of specified work:
 - 1. A list, similar to the one in Part 3.2 below, depicting the colors of all line markings and labels of the events to be included for approval prior to installation. Also, all symbols and markings clearly identified, illustrated, and their colors stated. The recommended NFSHSA colors shall be used.
 - 2. Installation process and requirements for line markings and any conditions that may limit the installation or affect quality of installation.
 - 3. Material safety data sheets on all products, as necessary.
- B. The following information shall be submitted at the completion of the specified work:
 - 1. Upon completion of all line markings, the Track & Field Synthetic Surfacing Contractor shall submit to the Owner a five (5) diagram/drawing depicting and identifying all line markings: 1) a key to the color codes, 2) a chart for all symbols, and 3) labels for all events.

PART 2 – PRODUCTS

2.1 PAINT

- A. The paint shall be a metal latex based paint typically used on Track & Field Synthetic Surface.

2.2 TEMPORARY REFERENCE MARKINGS

- A. These markings shall be removed at the completion of the project.

PART 3 – EXECUTION

3.1 SUMMARY

- A. General line markings of the 400-meter track and field events, shall be spray applied, using only paint, primers and finishes supplied and guaranteed by the approved manufacturer and/or supplier.
- B. All markings shall be in accordance with the rules of the NFSHSA and shall be certified for accuracy. The color code of the NFSHSA shall be followed.

- C. No line markings shall be installed if the weather conditions are not proper (i.e., too windy).

3.2 LINE MARKINGS

- A. Paint:
 - 1. All line markings to receive adequate paint to completely cover the track & field synthetic surface.
- B. Measure Line (Theoretical – not painted):
 - 1. Track oval will not utilize a regulation curb.
 - 2. Distance to right hand edge of the inside lane line of Lane 1 to be 20 centimeters from the measure line.
- C. Line Precedence:
 - 1. Lane lines to take precedence over other markings.
 - a. Numbers and letters to be broken at all lane line intersections.
 - 2. Waterfall starting lines take precedence over straight starting lines.
 - a. Straight starting lines to taper at waterfall starting lines – maintain a 1/2-inch gap.
- D. Chute Extensions:
 - 1. Chute extension lines to be solid not dashed.
 - 2. Break chute extension lies 2 inches either side of track oval lines.
- E. 100 Meters:
 - 1. One Direction – main straight away.
 - 2. Event label:
 - a. 100.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in the outside lane and is above the starting line.
 - 3. Color of starting line is white.
- F. 100 Meter Hurdles:
 - 1. One Direction – main straight away.
 - 2. Event label:
 - a. 100.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in the outside lane and is above the starting line.
 - 3. Color of the starting line is white.
 - 4. The hurdle tic marks are yellow.
 - a. Hurdle tic marks are a 2.5-inches wide by 3 inches high triangle, the triangle is pointing in the direction of running – Each lane shall have 2 tic marks with each tic mark adjacent to the lane line, but not touching the lane line.
- G. 110 Meter Hurdles:
 - 1. One Direction – main straight away.
 - 2. Event label:
 - a. 110.

- b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in the outside lane and is above the starting line.
 - 3. Color of the starting line is white.
 - 4. The hurdle tic marks are blue.
 - a. Hurdle tic marks are a 2.5-inches wide by 3 inches high triangle, the triangle is pointing in the direction of running – Each lane shall have 2 tic marks with each tic mark adjacent to the lane line, but not touching the lane line.
- H. 200 Meters:
 - 1. All in lanes.
 - 2. Event label:
 - a. 200.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in Lane 2 and is above the starting line.
 - 3. Color of the starting line is white.
- I. 400 Meters:
 - 1. All in lanes.
 - 2. Event label:
 - a. 400.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in Lane 2 and is above the starting line.
 - 3. Color of the starting line is white.
- J. 400 Meter Hurdles:
 - 1. All in lanes.
 - 2. Event label:
 - a. 400.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in lane 2 and is above the starting line.
 - 3. Color of the starting line is white.
 - 4. The hurdle tic marks are red.
 - a. Hurdle tic marks are a 2.5-inches wide by 3 inches high triangle, the triangle is pointing in the direction of running – Each lane shall have 2 tic marks with each tic mark adjacent to the lane line, but not touching the lane line.
- K. 800 Meters:
 - 1. Waterfall start and 1 turn stagger.
 - 2. Event label:
 - a. 800.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. The 1 turn stagger starting line is located in Lane 2, the waterfall starting line is located in the outside lane, and the labels are above the starting line.

3. Color of the 1 turn stagger starting line is white with a green insert.
 4. The color of the waterfall starting line is white.
- L. 1600 Meters:
1. Waterfall start.
 2. Event label:
 - a. 1600.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in the outside lane and is above the starting line.
 3. Color of the starting line is white.
- M. 1-Mile Run:
1. Waterfall start.
 2. Event label:
 - a. 1 mile.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in the outside lane and is above the starting line.
 3. Color of the starting line is white.
 4. Install 1-inch wide by 3-inch long white marks on the infield side of the inside lane line at the 3/4, 1/2, and 1/4 marks.
- N. 3200 Meters:
1. Waterfall start.
 2. Event label:
 - a. 3200.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in the outside lane and is above the starting line.
 3. Color of the starting line is white.
- O. 400 Meter Relay:
1. All in lanes.
 2. Event label:
 - a. 400.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in lane 2 and is above the starting line.
 3. Color of the starting line is white, same starting line as the staggered starting line for the 400 meters.
 4. The relay exchange zone markers are yellow.
 - a. Exchange zone markers are 36-inch wide by 18-inch high triangles, the two triangles point into the relay exchange zone, and the triangles are included in the 30-meter zone
- P. 800 Meter Relay:
1. Four turn stagger.

2. Event label:
 - a. 800R.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in lane 2 and is above the starting line.
 3. Color of the starting line is white with a red insert.
 4. The relay exchange zone markers are red.
 - a. Exchange zone markers are 36-inch wide by 18-inch high triangles, the two triangles point into the relay exchange zone, and the triangles are included in the 30-meter zone
- Q. 1600 Meter Relay:
1. Three turn stagger.
 2. Event label:
 - a. 1600R.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in lane 2 and is above the starting line.
 3. Color of the starting line is white with a blue insert.
 4. The relay exchange zone markers are blue.
 - a. Exchange zone markers are 36-inch wide by 18-inch high triangles, the two triangles point into the relay exchange zone, and the triangles are included in the 30-meter zone.
- R. 3200 Meter Relay:
1. One turn stagger.
 2. Event label:
 - a. 3200R.
 - b. 4 inches high.
 - c. The color of the label to be white.
 - d. Located in lane 2 and is above the starting line.
 3. Color of the starting line is white with a green insert.
 4. The relay exchange zone markers are green.
 - a. Exchange zone markers are 36-inch wide by 18-inch high triangles, the two triangles point into the relay exchange zone, and the triangles are included in the 30-meter zone.
- S. Break Lines:
1. The break line shall be a solid green arc line per Rule, Section 1, Article 10.
 2. Provide green dashes on the inside lane line of Lane 5 from box alley 2 start to break lines (both turns).
- T. Finish Line:
1. Location:
 - a. Common: Located at the point of curvature (PC) per plan.
 2. 2 inches wide and white in color.
 3. The intersection of the finish line with the lane lines shall be painted to conform with the current NCAA recommendation
 4. No lean line is to be provided.

- U. Box Alleys:
 - 1. Provide 1-turn box alley starts for the following events:
 - a. 800.
 - b. 1600.
 - c. 3200.
 - 2. Box 1 to be lanes 1 through 4.
 - 3. Box 2 to be lanes 5 through 8.
- V. Long/Triple Jump:
 - 1. Runway lines:
 - a. 2-inch wide lines.
 - b. White in color.
 - c. 48-inch wide runways (inside edge to inside edge of line).
 - 2. Distance marks:
 - a. Provide 1.5-inch long by 1-inch wide white lines outside the runway on the right hand (direction of running) side every foot beginning at 20 feet from the long jump foul line and extending the length of the runway or 150 feet, whichever is shorter.
 - b. Every 5- and 10-foot line to be 3 inches long by 1 inch wide.
 - c. Every 10-foot line to be labeled below the line facing the athlete.
- W. Pole Vault:
 - 1. Runway lines:
 - a. 2-inch wide lines.
 - b. White in color.
 - c. 48-inch wide runways (inside edge to inside edge of line).
 - d. Terminate runway lines at zero line.
 - 2. Zero line:
 - a. 1/2-inch wide line.
 - b. White in color.
 - c. 24-foot long centered on back edge of box (not flange).
 - 3. Marks:
 - a. Provide 36-inch long by 2-inch wide white line with label beside the line in the center of the runway at 12 feet from the back of the plant box.
 - b. Provide 12-inch long by 2-inch wide white lines in the center of the runway at 9, 10, 11, 13, 14, and 15 feet from the back of the plant box. Dimension labels to be placed outside the runway line.
 - 4. Distance marks:
 - a. Provide 1.5-inch long by 1-inch wide white lines outside the runway on the right- hand side (direction of running) every foot beginning at 15 feet from the plant box and extending the length of the runway or 150 feet whichever is shorter.
 - b. Every 5- and 10-foot line to be 3 inches long by 1 inch wide.
 - c. Every 10-foot line to be labeled below the line facing the athlete.
- X. Shotput:
 - 1. Dividing lines:
 - a. 2-inch wide lines.
 - b. White in color.

- c. Back edge of line to be on centerline of throw circle.
 - d. Extend 2.46 feet from edge of throw circle.
 - 2. Sector Lines:
 - a. To be at angle of 34.92 degrees.
 - b. 2-inch wide lines.
 - c. White in color.
 - d. Outside the recessed throwing circle.
 - e. Install 2-inch wide sector lines to the end of the landing area.
- Y. Discuss:
- 1. Dividing lines:
 - a. 2-inch wide lines.
 - b. White in color.
 - c. Back edge of line to be on centerline of throw circle.
 - d. Extend 2.46 feet from edge of throw circle.
 - 2. Sector Lines:
 - a. To be at angle of 34.92 degrees.
 - b. 2-inch wide lines.
 - c. White in color.
 - d. Outside the recessed throwing circle.
- Z. Lane numbers:
- 1. The numbers are a block style, 24 inches high, and the numbers will not have a color shadow.
 - 2. The color of the numbers will be white.
 - 3. There are 5 sets of numbers:
 - a. There is 1 set of numbers 5 feet before the 110M starting line.
 - b. There is 1 set of numbers 1 foot after the common finish line, facing to the outside of the track oval.
 - c. There is 1 set of numbers staggered in the first turn, above the 400M staggers.
 - d. There is 1 set of numbers staggered at the 300M, above the starting line.
 - e. There is 1 set of numbers staggered at the 200M, above the starting line.
- AA. Interval Marks:
- 1. Provide a 2-inch wide white line on the inside of the track oval extending from the inside edge of the inside Lane 1 line approximately 4 inches long.
 - 2. These lines are to be at 50-meter intervals starting at the common finish line and running the entire length of the track oval.
- BB. All color markings listed above must be reviewed and verified as correct, as per the rules and regulations of the governing body.

Note: All line markings must be reviewed and verified with the Owner's representative prior to installation.

END OF SECTION

SECTION 321823.41 – SYNTHETIC RUNNING TRACK CERTIFICATION SURVEY

PART 1 – GENERAL

1.1 SUMMARY

- A. This section covers all labor and materials required to provide certification of the final track & field facility. The Contractor is responsible for completing all survey work.

1.2 CODES AND STANDARDS

- A. The survey work must be completed by a licensed surveyor.
- B. Codes and standards follow the current guidelines set forth by the National Federation of State High School Associations (NFSHSA).

1.3 SUBMITTALS

- A. The following information must be submitted by the Contractor:
 - 1. After installation of the track & field synthetic surface and line markings:
 - a. The Contractor shall submit the below Track & Field Certification Survey, stating the completed facility meets requirements outlined in the NFSHSA Rulebook. The Engineer or Surveyor, selected by the Contractor, must survey the facility's as-built line markings.

- B. Certification Survey:

- 1. Facility Information:

Owner _____

Facility Name _____

Location _____

- 2. Surveyor/Engineer Information:

Firm Name _____

Contact _____

Phone # _____

Registration # _____

3. Survey Information:

Date of Survey _____

Weather Conditions _____

1.4 TRACK OVAL MEASUREMENTS

- A. Contractor shall provide for Engineer's review a completed Class 4 Markings Certification for Running Tracks per the latest ASBA (American Sports Builders Association) Construction and Maintenance Manual.
- B. The track survey and certification form shall be completed and stamped and signed by a licensed surveyor and the surveyor shall have provided similar work for at least 5 running tracks in the last 5 years.

END OF SECTION

SECTION 323113 – CHAIN LINK FENCE AND GATES

PART 1 – GENERAL

1.1 DESCRIPTION

- A. The Contractor shall provide all labor, materials, equipment, and services necessary for, and incidental to, the installation of chain link fence and gates, as shown on the Drawings and as specified herein.
- B. All chain link fence shall have a thermally-bonded and fused polymer color coating.
- C. All gates and gate hardware shall be powder coated.

1.2 QUALITY ASSURANCE

- A. Comply with standards of the Chain Link Fence Manufacturer's Institute.
- B. Provide steel fence and related gates as a complete system produced by a single manufacturer, including necessary erection accessories, fittings and fastenings.
- C. Comply with ASTM A53 for requirements of Schedule 40 piping.
- D. Comply with ASTM F668 Specification for Polymer Coated Chain Link Fence Fabric.
- E. Comply with ASTM F1043 Specification for Strength and Protective Coatings of Metal Industrial Fence Framework.
- F. Height of fence shall be measured from the top of concrete footing to the top of post.
- G. Manufacturer: Company shall be headquartered in the US having US manufacturing facility/facilities specializing in manufacturing chain link fence products with at least 5 years of experience.
- H. Fence contractor: Company with demonstrated successful experience installing similar projects and products in accordance with ASTM F567.
- I. Tolerances: Current published edition of ASTM specifications tolerances apply. ASTM specification tolerance supersede any conflicting tolerance.

1.3 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for chain-link fences and gates.
 - 1. Fence and gate posts, rails and fittings
 - 2. Chain link fabric, reinforcements, and attachments.
 - 3. Gates and hardware.
- B. Shop Drawings: Show locations of fences, gates, posts, rails, tension wires, details of extended posts, extension arms, gate swing, or other operation, hardware, and accessories. Indicate materials, dimensions, sizes, weights, and finishes of components. Include plans, gate elevations, sections details of post anchorages, attachment, bracing, and other required installation and operational clearances.

- C. Samples for Verification: For each type of chain-link fence and gate indicated:
 - 1. Polymer coated steel wire (for fabric) in 6-inch (150-mm) lengths on shapes for posts, rails, wires and gate framing.
 - 2. Two-stage powder coat finish, in 6-inch (150-mm) lengths on shapes for gate framing.
- D. Product Certificates: For each type of chain-link fence and gate, signed by product manufacturer:
 - 1. Strength test results for framing according to ASTM F1043.
 - 2. Material certifications, made in USA, Buy America Act or Buy America when required.
- E. Qualification Data: For installer.
- F. Field quality-control test reports.
- G. Maintenance Data: For the following to include in maintenance manuals:
 - 1. Polymer finishes.
 - 2. Powder coat finishes.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who has completed chain-link fences and gates similar in material, design and extent to those indicated for this Project and whose work has resulted in construction with a record of successful in-service performance.
- B. Pre-installation Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination."

1.5 PROJECT CONDITIONS

- A. Field Measurements: Verify layout information for chain-link fences and gates shown on Drawings in relation to property survey and existing structures. Verify dimensions by field measurements.

PART 2 – PRODUCTS

2.1 STEEL FRAME WORK

- A. Unless noted otherwise on the Drawings, minimum Nominal Framework Sizes shall be the following:

FENCE HEIGHT	LINE POSTS	END, CORNER & PULL POSTS	RAILS & BRACES	GATE FRAMES	*GATE POSTS	CONCRETE FOUNDATION DIA.		DEPTH
						Diameters	Corner/End	
						LINE POSTS	PULL & GATE POSTS	
3'	1-1/2"	2"	1-1/4"	1-1/2"	3"	12"	12"	3'
3'-6"	2"	3"	1-1/4"	1-1/2"	4"	12"	12"	3'
4'	2"	3"	1-1/4"	1-1/2"	4"	12"	12"	3'
4'-6"	2"	3"	1-1/4"	1-1/2"	4"	12"	12"	3'
5'	2"	3"	1-1/4"	1-1/2"	4"	12"	12"	3'
6'	2"	3"	1-1/4"	1-1/2"	4"	12"	18"	3'

FENCE HEIGHT	LINE POSTS	END, CORNER & PULL POSTS	RAILS & BRACES	GATE FRAMES	*GATE POSTS	CONCRETE FOUNDATION DIA.		DEPTH
						Diameters	Corner/End	
						LINE POSTS	PULL & GATE POSTS	
8'	2"	3"	1-1/4"	1-1/2"	4"	12"	18"	3'
10'	2-1/2"	3"	1-1/4"	1-1/2"	4"	12"	18"	3'
12'	3"	4"	1-1/4"	1-1/2"	4"	12"	18"	5'
16'	3-1/2"	4"	1-1/4"	1-1/2"	4"	12"	18"	5'

SCHEDULE 40 S/L PIPE TABLE		
NOMINAL SIZE (IN.)	ACTUAL OUTSIDE DIAMETER (IN.)	WEIGHT *(LB/FT)
1	1.315	1.67
1-1/4	1.660	2.27
1-1/2	1.900	2.71
2	2.375	3.65
2-1/2	2.875	5.79
3	3.500	7.58
3-1/2	4.000	9.11

50,000 PSI HOT DIPPED GALVANIZED STEEL TUBING		
NOMINAL SIZE (IN.)	ACTUAL OUTSIDE DIAMETER (IN.)	WEIGHT *(LB/FT)
1	1.315	
1-1/4	1.660	1.83
1-1/2	1.900	2.28
2	2.375	3.12
2-1/2	2.875	4.64
3	3.500	5.71
3-1/2	4.000	6.56

- B. Pipe must comply with ASTM F1043 Group 1A or 1C
- C. Round Steel Pipe and Rail: Round steel pipe and rail to be cold-rolled electric resistance welded pipe in accordance with ASTM 1043 materials group 1C, minimum steel yield strength 50,000 psi. Type B external coating, hot dip galvanized zinc 1.0 oz/ft² with a clear polymeric overcoat, Type D interior 90% by weight zinc-rich coating having a minimum thickness of 0.30 mils.
- D. Polymer Color Coated Pipe: Polymer coated pipe shall have a polyester or polyolefin coating fused and adhered to the exterior zinc coating of the galvanized pipe in accordance with ASTM F1043. The minimum thickness of the polymer coating shall be 3 mils.
1. Color: Black. To match fabric per ASTM F934.
- E. Polymer Coated Color Fittings: In compliance with ASTM F626. Polymer coating minimum thickness to be 0.006 in. fused and adhered to the zinc coated fittings. Color to match fence system.

2.2 CHAIN LINK FABRIC

- A. General: Height indicated on Drawings. Provide fabric in one-piece heights for fence heights up to 10 feet measured between top and bottom of outer edge of selvage knuckle or twist. Comply with ASTM A392, CLFMI CLF 2445, and requirements indicated below:
1. Steel Chain Link Wire Fabric:
 - a. Polymer Coated Steel Fabric: ASTM F668, the wire gauge specified for polymer coated wire is that of the metallic coated steel core wire.

- 1) 12 ga core fabric with 9 ga finish
- 2) Class 2b fused and adhered
- 3) Color: Black. In compliance with ASTM F934

B. Mesh Size:

1. 2 inches for track fences.
2. 1-3/4 inches for tennis court fencing.

C. Selvages: Knuckled top and bottom.

2.3 SWING GATES

A. Assemble gate frames with fully coped welds as shown on the Drawings or on Shop Drawings approved by the Engineer.

1. All ferrous metal components shall be blast cleaned to and SSPC-6 commercial blast clean.

B. Powder Coated Framework for Gates:

1. Colored Powder Coated Framework:

- a. Powder for coating shall be a polyester-based thermal setting resin.
- b. Powder coat system shall meet or exceed the following test requirements:
 - 1) Direct Impact Resistance: ASTM D2794-93, up to 160 inches per pound.
 - 2) Flexibility: ASTM D522-93, Method B, equal to or less than a 1/4-inch mandrel.
 - 3) Pencil Hardness: ASTM D3363-93a, HB-2H.
 - 4) Crosshatch Adhesion: ASTM D3359-97, Method B, 5B.
 - 5) Salt Spray Resistance: ASTM B117 plus 1,000 hours.
 - 6) Humidity Resistance: ASTM D2247 plus 1,000 hours.
- c. Moveable parts such as hinges, latches and drop rods may be field coated using a liquid polymer touch up.
- d. Chain link fabric on gate same as finish same for fencing.
- e. Color: To match that of the fencing system.

2.4 GATE HARDWARE

A. Hinges: Non-lift-off type, offset to permit 180-degree swing, and of suitable size and weight to support gate. Provide 1-1/2 pair of hinges for each leaf over 6 feet high.

B. Latch: Provide plunger bar type complete with flush plate set in concrete for all double gates and single gates over 10 feet. Padlock eye shall be an integral part of latch construction.

1. Provide plunger bar complete with flush plate set in concrete on each gate leaf
2. Provide flush plate set in concrete for both the fully open position and full closed position

C. Keeper for Vehicle Gates: Provide keeper which automatically engages the gate leaf and holds it in open position until manually released.

2.5 MISCELLANEOUS MATERIALS AND ACCESSORIES

A. Post Tops: Steel, wrought iron, or malleable iron.

B. Stretcher Bars: One piece equal to full height of fabric, minimum cross-section 3/16 inch by 3/4 inch.

- C. Metal Bands (for stretcher bars): Steel, wrought iron, or malleable iron, to secure stretcher bars to end, corner, pull and gate posts.
- D. Wire Ties:
 - 1. For tying fabric to line posts, rails and braces: 9-gauge steel wire.
- E. Truss Rods: 3/8-inch diameter.
- F. Angle Beams, I Beams and Steel Shapes: ASTM A36.
- G. Bolts and Nuts: ASTM A307, Grade A.

PART 3 – EXECUTION

3.1 EXAMINATION

- A. Examine areas and conditions, with Installer present, for compliance with requirements for a verified survey of property lines and legal boundaries, site clearing, earthwork, pavement work and other conditions affecting performance:
 - 1. Begin installation in general site areas or those not directly adjacent to the playing field only after final grading including topsoiling and paving is completed in that area or as otherwise permitted by Engineer.
 - 2. For installation directly adjacent to the playing field, coordinate footing installation timing with final installation of playing field materials so as not to contaminate, destroy or displace these playing field materials.
 - 3. If unsatisfactory conditions are present, proceed with installation only after they have been corrected.

3.2 PREPARATION

- A. Coordinate fence and gate installation with completion of finished grading and installation of adjacent finish field materials.
- B. Stake locations of fence lines, gates and terminal posts. Do not exceed intervals of 500 feet or line of sight between stakes. Indicate locations of utilities, irrigation system, underground structures, benchmarks and property monuments.

3.3 INSTALLATION

- A. Space posts equidistant in the fence line with a maximum of 10 feet on center or as shown on Drawings.
- B. Footings: Excavate holes as indicated for fence and gate posts. Excavate footings to depths and widths as noted in Specifications or on drawings. Install gravel drainage material in bottom of hole as shown on the drawings.
- C. Setting Posts and Footings at Concrete Areas: Set posts in center of hole. Embed post so that bottom of post is flush with the bottom of concrete footing and in gravel drainage layer. Fill hole with concrete. Plumb and align posts. Vibrate or tamp concrete for consolidation. Finish elevation on top of footing to be coordinated with construction of concrete adjacent to posts or as shown on drawings. Do not attach fabric to posts until concrete has cured a minimum of 7 days.

- D. Setting Posts and Footings at Warning Track Areas: Set posts in center of hole. Embed post so that bottom of post is flush with the bottom of concrete footing and in gravel drainage layer. Fill hole with concrete. Plumb and align posts. Vibrate or tamp concrete for consolidation. Finish elevation on top of footing to be set below finish grade. Do not attach fabric to posts until concrete has cured a minimum of 7 days.
- E. Setting Posts and Footings in Grass Areas: Set posts in center of hole. Embed post so that bottom of post is flush the bottom of concrete footing and in gravel drainage layer. Fill hole with concrete. Plumb and align posts. Vibrate or tamp concrete for consolidation. Finish concrete in a dome shape above ground to shed water. Do not attach fabric to posts until concrete has cured a minimum of 7 days.
- F. Locate corner posts at corners and at changes in direction. Use pull posts at all abrupt changes in grade and at intervals no greater than 500 feet. On runs over 500 feet, space pull posts evenly between corner or end posts. On long curves, space pull posts so that the strain of the fence will not bend the line posts.
- G. Install top rail continuously through post caps or extension arms, bending to radius for curved runs. Install expansion couplings as recommended by fencing manufacturers.
- H. Install intermediate rails in one piece between posts and flush with post on fabric side using special offset fittings where necessary.
- I. Diagonally brace corner posts, pull posts, and terminal posts to adjacent line posts with truss rods and turnbuckles.
- J. Attach fabric to playing field side of fence. Bottom of fabric to be set on finished grade of curb, track, or playing field except when indicated otherwise. Thread stretcher bars through fabric using one bar for each gate and end post and two for each corner and pull post. Pull fabric tight so that the maximum deflection of fabric is 2 inches when a 30-pound pull is exerted perpendicular to the center of a panel. Maintain tension by securing stretcher bars to posts with metal bands spaced 15 inches on center. Fasten fabric to steel framework with wire ties spaced 12 inches on center for line posts and 24 inches on center for rails and braces. Bend back wire ends to prevent injury. Tighten stretcher bar bands, wire ties, and other fasteners securely.
- K. Position bolts for securing metal bands and hardware so nuts are located opposite the fabric side of fence. Tighten nuts and score excess threads.
 - 1. Secure post tops, extension arms, and caps with one-way cadmium plated steel screws.
- L. Install gates plumb and level and adjust for full opening without interference. Install ground-set items in concrete for anchorage, as recommended by fence manufacturer. Adjust hardware for smooth operation and lubricate where necessary. Attach fabric as for fencing. Install ground-set items in concrete as shown on the drawings.
- M. Touch Up: Small nicks or other blemishes shall be touched up with paint materials suitable for and matching the finish of the damaged material. Severely damaged fencing/gates deemed as unacceptable at the sole discretion of the Owner or its representatives shall be replaced at the contractor's expense.

END OF SECTION

SECTION 329110 – AMENDED TOPSOIL FOR ATHLETIC FIELDS

PART 1 – GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 Specification Sections, apply to this section.
- B. Soil Testing Report. See Division 1.

1.2 SUMMARY

- A. This Section includes establishing an amended topsoil field as indicated on the drawings.
- B. Amended topsoil is to be used for all areas inside the limit of the field area as shown on the Drawings.
- C. Minimum thickness shall be as noted on the Drawings, for all proposed athletic field areas.

1.3 REFERENCE STANDARDS

- A. Comply with applicable requirements of the following standards. Where these standards conflict with other specified requirements, the most restrictive requirement shall govern, unless otherwise directed by the Engineer.
 - 1. American Society of Testing and Materials (ASTM):
 - a. C 136 Sieve Analysis of Fine and Coarse Aggregates.
 - b. D 422 Particle-Size Analysis of Soils.
 - c. E 11 Wire-Cloth Sieve for Testing Purposes.
 - d. D 5268 Standard Specification for Topsoil Used for Landscaping Purposes.
 - e. F 2396-4 Guideline for High Performance Sand Based Sport Fields.
 - 2. “Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO).

1.4 SUBMITTALS

- A. Supplier List: Submit list of procured and contracted suppliers of all materials required for the construction of the athletic field.
- B. Material Certifications: Manufacturer's or vendor's certified analysis for:
 - 1. Sand amendments.
 - 2. Organic amendments.
 - 3. Fertilizer and chemical amendments.
 - 4. Lime.

- C. Product Data: Submit manufacturer's product data and samples as noted for the following:
 - 1. Fertilizer and chemical amendments.
- D. Samples: Submit samples of each of the following materials for review and approval prior to delivery to site:
 - 1. Sand Amendment – 1-gallon.
 - 2. Organic Amendment – 1 gallon.
 - 3. Loam Borrow – 1 gallon.
 - 4. Prepared Root Zone Mix – 1 gallon.
- E. Preliminary Fertility/Chemical Schedule:
 - 1. Submit during construction and prior to grow-in. Schedule should include complete grow-in period up to the anticipated Substantial Completion date. This schedule as well as specific applications may be adjusted during the maintenance period as based on Fertility testing results, recommendations from the Owner's Testing Laboratory, climatic conditions, etc. Changes to the schedule shall be reviewed by the Engineer and Owner.
- F. Provide Engineer with a complete list of equipment proposed to be used during topsoil placement. No heavy machinery or rubber-tired loaders will be permitted on the established subgrade. Utilize low pressure track machines only to move soil.

1.5 QUALITY ASSURANCE

- A. All work shall be performed by one (1) Contractor with proven experience in amended topsoil athletic field construction.
- B. Field & Fertility Testing Agent(s):
 - 1. The Contractor shall utilize an independent Testing Agent, specializing in Natural Turf Pathology and Soil testing for Athletic Fields for all prequalification testing. The Testing Agent shall be A2LA accredited and be insured.
 - 2. All costs associated with pre-qualification testing shall be the responsibility of the Contractor.
 - 3. All costs associated with in-field testing shall be the responsibility of the Owner.
 - 4. See 1.6 Quality Control for specific Field Testing requirements.

1.6 QUALITY CONTROL

- A. Submit samples of each of the following materials for performance testing prior to shipping.
 - 1. Rootzone Mix:
 - a. Submit a one-gallon sample for every 300 cubic yards of rootzone mix to the Owner's Testing Laboratory for compliance with the specification.
- B. Pre-bid Materials Inspection and Testing:
 - 1. Bidders are encouraged to:
 - a. Pre-test sand materials with an independent Testing Agent prior to submitting a bid. This does not guarantee that the materials or source will be approved for construction.

2. All costs associated with pre-bid testing shall be borne by the bidder.

1.7 DELIVERY, STORAGE AND HANDLING

- A. All materials shall be delivered and stored within the Contractor's work limits or in an area approved by the Owner.
- B. All material shall be stored in strict accordance with the manufacturer's recommendations.
- C. Packaged Materials: Deliver packaged materials in containers showing weight, analysis, and name of manufacturer. Protect materials from deterioration during delivery, and while stored at site.
- D. Topsoil Amendments:
 1. Deliver tested and approved lots in clean, washed and covered trucks to eliminate contamination during transportation. Place directly on playing field. Do not stockpile on site.

1.8 PROJECT CONDITIONS

- A. Coordinate the placement of topsoil with the completion of all underground work including that of the other trades. The subgrade elevations shall be left within plus/minus .10 feet of the proposed subgrade elevations.

PART 2 – PRODUCTS

2.1 EXISTING TOPSOIL

- A. The Contractor shall review the existing Geotechnical and Topsoil Reports.
- B. Existing topsoil within the limit of work may be used in the development of the required root zone mix.
- C. Actual topsoil depths and conditions may vary from the results reflected in these reports.

2.2 IMPORTED TOPSOIL

- A. Topsoil may be imported if existing topsoil is not deemed acceptable for use in the Rootzone Mix, or if additional quantities are required.
- B. Imported Topsoil shall be natural, fertile, sandy loam as classified by the US Department of Agriculture Soil Classification System, typical of the cultivated topsoil of the locality.

2.3 ROOTZONE MIX

- A. The amended topsoil rootzone mix shall meet the following performance requirements:
 1. Organic Matter Content: Not less than 4% or more than 5% by weight, of decayed organic matter as determined by ASTM F1647.
 2. 3/4" screened to produce a material free from sub-soil, large stones, earth clods, sticks, stumps, clay lumps, roots or other extraneous matter or debris.
 3. Free of Quackgrass rhizomes, Agropyron Repens, Nutgrass tubers, Cyperus Esculentus, and all other primary noxious weeds.
 4. pH range between 6.0 and 7.0.

5. Shall conform to following particle size distribution, as determined by the pipet method in compliance with ASTM F1632 or ASTM D422.

PARTICLE TYPE	PARTICLE SIZE	WEIGHT PERCENTAGE
Gravel	> 2.0 mm	< 5%
Sand	.05-2.0 mm	72-76%
Silt	.002-.05 mm	10-15%
Clay	< .002 mm	5-10%

6. 50% of the sand fraction shall be medium sand or coarser (greater than .25 mm)
7. Maximum particle size shall have a diameter of 0.5 inches (1.27 cm).
8. Rootzone bulk density shall be between 1.45 and 1.6.
9. Ratios of nitrate, phosphorus, magnesium manganese, iron, zinc and calcium as recommended by Testing Agent.

2.4 SAND AMENDMENTS

A. Processed Sand:

1. Particle Size Distribution of Rootzone Sand (ASTM F2396):

SIZE FRACTION	U.S. STANDARD SIEVE	PARTICLE DIAMETER RANGE	% RETAINED ON SIEVE
Gravel	4	> 4.75 mm	0%
Gravel	6	3.4-4.75 mm	<5%
Fine Gravel	10	2.0-3.4 mm	<20%
Very Coarse Sand	18	1.0-2.0 mm	<20%
Coarse Sand	35	0.50-1.0 mm	25-50%
Medium Sand	60	0.25-.5 mm	>25%
Fine Sand	100	0.15-0.25 mm	<10%
Very Fine Sand	270	0.05-0.15 mm	5% maximum
Silt		<0.002-0.05 mm	5% maximum
Clay		<0.002	3% maximum

- a. No more than 30% in the combined very coarse sand, fine gravel, and gravel fractions.
- b. At least 60% of the total sand shall be in the combined medium sand and coarse sand fractions.
- c. No more than 15% in the combined fraction less than 0.25 mm (fine sand, very fine sand, silt and clay fractions).
- d. A Coefficient of Uniformity (CU = D60/D10) value of 2.5 to 4.5.

2.5 ORGANIC AMENDMENTS

A. Compost

1. Composted in an in-vessel system, through a thermophilic stage, to a mesophilic stabilization phase. It shall have been aged for at least 1 year. The material shall be proven to be non-phytotoxic, and be screened to 1/2 inch.
2. Performance Criteria:
 - a. Organic Matter: 60% or greater.
 - b. pH: 5.0 – 8.0%.
 - c. Ash Content: No more than 40%.
 - d. Moisture Content: 35 – 55%.
 - e. Soluble Salts: <6.0 mmhos/(dS).
 - f. C:N ratio: 15 to 30:1.

2.6 ACCESSORIES

A. Limestone:

1. Natural limestone containing not less than 85% of total carbonates, ground so that not less than 90% passes a 10-mesh sieve and less than 50% passes a 100-mesh sieve.

B. Aluminum Sulfate:

1. Aluminum Sulfate shall be unadulterated and shall be delivered in containers with the name of the material and manufacturer, and net weight of contents.

C. Fertilizer:

1. When applied as a topsoil amendment, fertilizer shall have an analysis that will deliver appropriate amounts of nitrogen, phosphorus and potassium as required to remedy deficiencies revealed by testing the topsoil.
2. Fertilizer shall be delivered in manufacturer's standard containers printed with manufacturer's name, material weight and guaranteed analysis.

D. Superphosphate:

1. Superphosphate shall be composed of finely ground phosphate rock as commonly used for agricultural purposes, and containing not less than 20% available phosphoric acid.
2. Superphosphate shall be delivered in manufacturer's standard containers printed with manufacturer's name, and guaranteed analysis.

E. Herbicide:

1. Apply a pre-emergent herbicide to the installed topsoil. Apply a post-emergent herbicide when weed infestation exceeds 5% of any planted area. Reapply post-emergent herbicide application until weeds are eradicated. All herbicides must meet requirements of application as established by the Owner.

PART 3 – EXECUTION

3.1 EXAMINATION AND PROTECTION

- A. Verification of Conditions: Examine areas and conditions under which all work of this Section is being performed. Do not proceed with any work until unsatisfactory conditions have been corrected. Commencement of work implies acceptance of all areas and conditions.
- B. Protection of Work: Protect all on-going work, so as not to delay work due to weather or project related construction. This includes but is not limited to the use of tarps, geotextile, plywood and other protective measures.
- C. Unanticipated Conditions: Notify the Engineer immediately upon finding evidence of previous structures, filled materials that penetrate below designated excavation levels, or other conditions which are not shown, or which cannot be reasonably assumed from existing surveys and geotechnical reports.

3.2 PREPARATION OF SUBGRADE

- A. Existing subgrade shall be scarified a minimum depth of 4 inches and cleared of stones greater than 2 inches, sticks, roots and other extraneous material prior to spreading topsoil.
- B. The final elevation of the subgrade shall be within one-half inch on a 25 foot by 25 foot grid of the finished grades indicated on the Contract Drawings. Laser controlled or indicated equipment shall be used for this part of the work.
- C. The final subgrade shall mirror the final finish elevation of the field surface regarding slope except where noted on the drawings.
- D. The subgrade shall be loosened to 80% of the maximum dry density as determined by the standard proctor test.

3.3 ROOTZONE MIX INSTALLATION

- A. All amendments and all additional topsoil to be bulk mixed prior to installation to produce a consistent homogenous mixture for placement in athletic field areas.
- B. A sample of the rootzone mixture in the proper ratios shall be tested for particle size, permeability (Ksat), bulk density, aeration and capillary porosity, and organic matter content using ASTM F-1815-97 standard method prior to bulk mixing for placement.
- C. Once mixing commences, samples shall be taken from the first 20 cubic yards, and every subsequent 300 cubic yards to confirm compliance with specified performance requirements.
- D. Premix the sand and soil components prior to screening. Mix required parts sand with required parts topsoil on a volume basis to achieve 72-76% sand by weight in the final mixture. Tumble the previously mixed sand-soil blend to achieve a homogeneous mixture.
- E. Rootzone Mix shall not be spread until it is possible to follow within 72 hours with seeding or sodding operations.
- F. Rootzone Mix shall not be placed when subgrade or rootzone mix are frozen, excessively wet or excessively dry. The Landscape Architect or the Owner's Representative may delay or reject rootzone placement if deemed appropriate based on field conditions.

- G. Begin placement of rootzone mix only after irrigation system layout and installation have been approved and after verification that the finish grade of the subgrade conforms to the installation tolerances.
 - 1. Depressions in the subgrade shall be removed/re-graded to a smooth surface prior to and during placement of rootzone material.
- H. The approved rootzone mix shall be dumped at the edge of the field and systematically worked outward onto the field. Equipment used for placement of rootzone mix/field shall utilize turf type tires or low pressure track equipment which will not damage or overly compact the field installation.
- I. The rootzone mix shall be spread onto the field in an even depth as shown on the drawings within a tolerance of one-quarter inch. The finish grade slope shall conform exactly to the subgrade slope, (unless indicated otherwise on drawings) when the root zone mix has been spread uniformly over the field and compacted to 75% minimum to 82% maximum dry density as determined by the standard proctor test. The field shall be compacted, settled and firmed uniformly. Operate the irrigation system as necessary to settle and compact the mix to a final uniform depth.
- J. Rootzone mix shall be placed in two equal lifts to ensure a minimum specified depth.
- K. Finish grades shall be achieved by using a combination of laser-operated equipment, string lines, drag screens, rollers, and hand raking with a tolerance of 1/4 inch in 25 feet, non- cumulative.

3.4 FIELD QUALITY CONTROL

- A. Subgrade Ground Surface Requirements:
 - 1. Perform density tests in accordance with ASTM A1556, ASTM D2167, or ASTM D2022. Minimum one test per 5000 SF.
 - 2. Perform moisture tests in accordance with ASTM D3017.
 - 3. Where field-testing is performed using nuclear test methods, verify calibration of both density and moisture gages at the beginning of work, on each different type of material encountered, and additionally as directed by the Owner.
- B. Contractor shall submit a complete maintenance schedule based on rootzone soil and tissue testing, recommendations by the testing agent and as discussed with the Owner's representative. This shall occur throughout the grow-in period and up to Substantial Completion.
- C. Grade Verification: A certified survey shall be made of the as-built condition at the subgrade, rootzone mix for conformance to specified elevations.
- D. Grade Verification: A certified survey shall be made of the as-built condition at subgrade, compacted rootzone mix, established turf field. A survey of the finished spot grades is to be developed by a State licensed surveyor over the entire surface in a 25 foot grid. The survey shall be certified (signed) and submitted to the Owner and its representatives for approval prior to installation of the grass material. In no event shall the Work contain depressions or other areas where water does not freely drain from the field

3.5 DISPOSAL OF EXCESS AND WASTE MATERIALS

- A. Removal from Owner's Property: Remove waste materials, including materials not allowed for fill, backfill or site grading as specified within, trash, and debris, and dispose of it properly off Owner's property at Contractor's expense.

- B. Leave the site in a clean, satisfactory condition ready to receive subsequent operations.

END OF SECTION

SECTION 329113 – SOIL PREPARATION

PART 1 – GENERAL

1.1 SUMMARY

- A. This section includes provisions for the placement of topsoil outside of the athletic field limits in conformance with the lines, grades and thicknesses as shown on the Drawings and as herein specified.
- B. Minimum thickness is 6 inches, for all areas disturbed during construction and not receiving other surface treatment.
- C. The Contractor shall furnish all materials and perform all work in accordance with these specifications, drawings, and instructions provided by the Owner.

1.2 SUBMITTALS

- A. Samples: Furnish earth materials to the testing laboratory for analysis and report, as directed by the Engineer or as outlined in the specifications.
- B. Quality Control Submittals:
 - 1. Test Reports: The testing laboratory shall submit written reports of all tests, investigations, and recommendations to the Contractor and the Engineer. Indicate quantities of materials necessary to bring topsoil into compliance with textural/gradation requirements. Indicate quantity of lime and quantity and analysis of fertilizer.

1.3 REFERENCES

- A. Comply with the latest edition of the following standards:
 - 1. SCDOT Standards
 - 2. “Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO).”
 - 3. ASTM International (ASTM)
 - a. C33, Standard Specification for Concrete Aggregates.
 - b. C602, Standard Specification for Agricultural Liming Materials
 - 4. U.S. Bureau of Reclamation (USBR)
 - a. 514.4.4, Reclamation Instructions, Series 510—Land Classification Techniques and Standards, Part 514—Laboratory Procedures, Chapter 4—Particle-Size Analyses.
 - b. 14.8.7, Reclamation Instructions, Series 510—Land Classification Techniques and Standards, Part 514—Laboratory Procedures, Chapter 8—Soil Chemical Tests

1.4 QUALITY ASSURANCE

- A. Provide and pay for all costs in connection with an approved independent testing facility to determine conformance of soils and aggregate with the specifications.

1.5 PROJECT CONDITIONS

- A. Coordinate the placement of topsoil with the completion of all underground work including that of the other trades.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Topsoil: Natural, friable, fertile, fine loamy soil possessing the characteristics of representative topsoils in the vicinity which produces a heavy growth; free from subsoil, objectionable weeds, litter, sods, stiff clay, stones larger than 1 inch in diameter, stumps, roots, trash, toxic substances, or any other material which may be harmful to plant growth or hinder planting operations. Contractor is to verify amount stockpiled and supply any additional as needed:
1. Topsoil shall contain not less than 6% nor more than 20% organic matter as determined by the wet combustion method (chronic acid reduction); topsoil shall have a pH value of not less than 5.5 nor more than 7.0;
 2. Topsoil shall meet the following mechanical analysis:

SIZE OF SCREEN	% OF SOIL RETAINED	% OF SOIL PASSING
1"	0	100
1/4	3	97
No. 100	40-60	40-60

3. Imported topsoil in which more than 60% of the material passing a No. 100 sieve shall be rejected. All percentages are to be based on the dry weight of the samples.
4. Laboratory tests of the topsoil shall be performed by a certified testing laboratory, and shall perform tests for the following:
 - a. Sieve particle size analysis and gradient of mineral content
 - b. Chemical analysis of the following:
 - 1) pH and buffer pH.
 - 2) Percent of organic content.
 - 3) Nutrient levels of phosphorus, potassium magnesium, manganese, iron, zinc and calcium.
 - 4) Soluble salt.
 - 5) Cation exchange capacity (CEC).
 - c. Recommended fertilizer and rate of application for low and medium level nutrient soils.

2.2 MATERIAL ACCEPTANCE

- A. Topsoil may be acquired from approved sites that are designated on the Drawings. If no sites are designated, material proposed for use as topsoil must be stockpiled, sampled, and tested prior to use.
- B. Topsoil containing foreign material may be rejected on the basis of visual examination by the Engineer, prior to testing.
- C. Acceptance of topsoil shall be based upon test results. Tested topsoil must be approved in writing by the Engineer before any material is used.

2.3 SOIL AMENDMENT

- A. Textural Amendments: Amend as necessary to conform to required composition by incorporating sand, peat, manure, or sawdust
- B. Fertilizer: Shall be delivered to the site, mixed as specified, in the original unopened standard size bags showing weight, analysis and name of manufacturer. Store fertilizer in a weatherproof place and in such a manner that it shall be kept dry and its effectiveness shall not be impaired.

1. Percentages of nitrogen, phosphorus and potash shall be based on laboratory test recommendations. For the purpose of bidding, assume 10% nitrogen, 6% phosphorus and 4% potash by weight. At least 50% of the total nitrogen shall contain no less than 3% water-insoluble nitrogen. At least 60% of the nitrogen content shall be derived from super-phosphate containing not less than 18% phosphoric acid or bone meal containing 25% to 30% phosphoric acid and 2% to 3% nitrogen. Potash shall be derived from muriate of potash containing 55% to 60% potash.
 2. Grass or sodded areas shall have fertilizer applied according to soil text report or as specified on the drawings.
- C. Organic Matter: Leaf matter and yard waste composted sufficiently to break down all woody fibers, seeds, and leaf structures, and free of toxic and non-organic matter. Organic matter shall be commercially prepared compost. Coarse sand shall be clean, sharp, natural sands free of limestone, shale and slate particles, ASTM C33 fine aggregate with a Fines Modulus Index of 2.75 or greater.
- D. Lime: Shall be ground palletized, or pulverized lime manufactured to meet agricultural standards and contain a maximum of 60% oxide.

PART 3 – EXECUTION

3.1 STOCKPILING

- A. Stockpile topsoil from on-site sources or provide from off-site sources and stockpile, if on-site quantities are deficient.
- B. Stockpiles are to contain not less than 200 cubic yards or the minimum required for the project.
- C. Stockpiles are to have a maximum height of 10 feet and be trimmed to uniform surfaces and slopes.
- D. The sites of all stockpiles and adjacent areas, which have been disturbed are to be graded and put into an acceptable condition by seeding, as directed by the Engineer.

3.2 PREPARATION

- A. Preparation - Disk, drag, harrow or hand rake subgrade to a depth of 3 inches to provide bond for topsoil. Topsoil, which must be transported across finished walks, shall be delivered in such a manner that no damage will be done to the walks. The Contractor shall be responsible for the repair of such damage.
- B. Before placing topsoil, rake subsoil surface clear of stones larger than 1.5 inches, debris, and roots. Compact topsoil to form a layer with minimum depth of 4 inches in lawn areas and 12 inches in shrub beds. Topsoil shall be placed so that after final settlement there will be good drainage (and conforming to elevations shown on drawings). Contractor is to maintain surfaces and place any additional topsoil necessary to replace that which may have eroded before acceptance.
- C. Locations containing unsuitable subsoil shall be treated in one of the following manners:
 1. Where unsuitability within the construction site is deemed by the Owner to be due to excessive compaction caused by heavy equipment or by the presence of boards, mortar, concrete or other construction materials in subgrade, and where the natural subsoil is other than A.A.S.H.T.O. classification of A6 or 7, the Contractor shall loosen such areas with spikes, discs, or other means to loosen the soil to a condition acceptable by the Owner. The Contractor shall also remove all debris and objectionable material. Soil should be loosened to a minimal depth of

12 inches with additional loosening as required to obtain adequate drainage. Contractor may introduce peat moss, sand, or organic matter into the subsoil to obtain adequate drainage should he so desire. All such remedial measures shall be considered as incidental to the work and no extra payment shall be made for this part of the work; and

2. Where subgrade is deemed by the Owner to be unsuitable because the natural subsoil falls into an AASHTO classification of A6 or 7 and contains moisture in excess of 30%, then such a condition shall be rendered suitable by installation of a subdrainage system or by other means described elsewhere in these specifications. Where such conditions have not been known or revealed prior to planting time and where they have not been recognized in the preparation of drawings and specifications, then the Owner shall issue a change order to install the proper remedial measures, all of which shall be in addition to the contract sum.

3.3 TOPSOIL PLACEMENT

- A. Do not place topsoil when subsoil or topsoil is frozen, excessively wet, or otherwise detrimental to the Work.
- B. Mix soil amendments, lime, and fertilizer with topsoil before placement or spread on topsoil surface and mix thoroughly into entire depth of topsoil before planting or seeding. Delay mixing of fertilizer if planting or seeding will not occur within 3 days.
- C. Place 1/2 of total depth of topsoil and work into subgrade soil to create a transition layer. Place remainder of topsoil to depth after compacting to 75% where seeding and planting are scheduled.
- D. Uniformly distribute to within 1/2 inch of final grades. Fine grade topsoil eliminating rough or low areas and maintaining levels, profiles, and contours of subgrade to ensure positive drainage.
- E. Remove stones exceeding 1 inch, roots, sticks, debris, and foreign matter during and after topsoil placement.
- F. Remove surplus subsoil and topsoil from Site. Grade stockpile area as necessary and place in condition acceptable for planting or seeding.

3.4 CLEANING

- A. Remove all surplus subsoil and topsoil from project site.
- B. Leave the site in clean, satisfactory condition ready to receive subsequent operations.

END OF SECTION

SECTION 329200 – TURF AND GRASSES

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the preparation of ground surfaces, fertilization of applicable areas, seeding, mulching of applicable surface areas, and maintenance of turf areas until such time as project is accepted by Owner. Applicable areas shall include those identified on the Contract Drawings.

1.2 SUBMITTALS

- A. Quality Control Submittals:
 - 1. Certification:
 - a. Submit manufacturer's or vendor's certified analysis for soil amendments and fertilizer materials.
 - b. Submit vendor's certified analysis for each grass seed mixture required, stating botanical and common name, percentages by weight, percentages by purity, germination, and weed seed.
- B. Maintenance Instructions: Submit instructions recommending procedures to be implemented for maintenance of landscaped work for one (1) full year. Submit prior to expiration of Contractor's maintenance period.
- C. Submit description of planned mulching techniques and corresponding manufacturer's installation recommendations for approval by Owner.

1.3 QUALITY ASSURANCE

- A. All turf and grasses work shall be performed by one Contractor, with proven expertise in this type of construction, completing at least 5 similar projects within the last 5 years.
- B. Package standard products with the manufacturer's certified analysis. For other materials, provide analysis by recognized laboratory made in accordance with methods established by the Association of Official Agriculture Chemists, wherever applicable.
- C. The Contractor shall provide and pay for all costs in connection with an approved independent testing facility to determine conformance of materials with the specifications.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Deliver packaged materials in containers, showing weight, analysis, and name of manufacturer. Protect materials from deterioration during delivery, and while stored on site.

PART 2 – PRODUCTS

2.1 MATERIALS

A. Fertilizer:

1. Commercial fertilizer (5-10-5) inorganic, or organic, containing not less than five (5) percent nitrogen, ten (10) percent available phosphoric acid, and five (5) percent water soluble potash.
2. If, as an alternative, the Contractor wishes to substitute for commercial fertilizer 5-10-5, another commercial fertilizer with a 1-2-1 ratio, such as 10-20-10 or 6-12-6, they may do so with the approval of the Owner and the rate of fertilizer to be used shall be whatever amount is required to furnish the same amount of nitrogen as would be supplied by the 5-10-5.

B. Mulch:

1. Provide and install a mulch adequate to protect the seeding during its growing period. It shall be the responsibility of the Contractor to determine the appropriate mulching techniques for the particular site conditions and acquire approval of the same from the Owner.
2. Clean straw for gentle slopes, consisting of stalks of oats, wheat, rye, or other approved crops which are free of noxious weed seeds. Weight shall be based on a fifteen (15) percent moisture content.
3. Mulching blanket for steep slopes and drainage swales: “Curlex Blanket” by American Excelsior, “Ero-Mat” by Contech Construction Products, Inc, or approved equal.
4. Bonded fiber matrix for mulching in areas where slopes are 1.5H:1V or greater, or cut or fill slopes 20 feet (6m) or more in height. Product shall be EcoAegis as manufactured by Canfor, or approved equal meeting U.S. DOT Standard Specification FP-96, Section 713.05(h)
 - a. Package Weight: 50 pound (18.6kg) bags.
 - b. Moisture Content: 12 +/- 3 percent by weight.
 - c. Minimum Water Holding Capacity: Approximately 10 times dry weight.
 - d. Composition:
 - 1) Refined Softwood Fiber: (90% by weight).
 - 2) Blended Hydrocolloid-based Binder: (9% by weight).
 - 3) Mineral Activator: (1% by weight).
 - e. Color: Natural – No Dye Products.

C. Water: Clean and potable.

2.2 ACCESSORIES

A. Soil Amendments: Soil amendments are not to be made without review and authorization by the Owner.

1. Lime: Natural limestone containing not less than 85% of total carbonates, ground so that not less than 90% passes a 10-mesh sieve and not less than 50% passes a 100-mesh sieve.
2. Aluminum Sulfate: Commercial grade.
3. Peat Humus: FS Q-P-166 and with texture and pH range suitable for intended use.
4. Bonemeal: Commercial, raw, finely ground; 4% nitrogen and 20% phosphoric acid.
5. Superphosphate: Soluble mixture of treated minerals; 20% available phosphoric acid.
6. Sand: Clean, washed sand, free of toxic materials.
7. Perlite: Conforming to National Bureau of Standards PS 23.

8. Vermiculite: Horticultural grade, free of toxic substances.
9. Sawdust: Rotted sawdust, free of chips, stones, sticks, soil, or toxic substances and with 7.5 pounds (2.8 kg) nitrogen uniformly mixed into each cubic yard of sawdust.
10. Manure: Well-rotted, unleached stable or cattle manure containing not more than 25% by volume of straw, sawdust, or other bedding materials and containing no chemicals or ingredients harmful to plants.
11. Commercial Fertilizer: Complete fertilizer of neutral character, with some elements derived from organic sources and containing available plant nutrients.
12. Composted Organic Material: Shall have a minimum organic matter content of 60 percent, as determined by ASTM D-2974, and screened to ¾-inch (1.9 cm).

PART 3 – EXECUTION

3.1 PREPARATION OF TOPSOIL

- A. Clean topsoil of roots, plants, stones, clay lumps and other extraneous materials harmful or toxic to plant growth.
- B. Mix fertilizer into top 2 inches (5 cm) of topsoil at a rate of 10 pounds (3.7 kg) per 1,000 square feet. (92.9 m²)
- C. Mix approved soil amendments into top 2 inches (5cm) of topsoil at necessary rates.
- D. Water dry topsoil to depth of 4 inches (10cm) at least 48 hours prior to seeding to obtain a loose friable seed bed.

3.2 PREPARATION OF UNCHANGED GRADES

- A. Where lawns are to be planted in areas not altered or disturbed by excavating, grading, or stripping, prepare soil for seeding as follows:
 1. Till to a depth of not less than 6 inches (15cm).
 2. Apply soil amendments and initial fertilizers as specified.
 3. Remove high areas and fill in depressions.
 4. Till soil to a homogeneous mixture of fine texture, free of lumps, clods, stones, roots, and other extraneous matter.
 - a. Prior to preparation of unchanged areas, remove existing grass, vegetation and turf. Dispose of such materials off the site; do not turn over into soil being prepared for lawns.
 - b. Apply specified commercial fertilizer at rates specified and thoroughly mixed into upper 2 inches (5 cm) of topsoil. Delay application of fertilizer, if lawn planting will not follow within one week.

3.3 MULCHING

- A. Spread straw uniformly over seeded and sprigged area with 75% ground coverage and at least 1-½ inches loose depth.

1. If, in the opinion of the Owner, wind will disrupt the mulching, apply asphalt emulsion at a rate of 10 gallons (37.81) per 1,000 square feet (92.9 m²).
- B. Place mulching blanket in accordance with submitted manufacturer's recommendations.
- C. Place bonded fiber matrix mulch material, EcoAegis, at a rate of 3,500 to 4,100 pounds per acre, based on manufacturer's recommendations.

3.4 PROTECTION

- A. Immediately after seeding, erect barricades and warning signs as required to protect newly planted areas from pedestrian and vehicular traffic. Maintain barricades throughout maintenance period until grass and/or turf is established.
- B. Repair or replace damaged landscape work as directed by Owner.

3.5 MAINTENANCE

- A. Begin maintenance immediately after seed placement.
- B. Watering:
 1. Keep soil moist during seed germination period.
 2. Supplement rainfall to produce a total depth penetration of 2 inches per day after germination.
 3. Prevent erosion and displacement of seed.
- C. Mowing:
 1. When grass reaches 4 inches in height, mow to 2-½ inches in height.
 2. Maintain grass between 1-½ inches and 2-½ inches in height.
 3. Do not cut off more than 30% of grass leaf in a single mowing.
 4. Remove grass clippings.
- D. Reseed and mulch spots larger than 1 square foot not having uniform coverage.
- E. Maintain lawns by watering, fertilizing, weeding, mowing, trimming, and other operations such as rolling, regrounding, and replanting as required to establish a smooth, acceptable lawn, free of eroded or bare areas.
- F. Maintain and protect all seeded areas until final acceptance of the Contract. Final acceptance of "Turf and Grasses" will not be made until an acceptable uniform stand of grass is obtained in all new lawn areas, except that the Owner at their discretion may accept a portion or portions of the "Turf and Grasses" at various times. Upon acceptance by the of a seeded area, the Owner will immediately assume responsibility for maintenance and protection of that portion of the Contract Seeding.

END OF SECTION

SECTION 329223.10 – SODDED ATHLETIC FIELDS

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes preparation of ground surfaces, fertilizing, sodding, mulching, and maintenance of turf areas as shown on the Drawings or as specified herein.

1.2 SUBMITTALS

- A. Quality Control Submittals:

- 1. Certification:

- a. Submit manufacturer's or vendor's certified analysis for soil amendments and fertilizer materials.
 - b. Submit vendor's certified analysis for each grass required, stating botanical and common name.

1.3 QUALITY ASSURANCE

- A. All work shall be performed by one (1) Contractor, with proven experience in this field.
- B. Package standard products with the manufacturer's certified analysis. For other materials, provide analysis by recognized laboratory made in accordance with methods established by the Association of Official Agriculture Chemists, wherever applicable.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Deliver packaged materials in containers showing weight, analysis and name of manufacturer. Protect materials from deterioration during delivery, and while stored at site.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Fertilizer:

- 1. Commercial starter fertilizer (19-26-5) with fine particles, chemically homogeneous, having a minimum 75% of total nitrogen (19%) derived from urea and methylene ureas and a minimum of 26% monoammonium phosphate.
 - 2. The POLY-S fertilizer shall be a 19-3-19* analysis, uniform particle size, have a minimum of 97% of the total nitrogen (19%) derived from polymer encapsulated coated urea, a minimum of 3% monoammonium phosphate and 19% from potassium sulfate.
 - 3. The POLY-S product NPK Turf Fertilizer with Minors (19-3-19) shall be applied as specified.

B. Grass Materials:

1. Sod: Provide machine-cut, strongly rooted, certified turf grass sod, at least 18 months old and free of weeds, non-organic contaminants and undesirable native grasses. Provide sod capable of vigorous growth and development when planted and complying with the following requirements:
 - a. Type: Sod shall consist of a Bermuda type sod.
 - b. Sod Roll Size: Uniform thickness of 1 inch, plus or minus 1/8 inch (.31cm), measured at time of cutting and excluding top growth and thatch. Provide turf that measures a minimum of 24 inches wide and 50 feet in length. Broken or torn rolls or rolls with uneven ends are not acceptable.
 - c. Sod Strength: Provide sod pads capable of supporting their own weight and retaining size and shape when supplier's standard size pad is suspended vertically from a firm grasp on upper 10 percent of the pad.
 - d. Grown on a sand-based soil (Sandy Loamy Sand or Sandy Loam). Sod grown on a muck soil bed is not allowed.

C. Water: Clean, potable.

2.2 ACCESSORIES

A. Soil Amendments:

1. Soil amendments are not to be made without review and authorization by the Architect.
2. Lime: Natural limestone containing not less than 85% of total carbonates, ground so that not less than 90% passes a 10-mesh sieve and not less than 50% passes a 100-mesh sieve.
3. Herbicide: Apply a pre-emergent herbicide to the installed topsoil. Apply a post-emergent herbicide when weed infestation exceeds 5% of any planted grass area. Reapply post-emergent herbicide application until weeds are eradicated.

PART 3 – EXECUTION

3.1 PREPARATION OF ROOT ZONE MATERIAL

- A. Mix fertilizer into top 4 inches (10.16 cm) of root zone at a minimum rate of 6 lbs. (2.72 kg) per 1000 square feet for the starter fertilizer and at a minimum rate of 7 lbs. (3.17 kg) per 1000 square feet (92.90 m²) for the POLY-S fertilizer.
- B. Mix approved soil amendments into top 4 inches (10.16cm) of root zone at necessary rates.
- C. Water dry root zone to depth of 4 inches at least 48 hours prior to sodding to obtain a loose friable planting bed.
- D. The final planting bed must be smooth and surface free from water holding depressions or pockets.

3.2 SODDING NEW TURF AREAS

- A. Lay sod within 24 hours of harvesting. Do not lay if ground is frozen.

- B. Lay sod to form solid mass with tightly fitted joints in a direction parallel to the width of the field. Butt ends and sides of sod strips; do not overlap. Stagger strips to offset joints in adjacent courses. Work from boards to avoid damage to subgrade or sod. Tamp or roll lightly to ensure contact with subgrade. Work sifted soil into minor cracks between pieces of sod; remove excess to avoid smothering adjacent grass.
- C. Water sod with fine spray immediately after planting. During first week, water daily or more frequently as necessary to maintain moist soil to depth of 4 inches (10.16cm).

3.3 PROTECTION

- A. Erect barricades and warning signs as required to protect newly planted areas from pedestrian and vehicular traffic. Maintain barricades throughout maintenance period until turf is established.

3.4 MAINTENANCE

- A. Begin maintenance of turf immediately after each area is planted and continue for the periods required to establish acceptable turf, but no less than the following:
 - 1. Sodded turf, at least 30 days after date of substantial completion of turf installation.
- B. Maintain turf by watering, fertilizing, weeding, mowing, trimming, and other operations such as rolling, regarding, replanting as required to establish a smooth, acceptable turf, free of eroded or bare areas.
- C. Resod bare areas with same materials specified for turf.
- D. Watering: Provide water to keep turf areas uniformly moist as required for proper growth. Apply a minimum of 1.5 inches (3.81cm) of water per week to all turf grass or more if directed by Landscape Architect during hot, dry and/or windy periods.
- E. Mow turf as soon as there is enough top growth to cut with mower set at specified height for principal species planted. Repeat mowing as required to maintain specified height. Remove no more than 30 percent of grass leaf growth in initial or subsequent mowings. Do not delay mowing until grass blades bend over and become matted. Do not mow when grass is wet. Time initial and subsequent mowings to maintain following grass height:
 - 1. Mow grass from 1 inch to 3/4 inch high.
- F. Apply second fertilizer application after first mowing and when grass is dry.
 - 1. Use fertilizer that will provide at least 1.0 lb. (.453 kg) of actual nitrogen per 1,000 sq. ft. (92.90m²) of lawn area.

3.5 ACCEPTANCE

- A. When work is substantially completed, including maintenance, Landscape Architect will, upon request, make an inspection to determine acceptability.
 - 1. Sodded fields will be inspected for acceptance in whole, agreeable to Landscape Architect, provided work offered for inspection is complete, including maintenance.
- B. Resod rejected work and continue specified maintenance until reinspected by Landscape Architect and found to be acceptable.

- C. Sodded turf will be acceptable provided requirements, including maintenance, have been met and healthy, well-rooted (minimum 1" depth), even-colored, viable lawn is established, free of weeds, open joints, bare areas, and surface irregularities.

3.6 CLEANUP

- A. Promptly remove soil and debris created by turf work from paved areas. Clean wheels of vehicles before leaving site to avoid tracking soil onto surface of roads, walks, or other paved areas.

END OF SECTION

SECTION 330500 – COMMON WORK RESULTS FOR UTILITIES

PART 1 – GENERAL

1.1 SUMMARY

- A. This section includes the installation of buried piping.

1.2 REFERENCES

- A. The following references shall be applicable: American Society of Testing and Materials (ASTM).
 - 2. American National Standards Institute (ANSI).
 - 3. American Water Works Association (AWWA).
 - 4. Uni-Bell Plastic Pipe Association.

1.3 SUBMITTALS

- A. Submit for approval a schedule for all proposed testing. Include proposed testing procedures indicating the sequence in which pipe sections will be tested and description of methods and equipment to be used.
- B. Field Test Reports: Submit results of field testing directly to Engineer with copy to Contractor

1.4 STORAGE, AND HANDLING

- A. Deliver and store materials within the Contract limits as approved by Engineer.
- B. Handle materials carefully with approved handling devices in accordance with manufacturer's recommendations. Special care shall be exercised during delivery and storage to avoid damage to the materials.
- C. Do not drop or roll products off trucks. Products are not to be otherwise dragged, rolled, or skidded.
- D. Materials shall be stored on heavy wood blocking or platforms in accordance with the manufacturer's instructions and recommendations. Materials shall not be in contact with the ground and their interiors shall be maintained free from dirt and other foreign matter.
- E. Products cracked, gouged, chipped, dented, or otherwise damaged will not be approved and are to be removed and replaced at the Contractor's expense, unless the product can be repaired in a manner acceptable to the manufacturer and the Engineer. All repairs shall be at the Contractor's expense.

1.5 COORDINATION

- A. Contractor shall be responsible for coordinating site utility work with other trades to ensure building service connection locations are verified and coordinated prior to commencing site construction.

PART 2 – PRODUCTS

2.1 MATERIALS

- A. Conform to individual pipe specification(s).

- B. Pipe transition fittings: Shall be as indicated on the drawings. If not specifically indicated selection shall be based on pressure requirements of the system and types of materials being joined. Product selection shall be approved by the engineer.
- C. Grout:
 - 1. Description: ASTM C1107, Grade B, nonshrink and nonmetallic, dry hydraulic-cement grout.
 - a. Characteristics: Post hardening, volume adjusting, nonstaining, noncorrosive, nongaseous, and recommended for interior and exterior applications.
 - b. Design Mix: 5000 psi (34.5 MPa), 28-day compressive strength.
 - c. Packaging: Premixed and factory packaged.

PART 3 – EXECUTION

3.1 UTILITY DEMOLITION

- A. Disconnect, demolish, and remove piped utility systems, equipment, and components indicated to be removed.
 - 1. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
 - 2. Piping to Be Abandoned in Place: Drain piping. Fill abandoned piping with flowable fill, and cap or plug piping with same or compatible piping material.
 - 3. Equipment to Be Removed: Disconnect and cap services and remove equipment.
 - 4. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make operational.
 - 5. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.

3.2 BURIED PIPE INSTALLATION

- A. General:
 - 1. Installation of all pipe, fittings, valves, specials, and appurtenances shall be subject to the review and/or approval of the Engineer.
 - 2. Install piping valves and fittings as shown, specified and as recommended by the manufacturer and in conformance with referenced standards, and approved Shop Drawings.
 - 3. Request instructions from Engineer before proceeding if there is a conflict between the manufacturer's recommendations and the Drawings or Specifications.
 - 4. All piping and appurtenances shall be inspected by the Engineer prior to installation. Engineer's inspection will not relieve Contractor or manufacturer from responsibility for damaged products.
 - 5. Present all conflicts between piping systems and equipment, structures or facilities to Engineer for determination of corrective measures before proceeding.
 - 6. Take field measurements prior to installation to ensure proper fitting of Work. Uncover the existing pipelines sufficiently in advance of the proposed Work in order that the type and location of the existing pipes and joints and other information required to fabricate the proposed piping can be determined. Obtain whatever information is required to complete the connections of the proposed pipelines to the existing pipelines.
 - 7. Carefully examine all piping for cracks, damage, or other defects before installation. Immediately remove defective materials from the site, unless the defective materials can be repaired in a manner acceptable to the manufacturer and Engineer. Remove, replace, or repair at the Contractor's expense piping found to be broken or defective.

8. Inspect interior of all piping and mating surfaces and remove all dirt, gravel, sand, debris, or other foreign material before installation. Maintain the interior of all piping clean until acceptance of the completed Work. Prevent foreign matter from entering joint space.
9. Install buried piping accurately to line and grade shown, specified or directed, unless otherwise approved by the Engineer. Use accurate means of determining and checking the alignment and grade subject to the approval of the Engineer. Remove and relay piping that is incorrectly installed at Contractor's expense.
10. Do not lay piping in water, unless approved by the Engineer. Ensure that the water level in the trench is at least 6 inches below the bottom of piping. Maintain a dry trench until jointing and backfilling are complete, unless otherwise specified in these Specifications or approved by the Engineer.
11. Pipe laying work shall be conducted so that trenching operations are not advanced too far ahead of the pipe laying operation resulting in excessive lengths of open trench. In general, open trench ahead of pipe laying shall not exceed 50 feet.
12. Start laying piping at lowest point and proceed toward the higher elevations, unless otherwise approved by the Engineer. Slope piping uniformly between elevations shown on the Drawings or as otherwise provided by the Engineer.
13. Where pipe crossings occur, the lower pipe shall be laid first and all backfill thoroughly compacted to the level of the higher pipe before the higher pipe is installed. Backfill material under such conditions may be earth, broken stone, or 2500 psi concrete.
14. Install piping so that the barrel of the piping and not the joints receives the bearing pressure from the trench bottom, or other bedding condition.
15. No piping shall be brought into position until the preceding length, valve, fitting, or special has been bedded and secured in place.
16. Whenever pipe laying is not actively in progress, the open ends of the piping shall be closed by a temporary plug or cap to prevent soil, water and other foreign matter from entering the piping.
17. Where required for inserting valves, fittings, special appurtenances, and closures, shall be made with a machine specially designed for cutting piping and in accordance with the manufacturer's instructions for field cutting of pipe. Make cuts carefully, without damage to piping, so as to leave a smooth end at right angles to the axis of the piping. Taper cut ends and file off sharp edges until smooth. Flame cutting will not be permitted. Replace and repair damaged piping.
18. Blocking under piping will not be permitted unless specifically approved by Engineer for special conditions.
19. Touch up protective and linings and coatings prior to installation.
20. Rotate piping to place outlets in proper position.

B. Bedding and Backfilling:

1. Bedded and installed piping in conformance with Section "Trenching and Backfilling" and as shown except as otherwise specified.
2. No piping shall be laid until Engineer approves the bedding condition.
3. Excavation in excess of that required as shown on the Drawings or specified, which is not authorized by the Engineer, shall be at the Contractor's expense. Backfilling and compaction of the over-excavated areas shall be at the Contractor's expense.
4. Carefully and thoroughly compact all pipe bedding and fill up to the pipe centerline with hand-held pneumatic compactors.

C. Restraints, Supports, and Thrust Blocks:

1. Install restrained joints as shown, specified, required, and as recommended by manufacturer. Assembly of restrained joints shall be in strict accordance with manufacturer's recommendations.

2. Provide concrete and metal cradles, collars, and blocks as shown on the Drawings or otherwise required by Engineer.
 3. Thrust Blocks:
 - a. Provide concrete thrust blocking to resist test pressure on all plugs, caps, tees, bends and other fittings in pressure piping systems unless otherwise shown on the Drawings.
 - b. Conform to the details for concrete thrust blocks and tie rods.
 - c. Concrete: 3000 psi, placed around the fittings to completely fill the space between the fittings and the undisturbed walls of the trench. Do not overlap any joint with concrete and place concrete so as not to interfere with removing or installing any of the jointing hardware.
 4. Retainer Glands (for water distribution piping):
 - a. Provide retainer glands for joint restraint of all fittings and valves.
 - b. Retainer glands shall be Megalug Series 1100 as manufactured by EBAA or approved equal.
- D. Transitions From One Type of Pipe to Another:
1. Provide all necessary adapters, specials, and connection pieces required when connecting different types and sizes of pipe or connecting pipe made by different manufacturers.
- E. Work Affecting Existing Piping:
1. Location of Existing Piping:
 - a. Locations of existing piping shown shall be considered approximate. Contractor shall perform all necessary subsurface investigation to verify actual locations in the field.
 - b. Determine exact location of existing piping to make connections, relocate, replace or which may be disturbed during earth moving operations, or which may be affected by work in any way.
 - c. Coordinate all excavations with utility companies, Owner and Engineer.
 2. Taking Existing Pipelines Out of Service:
 - a. Do not take pipelines out of service unless specifically approved by Engineer.
 - b. Notify Engineer at least 48 hours prior to taking any pipeline out of service.

3.3 SPECIFIC PIPE INSTALLATION

- A. Polyvinyl Chloride Pipe (PVC):
1. Gravity Sewers: Install all PVC piping in accordance with ASTM D234 "Standard Practice for Underground Installation of Thermoplastic Pipe for Sewers and Other Gravity Flow Applications."
 2. Water Distribution/Pressure Sewers: Install all PVC pipe in accordance with AWWA Standard C605 "Underground Installation of PVC Pressure Pipe and Fittings for Water."
 3. Lay pipe with bell and spigot joints with bells upstream.
 4. Completely clean all jointing surfaces and adjacent areas prior to making joint.
 5. Field cut pipe for shorter than standard pipe lengths. Cut ends square and perpendicular to the pipe axis. Remove and smoothly bevel ends. Field spigots shall be stop marked with a felt tip mark or wax crayon for proper length of assembly insertion. The angle and depth of field bevels, and lengths to stop marks, shall be comparable in quality to factory made spigots.
 6. Assemble all joints in accordance with recommendations of the manufacturer. If a lubricant is required to facilitate assembly, it shall have no detrimental effect on the gasket or on the pipe when subjected to prolonged exposure.

7. Rotate the spigot by hand or with a strap wrench to verify proper jointing. If unusual joining resistance is encountered or if the insertion mark does not reach the flush position, disassemble the joint, inspect for damage, reclean the joint components and repeat the assembly steps.
8. Use a bar and wood blocking to properly seat pipe joints. **DO NOT USE BACKHOE BUCKET, OR SIMILAR MACHINERY, TO FORCE JOINT ASSEMBLY.**

B. High Density Polyethylene Gravity Piping (HDPE):

1. Install in accordance with the pipe manufacturer's specifications
2. Completely clean all jointing surfaces and adjacent areas prior to making joints.
3. Field cut pipe for shorter than standard pipe lengths. Cut ends square and perpendicular to the pipe axis. Remove and smoothly bevel ends.
4. Assemble all joints in accordance with recommendations of the manufacturer. If a lubricant is required to facilitate assembly, it shall not have a detrimental effect on the gasket or on the pipe when subjected to prolonged exposure.

3.4 FIELD QUALITY CONTROL

A. General:

1. Notify Engineer at least 48 hours in advance of all testing.
2. Provide all testing apparatus including pumps, hoses, gauges, fittings, temporary bulkheads, plugs, compressors and miscellaneous other required items.
3. Provide temporary blocking and bracing or approved thrust and joint restraint to prevent joint separation and pipe movement during testing.
4. Unless otherwise approved, conduct all tests in the presence of the Engineer and in the presence of local authorities having jurisdiction.
5. Water Source:
 - a. Provide all water for testing, flushing, and other water uses. The source of the water shall be subject to the approval of the Engineer.
 - b. The point of introduction of water for conducting tests shall be subject to the approval of the Engineer.
6. All costs for tests shall be included in the Contractor's bid.
7. Locate, and repair or replace, section of piping which fail the test and retest until acceptance.

B.

B. Required Tests for Waterlines and Force Mains:

1. Pressure and leakage test shall comply with the most current revision of AWWA C600.
2. Perform the following after the pipe has been installed and prior to final acceptance:
 - a. Pressure Test.
 - b. Leakage Test.
3. Presumptive hydrostatic tests may be performed when the system is partially backfilled to "check" the work, but final acceptance shall be based on hydrostatic tests performed on the finished system after it is completely backfilled.
4. Pressure Test:
 - a. Test piping to 1.5 times the pipe working pressure, or 150 psi, whichever is greater. Measure test pressures at the lowest point in the pipe section and correct to the elevation of the gauge.
 - b. Relieve trapped air at the section high points through hydrants, or taps installed for this purpose, provided temporary installations are removed and plugged after acceptance.
 - c. Maintain the test pressure for a period of 2 hours. At the end of the test period, if the test pressure remains constant, the pipe section shall have passed the test. If the pressure has

dropped, it shall be brought back to the test pressure by pumping a known volume of water (by pumping from a graduated container or by metering) back into the pipe. The volume of water thus used, representing leakage from the pipe, shall be recorded. If the leakage is less than the allowable leakage specified below, the pipe shall have passed the test. If the leakage exceeds the allowable leakage specified, the Contractor shall locate the leak, permanently repair the section of pipe where the leak is occurring to the satisfaction of the Engineer, and retest the pipe as specified above.

5. Leakage Test:

- a. Conduct the leakage test concurrently with the pressure test.
- b. Perform the leakage test in accordance with all applicable AWWA standards.
- c. The maximum allowed leakage is determined by the following formula:

$$\frac{L = S \times D \times P^{1/2}}{148,000}$$

where L = allowable leakage, in gph

where S = length of pipe tested, in feet

where D = nominal pipe diameter, in inches

where P = average test pressure, in psig

HYDROSTATIC ALLOWABLE LEAKAGE PER 1,000 FEET OF PIPELINE ^A (gph) ^B												
AVG. TEST PRESSURE (psi)	NOMINAL PIPE DIAMETER (INCHES)											
	3	4	6	8	10	12	14	16	18	20	24	30
450	0.43	0.57	0.86	1.15	1.43	1.72	2.01	2.29	2.58	2.87	3.44	4.30
400	0.41	0.54	0.81	1.08	1.35	1.62	1.89	2.16	2.43	2.70	3.24	4.05
350	0.38	0.51	0.76	1.01	1.26	1.52	1.77	2.02	2.28	2.53	3.03	3.79
300	0.35	0.47	0.70	0.94	1.17	1.40	1.64	1.87	2.11	2.34	2.81	3.51
275	0.34	0.45	0.67	0.90	1.12	1.34	1.57	1.79	2.02	2.24	2.69	3.36
250	0.32	0.43	0.64	0.85	1.07	1.28	1.50	1.71	1.92	2.14	2.56	3.21
225	0.30	0.41	0.61	0.81	1.01	1.22	1.42	1.62	1.82	2.03	2.43	3.04
200	0.29	0.38	0.57	0.76	0.96	1.15	1.34	1.53	1.72	1.91	2.29	2.87
175	0.27	0.36	0.54	0.72	0.89	1.07	1.25	1.43	1.61	1.79	2.15	2.68
150	0.25	0.33	0.50	0.66	0.83	0.99	1.16	1.32	1.49	1.66	1.99	2.48
125	0.23	0.30	0.45	0.60	0.76	0.91	1.06	1.21	1.36	1.51	1.81	2.27
100	0.20	0.27	0.41	0.54	0.68	0.81	0.95	1.08	1.22	1.35	1.62	2.03
^A If the pipeline under test contains sections of various diameters, the allowable leakage will be the sum of the allowable leakage for each size.												
^B Calculated on the basis of the formula above.												

6. Acceptance shall be determined on the basis of allowable leakage. If any pipe section discloses leakage greater than that specified, locate, repair, and retest until the leakage is within the limits specified.
7. Make all visible leaks tight regardless of the amount of leakage; and if the lines do not meet the above leakage test, repair and retest as necessary until the leakage requirement is met. Repair or replace all defective work.

C. Required Tests for Storm Sewers:

1. Perform the following tests after the storm drainage pipe has been installed and prior to final acceptance:

- a. Alignment Test for all pipe.
2. Based upon visual observations, the Engineer may order additional testing including the following:
 - 1) Television Inspection, if required by the Engineer.
 - 2) Deflection Test, if required by the Engineer
 - 3) Water-tight field test ASTM F1417 if required by the Engineer.
3. Perform tests prior to placement of pavement, or other construction which may, in the opinion of the Engineer, be detrimentally affected by excavation required for repairs.
4. Submit details prior to making tests of proposed testing procedures with a description of methods and equipment to the Engineer for approval.
5. Alignment Test:
 - a. All storm drainage pipe will be subject to a visual inspection in order to identify proper alignment, grade, and excessive deflection.
 - b. The Engineer may choose to perform an alignment test using the hand-lamp method, in which case the full diameter of the pipe shall be visible when viewed between consecutive structures.
6. Television Inspection:
 - a. The Engineer will notify the Contractor in writing which completed sewers shall be inspected by closed-circuit television.
 - b. The Contractor shall commence the television inspection within 15 days of the Engineer's written notification. The Contractor shall notify the Engineer at least 5 days prior to commencement of television inspection.
 - c. No television inspection shall be performed without the Engineer or his representative present to witness the inspection.
 - d. The Contractor shall provide the Engineer with 3 copies of a report of the televising inspection of each section of completed sewer inspected. Show the exact location and extent of all cracks, loose joints, holes, vertical and horizontal, misalignment, faulty service connections, caved-in pipe, points of infiltration, obstructions, debris and all else detrimental to the proper functioning and service of the completed sewer. The Contractor shall provide the actual television inspection video with the report showing all the above conditions found, at all wyes, tees and laterals and as directed by the Engineer.
 - e. The Engineer will review the report and will instruct the Contractor, to repair any conditions which, in the opinion of the Engineer, are detrimental to the proper function and service of the storm pipe.
7. Deflection Test:
 - a. The Engineer will notify the Contractor in writing which completed sewers shall be tested by the deflection method.
 - b. The Contractor shall commence the deflection test within 15 days of the Engineer's written notification. The Contractor shall notify the Engineer at least 5 days prior to commencement of television inspection.
 - c. No Deflection testing shall be performed without the Engineer or his representative present to witness the test.
 - d. The deflection test shall be performed on flexible drainage pipe with a "go/no-go" mandrel with a diameter equal to 95 percent of the inside diameter of the pipe being tested.
 - e. The maximum pipe deflection shall be 5 percent.
 - f. The Engineer will review the Deflection Test results and will instruct the Contractor, to repair any conditions which, in the opinion of the Engineer, are detrimental to the proper function and service of the storm pipe.

8. Visual Inspection: Prior to final acceptance, a visual inspection of all appurtenance structures (i.e., manholes, chambers, etc.) will be required. Repair visual leaks, regardless of their magnitude.

END OF SECTION

SECTION 334100.20 – HIGH DENSITY POLYETHYLENE STORM UTILITY DRAINAGE PIPING

PART 1 – GENERAL

1.1 SUMMARY

- A. This Section includes the installation of polyethylene piping systems as shown on the Drawings and as specified herein.
- B. All piping, fittings, and appurtenances shall be new, clean, and in accordance with material specifications. In no instance shall second- hand or damaged materials be acceptable.

1.2 QUALITY ASSURANCE

- A. Reference Standards:
 - 1. The latest edition of the following standards, as referenced herein, shall be applicable:
 - a. Standard Specifications for Highway Materials and Methods of Sampling and Testing, American Association of State Highway and Transportation Officials (AASHTO).
 - b. American Society of Testing and Materials (ASTM).

1.3 SUBMITTALS

- A. Product Data:
 - 1. Submit manufacturer's catalog cuts, specifications, and installation instructions for both pipe and coupling system.
 - 2. Submit manufacturer's certification that product was manufactured, tested, and supplied in accordance with the standards specified herein.

1.4 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Delivery and Storage:
 - 1. Pipe, fittings, specials, appurtenances, and accessories shall be delivered to and stored within the Contractor's work limits as shown on the Drawings.
 - 2. Special care shall be exercised during delivery and storage to avoid damage to the products.
 - 3. Products shall be stored so as to avoid unnecessary handling and in locations where they will not interfere with the Owner's operations or public travel.
- B. Handling:
 - 1. Pipe, fittings, special appurtenances, and accessories shall be handled carefully with approved handling devices in strict conformance with the manufacturer's recommendations.
 - 2. Products shall not be dropped nor shall products be otherwise dragged, rolled, or skidded.
- C. Products cracked, gouged, chipped, dented, or otherwise damaged will not be approved and shall be removed and replaced at the Contractor's expense, unless the product can be repaired in a manner acceptable to the manufacturer and Engineer. All repairs shall be at the Contractor's expense.

PART 2 – PRODUCTS

2.1 MATERIALS

A. HDPE Water Tight Pipe:

1. Pipe shall be ADS N-12 WT IB (per AASHTO) smooth interior with annular exterior corrugations and a Manning's "n" value of 0.012 high-density polyethylene pipe (HDPE) as manufactured by Advanced Drainage Systems (ADS) or approved equal. Pipe shall have an integral water tight gasketed bell and spigot or approved equal.
 - a. 4 inches through 11 inches conforming to AASHTO M252 Type S.
 - b. 12 inches through 60 inches conforming to AASHTO M294 Type S or ASTM F2306.
2. 4 inches through 60 inches (100 to 1500 mm) shall be watertight according to the requirements of ASTM D3212. Gaskets shall be made of polyisoprene meeting the requirements of ASTM F477. Gaskets shall be installed by the pipe manufacturer and covered with a removable, protective wrap to ensure the gasket is free from debris. A joint lubricant available from the manufacturer shall be used on the gasket and bell during assembly 12- through 60-inch (300 to 1500 mm) diameters shall have a reinforced bell with a bell tolerance device. The bell tolerance device shall be installed by the manufacturer.
3. Fittings shall conform to ASTM F2306. Bell and spigot connections shall utilize a spun-on or welded bell and valley or saddle gasket meeting the water-tight joint performance requirements of ASTM F2306.

B. Flared End Section:

1. Flared end sections shall be 1210 NP or 1810 NP HDPE end sections as manufactured by ADS or equal.
2. End sections shall be fastened to the last corrugation of the pipe length using a high strength nylon cable tie supplied by the manufacturer through pre-drilled holes at the top of the end section collar.

PART 3 – EXECUTION

3.1 INSPECTION

- A. Inspect all pipe and fittings prior to laying in the trench. Remove defective pipe and fittings from the site.
- B. Do not backfill until inspection by the Engineer, unless otherwise approved by the Engineer.

3.2 INSTALLATION AND TESTING

- A. Trenching, backfilling and compaction shall conform to Section "Trenching and Backfilling."
- B. Pipe installation and testing shall conform to Section "Common Work Results for Utilities."

END OF SECTION