



**Board of Education**  
Chris Proudfoot, President  
John Cole  
Kerri Condley  
Karalee Hargrove  
L. Hilary Slotta

5715 Utah Trail (P.O. Box 1209), Twentynine Palms, CA 92277 (760) 367-9191 or 365-3394 Fax: (760) 367-7189

Tom Baumgarten  
District Superintendent

**DATE:** May 23, 2019

**SUBJECT:** Addendum #1 – Bid #19-00 Re-Roofing at Yucca Valley High School

### **NOTICE TO CONTRACTORS**

This Addendum forms a part of the contract documents and modifies the original bidding documents. Modify the following items wherever appearing in the contract documents and bid document package. **Acknowledge receipt of Addendum #1 in the space provided on the bid form. Failure to do so may subject bidders to disqualification.**

### **REVISION OF DOCUMENTS**

**Site:** Yucca Valley High School

#### **Item #1 – Sealing of Exposed Duct Work on Wrestling Room Roof Section:**

1. The exposed duct run on the Wrestling Room roof section is to be sealed by the contractor as follows:
  - a. Remove existing failed repairs at seams to provide smooth substrate.
  - b. Install a three course application of SolarGard Acrylic Sealer and Polyester reinforcement to all duct work seams.
  - c. Coat exposed duct work with SolarGard 6083 base and top coat according to manufacturer application requirements.

#### **Item #2 – Coping Metal Seams on Wrestling Room:**

1. All existing coping metal seams on the Wrestling Room roof section are to be sealed with a three course application of SolarGard Acrylic Sealer and Polyester reinforcement.

#### **Item #3 – Correction to Bid #19-00 “Bid Form” Document:**

1. Please use corrected “Bid Form” document with the corrected roofing system details, (see attachment for correct form.)

If you should have any questions regarding the above change, please contact me at your earliest convenience.

Sincerely,

A handwritten signature in cursive script that reads "David Daniels".

David Daniels  
Director  
Maintenance & Operations

cc: Marilyn Waters, Director, Purchasing  
File